

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001

Fax: 23412593 E-mail:cfhq.dlfire@nic.in

No

FG/DFS/MS/2014/ND2/49


Dated

13-01-2014

FIRE SAFETY CERTIFICATE

Certified that the M/s Chem House, Plot No.3, U-179, Shakarpur, Delhi comprises of ground floor was granted NOC by this department. vide letter No. F5/ DFS / MS/3A/2010 / 51 dated 15- 02- 2011. The premises was re-inspected by the officer concerned of this department on 05-12-2013 in the presence of Mr. Subhash Gupta (Prop) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class storage of sulphur with effect from 13 - 01 - 2014 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 13-01-14 at New Delhi.



(DR. G.C.MISRA)
Chief Fire Officer
Delhi Fire Service
Ph. 23414333

5.1.14

Copy to:-

1. M/s Chem House,
Plot No.3, U-179, Shakarpur,
Delhi.
2. Addl. Commissioner of Police (Lic)
1ST Floor, Police Station,
Defence Colony, New Delhi.

Condition

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, the management shall be responsible.
4. The clarification with regards to electrical installation, ventilation, structure stability set back areas, occupancy and construction deviation in building etc. may be got verified from the authorities concerned.
5. This certificate can not be treated in any case for regularization of unauthorized construction, unauthorized use of land, if any.
6. The owner/occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

-N/24-

INSPECTION REPORT

1. Name & address of the building : Chem House, Plot No. 3, U-179,
Shakarpur, Delhi.
2. Building is comprised of : Ground floor.
3. Type of Occupancy : Storage
4. Type of Case : Renewal
5. Details of Previous NOC Letter: F5/DFS/MS/3A/2011/51dated
15.2.2011
6. Fire Safety directive letter No : NA
7. Date of Inspection : 5.12.2013
8. Name of the Inspecting officers : Gurmukh Singh
9. Name and designation of Officer:
from the building side : Mr. Subhash Gupta. (Prop)
10. Year of Construction : old building
11. Applicant's letter No : 69743-44/JointCP/Lic.(Expl.)
dated. 14.11.2013

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	Exiting Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none">• Road width• Gate width• Width of internal road	Motorable NA NA	4 Mtrs. NA NA	MR (old case) NA NA
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none">• Upper Floor• Basement	NA NA	NA NA	NA NA
	B. Width of Staircases			
	<ul style="list-style-type: none">• Upper Floor• Basement	NA NA	NA NA	NA NA
	c. Protection of exits			
	<ul style="list-style-type: none">• Fire check door• Pressurization	NA NA	NA NA	NA NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	g. Width of Corridor	NA	NA	NA
	h. Door Size	NA	NA	NA

h

N/45

M

3	Compartmentation.	NA		
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire rating of shaft door	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.	NA		
	• Basement	NA	NA	NA
	• Upper floor	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	2nos.	2nos.	MR
	• types	DCP	DCP	MR
	• ISI marking	Required	Provided	MR
6	First-aid-Hose Reels.			
	• Total numbers at ground floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system.	NA		
	• Type of detectors	NA	NA	NA
	• Location of main panel	NA	NA	NA
	• Location of repeater panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooter's location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public address System.	NA	NA	NA
10	Automatic Sprinkler System.	NA	NA	NA
	• Basement	NA	NA	NA
	• upper floor	NA	NA	NA
	• sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			

W

-M/116-

Chem House,
Plot No 3, U-179, Shalimar,
Delhi

	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main Pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby pump out put	NA	NA	NA
	➤ Standby pump Head	NA	NA	NA
	➤ Auto Starting /Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace Level	NA	NA	NA
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the Pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.	NA		
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication in lift car	NA	NA	NA
	• Firemen's grounding switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.	NA	NA	NA
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire Control Room	NA	NA	NA
	• Detector system panel	NA	NA	NA
	• Flow switch panel	NA	NA	NA
	• PA system panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection systems	NA	NA	NA

Dr

	fire protection of special Risks, if any:			
--	---	--	--	--

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no.F5//DFS/MS/3A/2011/51 dated 15.2.2011 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.



Signature of the Inspecting Officer

Name

Guramkh Singh

Designation

DO