

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/DFS/MS/School/2014/02/155

Dated: 31/01/2014

FIRE SAFETY CERTIFICATE

Certified that the **White Leaf Public School, Gali no.-2- 3, Plot no.-89, Pooth Khurd, Delhi-110039** comprised of **Basement + Ground + One Upper Floor** owned/occupied by **White Leaf Public School**, have complied with the fire prevention and fire safety requirements in accordance with the **Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011** issued by Director of Education and verified by the officer concerned of Fire Service on **07/11/2013** in the presence of **Brig. Retd. Ram Darshan** and that the building / premises are fit for occupancy of **Educational** building with effect from **/ 31 / 01 /2014** for a period of **three years**, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 The basement shall be used strictly as per the provision of building bye laws.
- 6 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 31/01/14 at New Delhi


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, White Leaf Public School, Gali no.-2- 3, Plot no.-89, Pooth Khurd, Delhi.
2. The Director of Education, Old Secretariat, Delhi – 110054.



INSPECTION REPORT

(B + G + 1)

1. Name & address of the building : White Leaf Public School, Gali no.-2-3, Plot no.-89, Pooth
Khurd, Delhi-110039
2. Type of Occupancy : **Educational**
3. Type of Case : New Case
4. Details of previous NOC : **Nil**
5. Fire Safety directives letter No : Director of education / NBC Part-IV
6. Date of inspection : 07/11/2013
7. Name of the Inspecting Officers : DO(NW)
8. Name and designation of officers
from the building side : Brig Retd. Ram Darshan
9. Year of Construction : 2006
10. Applicant's letter No. : WL/Pooth/59 dated 28/03/2013

Plot area- 2520 Sq.Yds Covered area-2250 Sq. f No's student- 350 No. of Rooms-30 (Class Room-20)

	Minimum Standards on fire prevention and fire safety U/R 33	NBC/Dir of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none">• Road width• Gate width• Width of internal road	Accessible -- --	Accessible -- --	M/R -- --
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none">• Upper Floors• Basements	02 02	02 05 Basement to GF	M/R M/R
	b. Width of staircases			
	<ul style="list-style-type: none">• Upper Floors• Basements	1.5 mtr 1.5 mtr (B to G)	02 - 1.5mtr 04 of 1.5 mtr 01 of 135 - 145 cm	M/R M/R
	c. Protection of exits			
	<ul style="list-style-type: none">• Fire check door• Pressurization	-- --	-- --	-- --
	e. No. of continuous staircases to terrace			
	g. Width of Corridor	--	--	--
	h. Door Size			

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	--	--	--
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	--	--	--
	<ul style="list-style-type: none"> • Water Curtain 	--	--	--
	<ul style="list-style-type: none"> • Fire Dampers 	--	--	--
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	--	--
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	--	--
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	10	10	M/R
	<ul style="list-style-type: none"> • Types 	ABC	ABC	M/R
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Yes	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	N.A	P	N/A
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	P	N/A
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	P	N/A
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Hooters' Location 	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	R	P	M/R
	<ul style="list-style-type: none"> • Upper Floor 	--	--	--
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	--	--	--

11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	--	--	--
	<ul style="list-style-type: none"> • Number of hydrants per floor 	--	--	--
	<ul style="list-style-type: none"> • Hose Box 	--	--	--
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants 	--	--	--
	<ul style="list-style-type: none"> • Hose Box 	--	--	--
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	--	--	--
	<ul style="list-style-type: none"> ➤ Head of Main pump 	--	--	--
	<ul style="list-style-type: none"> ➤ Number of main pumps 	--	--	--
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	--	--	--
	<ul style="list-style-type: none"> ➤ Jockey pump head 	--	--	--
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	--	--	--
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	--	--	--
	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping 	--	--	--
	<ul style="list-style-type: none"> ➤ Pump House Access 	--	--	--
	<ul style="list-style-type: none"> • Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	450 LPM	P	M/R
	<ul style="list-style-type: none"> ➤ Head of the pump 	--	--	--
	<ul style="list-style-type: none"> ➤ Power Supply 	--	--	--
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	--	--	--
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity 	--	--	--
	<ul style="list-style-type: none"> ➤ Draw-off connection 	--	--	--
	<ul style="list-style-type: none"> ➤ Fire service inlet 	--	--	--
	<ul style="list-style-type: none"> ➤ Access to tank 	--	--	--
	<ul style="list-style-type: none"> • Overhead Tank capacity 	5000 ltr	Provided 10,000 Ltr	M/R
15	Exit Signage.			
		--	--	--

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	--	--	--
18	Refuge Area.			
	➤ Total Area	--	--	--
	➤ Location	--	--	--
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation

put up on 27-1-14
W

[Handwritten Signature]
27/1/14

2/1/14