

M

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/2014/School/WZ/172

Dated: 05/02/2014

FIRE SAFETY CERTIFICATE

Certified that **Shiva Modern School, Daryapur Kalan, Delhi-110039** comprised of **Ground floor** owned/occupied by **Shiva Modern School** has already been issued fire safety certificate **vide letter no. F-6/DFS/MS/2007/472 dated 19/02/2007.** The premises was re-inspected by the officer from this department on **18/01/2014** in the presence of **Smt. Nirmala** and observed that the premise is comprised of Ground + one upper floor all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have there fore deemed complied with the requirements of **circular issued by Director of Education letter dated 17/01/2005** and the building / premise is fit for occupancy of **Group Class B (Educational)** with effect from **05/02/2014** for a period of **three years**, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 05/02/14 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1.  The Principal, Shiva Modern School, Daryapur Kalan, Delhi-110039
2. The Director of Education, Old Secretariat, Delhi

Earlier - Ground floor only.
Presently - Ground + one floor

INSPECTION REPORT

1. Name & address of the building: Shriya Modern School, Dargiya Pur Karkeri, Delhi-30
2. Type of Occupancy : Educational
3. Type of Case : New Case / Renewal
4. Details of previous NOC : F-6/DFE/MS/2007/472 dt-19-2-07 (for Gr. floor only)
5. Fire Safety directives letter No : Dir. of Edu.
6. Date of inspection : 18-1-14
7. Name of the Inspecting Officers : ADP (B.W.)
8. Name and designation of officers from the building side : Smt Nirmala
9. Year of Construction : 1998 & 2009-10
10. Applicant's letter No. : SMS/26/2014 dt-6-1-14

Plot area:- Covered area:- No.'s of students:- No.'s of classrooms:-

	Minimum Standards on fire prevention and fire safety U/R 33	Circular Dir. of Edu Requirement/ NBC	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	—	—	—
	• Upper Floors	1	2	M/R
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	1.50 mts	125 cms & 85 cms	M/R
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	1 mts	95 cm & 1.00 mts old case	M/R ✓

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	—	—	—
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	— —	— —
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	S ABC ISI marked	5 ABC yes	MIR MIR MIR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	— — —	— — —
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	— — — — —	— — — — —	— — — — —
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	— — —	— — —	— — —
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	— — —	— — —	— — —

12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants 			
	<ul style="list-style-type: none"> • Hose Box 			
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pum 			
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity 			
	<ul style="list-style-type: none"> ➤ Draw-off connection 			
	<ul style="list-style-type: none"> ➤ Fire service inlet 			
	<ul style="list-style-type: none"> ➤ Access to tank 			
	<ul style="list-style-type: none"> • Overhead Tank capacity 			
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 			
	<ul style="list-style-type: none"> • Pressurization of Lift lobby 			
	<ul style="list-style-type: none"> • Communication In lift Car 			
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 			
	<ul style="list-style-type: none"> • Lift Signage 			
17	Standby power supply			

18	Refuge Area.			
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	Fire Control Room			
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-6/DFS/MS/2007/472 Dated. 13.11.07...07.. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

DD (N) on BIL
DLFO-402

Signature of the Inspecting Officer

Name

Designation

[Signature]
19/1/14

ADD (BWS)

59/DFP/024
28/1/14.

