

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**  
**Fax: 23412593, Email: cfohq.dfire@nic.in, Tel:- 011-23414333**

NO.F6/ DFS/ MS/School/2014/ 52/165

Dated: 31/01/14

**FIRE SAFETY CERTIFICATE**

Certified that, Sant Nirankari Public School, T-23, Malviya Nagar, Khirki Village Road, New Delhi-110017 comprised of Ground + 02 Upper floors, owned/occupied by Sant Nirankari Public School Management was granted NOC by this department vide letter no F6/DFS/MS/2008/827 Dated-24/03/2008. The school was re-inspected by the officer concerned of this department on 07/01/2014 in presence of Mrs. Sushma Manchanda (Head Mistress) and found that the school have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.262-362 issued by the Directorate of Education dated 17-01-2005 and that the school building is fit for occupancy class "Educational (School)" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the below mentioned conditions.

Issued on 31/01/14 at New Delhi by.



(Dr. G.C. Misra)  
**CHIEF FIRE OFFICER**

9c  
27/1/14  
ADD (2014)

Copy to: -

The Principal,  
Sant Nirankari Public School,  
T-23, Malviya Nagar,  
Khirki Village Road, New Delhi-110017

**Conditions for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

### INSPECTION REPORT

1. Name & address of the building : **Sant Nirankari Public School,T-23,Malviya Nagar,  
(Khirki Village Road) New Delhi-110017**
2. Type of Occupancy : Educational (School)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2008/827 Dated: 24/03/2008
5. Fire Safety directives letter No : Circular No-F.262-362 issued by the Directorate of Education dated  
17-01-2005
6. Date of inspection : 07-01-2014
7. Name of the Inspecting Officers : ADO D.B.Mukherjee
8. Name and designation of officers  
from the building side : Mrs. Sushma Manchanda (Head Mistress)
9. Year of Construction : 1993
10. Applicant's letter No. : Nil dated: 07/10/2013, ( Ground Plus, 2 upper Floor)

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Required	Provided	MR
	• Gate width	Required	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
a. Number of staircases				
• Upper Floors	02		02	MR
• Basements	N/A		N/A	N/A
b. Width of staircases				
• Upper Floors	1.5 m		2 nos. Provided 1.08 m each	MR
• Basement	N/A		N/A	N/A
c. Protection of exits				
• Fire check door	N/A		N/A	N/A
• Pressurization	N/A		N/A	N/A
e. No. of continuous staircases to terrace	01		02	MR
g. Width of Corridor	N/A		N/A	N/A
h. Door Size	N/A		N/A	N/A

3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A
5	<b>Fire Extinguishers</b>			
	• Total numbers	Required	10 nos	MR
	• Types	ABC,CO <sub>2</sub>	Provided	MR
	• IS marking	Required	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	N/A	N/A
9	<b>Public Address System.</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System</b>			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR

12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	<b>Pumping Arrangements</b>			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5000 L	5,000 L	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

✓

2/10

17	Standby power supply	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Provided one CO <sub>2</sub> Fire extinguisher near electric panel board.	MR

The fire protection system provided in the school were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter no F6/DFS/MS/2008/827 Dated-24/03/2008 renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

*[Handwritten Signature]*  
16/1/14

*[Handwritten Signature]*  
13/1/2014

Name (D.B.Mukherjee)

Designation :- Assistant Divisional Officer

DO (South)  
A.S.C. 9/20/14  
H