

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F.6/DFS/MS/ School/2014/204

Dated: 10/02/2014

FIRE SAFETY CERTIFICATE

Certified that G.D. Goenka Public School, Plot No-03, Pocket-7, Sec-22, Rohini, Delhi-110085 comprised of Ground + 3 upper floor owned/occupied by G.D Goenka Public School has already been issued fire safety certificate vide letter no. F-6/DFS/MS/2009/203, dated 23/01/2009 The premises was re-inspected by the officer from this department on dated 08/01/2014 in the presence of Sh. Jony Anthony and observed that a basement also exist in the building & sealed by the owner/occupier. All the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have there fore deemed complied with the requirements of circular issued by Director of Education letter dated 17/01/2005 and the building / premise is fit for occupancy of Group Class B (Educational) excluding basement with effect from 10/02/2014 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.


Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 10/02/14 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, G.D Goenka Public School, Plot No-03, Pocket-7, Sec-22, Rohini, Delhi-110085
 2. The Director of Education, Old Secretariat, Delhi
- 

INSPECTION REPORT**(G + 3)**

1. Name & address of the building : G.D Goenka Public School Sec-22, Rohini Delhi- 86
2. Type of Occupancy : **Educational**
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2009/203 dated 23/01/2009 for (G + 3)
5. Fire Safety directives letter No : Director of Education Circular No-262-362 dt 17/01/2005
6. Date of inspection : 08/01/2014
7. Name of the Inspecting Officers : DO(NW)
8. Name and designation of officers
from the building side : Sh. Sanjay Anthony (Mech Engg.)
9. Year of Construction : 2005
10. Applicant's letter No. : GDGPS/MISC/2013/114 dated 01/10/2013

Plot Area-7999.86 M² , Covered Area- 7413.22 M² , No's of Student-2000 No of Rooms-72

	Minimum Standards on fire prevention and fire safety U/R 33	DOE Circular dt 17/01/2005	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible	Accessible	M/R
		Accessible	Accessible	M/R
		—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	03	06	M/R
		—	sealed	—
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	Old case	Old case	Old case
		—	Found sealed photo attached	—
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	—	—	—
		—	—	—
	d. No. of continuous staircases to terrace	06	06	M/R
	e. Width of Corridor	--	--	--
	f. Door Size	1 mtr	Double door of 1 mtr	M/R

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Water Curtain 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Dampers 	N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	Sealed	—
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	P	M/R
5	Fire Extinguishers-			
	<ul style="list-style-type: none"> • Total numbers 	One @ 300 mtr	40	M/R
	<ul style="list-style-type: none"> • Types 		Co2- 08, ABC-32	M/R
	<ul style="list-style-type: none"> • IS marking 	ISI marked	P	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	R (05)	05	M/R
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	yes	yes
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	P	M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	Smoke	P	M/R
	<ul style="list-style-type: none"> • Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Hooters' Location 	N/A	N/A	N/A
8	MOEFA	R	P	M/R
9	Public Address System.	N/A	P	—
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	R	P	Basement found sealed photo attached
	<ul style="list-style-type: none"> • Upper Floor 	—	—	—
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	—	—	—
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	4"	P	M/R
	<ul style="list-style-type: none"> • Number of hydrants per floor 	05	05	M/R
	<ul style="list-style-type: none"> • Hose Box 	05	05	M/R

12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	1620 LPM	P	M/R
	➤ Head of Main pump	40m	P	M/R
	➤ Number of main pumps	01	P	M/R
	➤ Jockey Pump out put	225 LPM	P	M/R
	➤ Jockey pump head	40m	P	M/R
	➤ Standby Pump out put	—	—	—
	➤ Standby Pump Head	—	—	—
	➤ Auto Starting/ Manual stopping	R	P	M/R
	➤ Pump House Access	R	P	M/R
	• Terrace level			
	➤ Discharge of pump	—	—	—
	➤ Head of the pump	—	—	—
	➤ Power Supply	—	—	—
	➤ Auto Starting of pump	—	—	—
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	50000 ltr	P	M/R
	➤ Draw-off connection	R	P	M/R
	➤ Fire service inlet	R	P	M/R
	➤ Access to tank	R	P	M/R
	• Overhead Tank capacity	20000 ltr	P	M/R
15	Exit Signage.	R	P	M.R
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/R	P	—
	• Lift Signage	N/R	—	—
17	Standby power supply	R	125 & 750 KVA	M/R

N-10

18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	--	--	--

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/2009/203 dated 23/01/2009 Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation

[Handwritten Signature]
9/1/14