

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No. F.6/DFS/MS/School/2014/ *527136*

Dated: *30/11/14*

FIRE SAFETY CERTIFICATE

Certified that the **Banasthali Public School** located at Plot No-16, G-Block, Vikaspuri, New Delhi-110018 comprised of ground floor plus two upper floors, having total 32 rooms (Including Class Rooms, Offices, Sci. Labs, Comp. Lab, Sports Room, Library, Hall & Store etc.) was issued NOC by this department vide letter No.F.6/DFS/MS/09/1869 dated 25.06.2009. The School building was re- inspected by the officer concerned of this department on 22.01.2014 in the presence of Smt. Shashi Mohan (Principal) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....*30/11/2014*..... at New Delhi.


(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Principal,
Banasthali Public School,
Plot No-16, G-Block, Vikaspuri, New Delhi-18.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi – 110 054.

ole
QW

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on **www.dfs.delhigovt.nic.in**

Ground plus two upper floors.

N/B

old cat

(Renewal)

INSPECTION REPORT

1. Name & address of the building : Banasthali Public School, Plot no 16, G-Block, Vikaspuri, Noida-2013018
2. Type of Occupancy : Educational
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F6/DFS/MS/09/1869 Date 25-06-2009
5. Fire Safety directives letter No : _____
6. Date of inspection : 22-01-2014
7. Name of Inspecting Officer : AO Sandeep Duggal
8. Name and designation of officers
From the building side : Smt Shashi Mohan (Principal)
9. Year of Construction : 2000
10. Applicant's letter No. : 235/B.P.S/013/25 dt 16-12-2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p>Accessible</p> <p>—</p>	<p>12 mtr</p> <p>4 mtr</p> <p>—</p>	<p>MR</p> <p>NMR</p> <p>—</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<p>Two</p> <p>—</p>	<p>Two provided</p> <p>—</p>	<p>MR</p> <p>No Basement</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	<p>—</p> <p>—</p>	<p>135cm & 145cm (2000) converge to 210cm</p> <p>—</p>	<p>MR</p> <p>No Basement</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • pressurization 	<p>—</p> <p>—</p>	<p>—</p> <p>—</p>	<p>—</p> <p>—</p>
	d. No. of continuous staircases to terrace			
		<p>—</p>	<p>01</p>	<p>—</p>
	e. Width of Corridor			
		<p>—</p>	<p>160-4130</p>	<p>—</p>
	f. Door Size			
		<p>1mtr</p>	<p>106 cms</p>	<p>MR (Students less than 45 in each class)</p>
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<p>30 a/c per hour</p> <p>—</p>	<p>—</p> <p>Natural Ventilation</p>	<p>No Basement</p> <p>MR</p>

Sana

P14

		12 a/c per hour		
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	IS No's ABC & CO ₂ ISI marked	Provided do do	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	one 30 m 5 mm	Provided do do	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	— — — — —	— — — — —	— — — — —
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	— — —	— — —	— — —
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	— — —	100mm Provided Provided	— — —
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	— —	— —	— —
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual stopping 	— — — — — — — —	— — — — — — — —	— — — — — — — —

SAN

N/S

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—
		450lpm & 180lpm	Provided	MR
		40 m/hr	— do —	MR
		—	—	—
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	1 Lakh ltr	—
		—	—	—
		—	2 way provided	MR
		—	—	—
		—	40000 ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts:			No lift
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
17.	Standby power supply	—	—	—
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
		—	—	—
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
20.	Special Fire Protection System for Protection of special Risks, if any:	—	—	—

San

N/6

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/09/1869 dated 25.06.2009 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Note:- There are less than 45 students in each class as given in form 'K' (placed on C-6), by the principal of school.

Sandeep
24/01/2014

Signature of Inspecting Officer

Name

Sandeep Duggal

Designation

Asst. Divisional officer

Signature of Inspecting Officer

Name

Designation