

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/School/2014/W2/246 Dated: 18/02/2014

**FIRE SAFETY CERTIFICATE**

Certified that Mansa Vidya Peeth, 68/1 Bhorgarh Narela Delhi-110040 comprised of Ground + Two Upper Floor Only owned / occupied by Mansa Vidya Peeth has already been issued fire safety certificate vide this office letter No F-6/DFS/MS/2011/51 dated 11/01/2011. The premise was re-inspected by the officer concerned and all the fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have there fore deemed complied with the fire prevention and fire safety requirements in accordance with Circular No 262-362 dated 17/01/2005 issued by Director of Education / NBC- Part IV and verified by the officer concerned of Fire Service on 11 / 01 /2014 in the presence of Sh. Rajender Chauhan and that the building / premises is fit for occupancy of Group Class B (Educational) with effect from 18 / 02 /2014 for a period of three years, subject to compliance of the conditions.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 18/02/14 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
cfowz.dlfire@nic.in

**Copy to:**

1. The Principal, Mansa Vidya Peeth, 68/1 Bhorgarh Narela Delhi-110040
2. Director of Education, Old Sectt. Delhi for information

N-9

Gt + Two floors

INSPECTION REPORT

1. Name & address of the building: Mansa Vidya peeth 68/1 Bhargava Narela Delhi-110
2. Type of Occupancy: Educational
3. Type of Case: New Case / Renewal
4. Details of previous NOC: F-6/DAS/MS/2011/51 dt. 11.1.11
5. Fire Safety directives letter No: D/S. of Edu & NBC dt. 17.1.05
6. Date of inspection: 14.1.14
7. Name of the Inspecting Officers: A DO (RW)
8. Name and designation of officers from the building side: Sh. Rajender Chauhan - Manager
9. Year of Construction: 2001 & 2006
10. Applicant's letter No.: Lt. No. - N12 dt. 31.12.13

Plot area: 7042 m<sup>2</sup> Covered area: 702 m<sup>2</sup> No.'s of students: 600 No.'s of classrooms: 16  
5 for other purpose

	Minimum Standards on fire prevention and fire safety U/R 33	Circular Dir. of Edu Requirement/ NBC	Provided at site	Remarks MR/NMR
1	Access to building	<del>17.1.05</del>		
	• Road width	Accessible	Accessible	M/R ✓
	• Gate width	Accessible	Accessible	M/R ✓
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	—	—	—
	• Upper Floors	1	2	M/R ✓
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	old case	old case	old case ✓
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	1 mtr	1 mtr	M/R ✓

3	<b>Compartmentation.</b>				
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>				N/A
4	<b>Smoke Management System.</b>				
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour			N/A
		12 a/c per hour			
5	<b>Fire Extinguishers</b>				
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	8 ABC	7 ABC one CO2	MIR	✓
		ISI marked	—	—	
			yes	MIR	✓
6	<b>First-Aid Hose Reels.</b>				
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	one	P	MIR	✓
		30 m	P	MIR	✓
		5 mm	P	MIR	✓
7	<b>Automatic fire detection and alarming system.</b>				
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>				N/A
8	<b>MOEFA</b>				
9	<b>Public Address System.</b>				
10	<b>Automatic Sprinkler System.</b>				
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>				
11	<b>Internal Hydrants</b>				
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>				N/A

12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—
13	<b>Pumping Arrangements.</b>			
	• Ground Level	—	—	—
	➤ Discharge of main Pump	—	—	—
	➤ Head of Main pump	—	—	—
	➤ Number of main pumps	—	—	—
	➤ Jockey Pump out put	—	—	—
	➤ Jockey pump head	—	—	—
	➤ Standby Pump out put	—	—	—
	➤ Standby Pump Head	—	—	—
	➤ Auto Starting/ Manual stopping	—	—	—
	➤ Pump House Access	—	—	—
	• Terrace level	—	—	—
	➤ Discharge of pump	450 LPM	450 LPM	M/R ✓
	➤ Head of the pump	40 M	40 M	M/R ✓
	➤ Power Supply	—	—	—
	➤ Auto Starting of pum	R	P	M/R ✓
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	—	—	—
	➤ Draw-off connection	—	—	—
	➤ Fire service inlet	—	—	—
	➤ Access to tank	—	—	—
	• Overhead Tank capacity	5000 lts	5000 lts	M/R ✓
15	<b>Exit Signage.</b>	—	—	—
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	<b>Standby power supply</b>	—	—	—

N-12

18	<b>Refuge Area.</b>			
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	<b>Fire Control Room</b>			
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-6/DFSM/MS/2011/51. Dated...11/01/2011. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation


20 (MS)  
Quish  
3/2/14

Signature of the Inspecting Officer

Name

Designation

M. Chandra  
28.1.14  
ADD (BWS)



73/DFSM (W2)  
5/2/14