

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS DELHI FIRE SERVICE NEW DELHI - 110001

Fax:- 011-23412593

E-mail ID:cfohq.dlfire@nic.in

NoF 6 /DFS/MS/GH/2014 / NI9.2 /Q.kiw

Dated S 1 2_ I k

FIRE SAFETY CERTIFICATE

Certified that the Restaurant in the name and style of M/s Town House Cafe located at, N-63, 64 & 64B, 1st floor, Municipal Building, Outer Circle, Connaught Place, New Delhi – 110001 occupied by (A Unit of J.V. Restaurant Pvt. Ltd) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of the fire service on 10/02/2014 in the presence of Mr. Sanjay Pandey and the said building / premises is fit for occupancy Class Group D Assembly Building with effect from 2014 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on S 1 9-1 2 at New Delhi by.

1\6?

(Dr. G. C. isra)
Chief Fire Officer
Delhi fire Service
Ph —011-23414333

Copy to:-

1. M/s Town House Café located at, N-63, 64 & 64B, 1st floor, Municipal Building, Outer Circle, Connaught Place, New Delhi — 110001.
2. Medical officer of Health, Health Department, Palika Kendra, New Delhi — 110001
No. MOH/D/162/CSI(Lic.)SI-I dated 07/01/2014.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

MR

INSPECTION REPORT

1. Name & address of the building : M/s Town House Café at, N-63, 64 & 64B, 1st floor, Municipal Building, Outer Circle, Connaught Place, New Delhi

2. Type of Occupancy : Assembly at F. floor

3. Type of Case : Fresh 00 reM viA, JAA (7, LA tuAik ; ; t\i ZIA, SAK '

4. Details of previous NOC : NA

5. Fire Safety directives Letter No. : NA

6 Date of inspection : 10/02/2014

7 Name of the Inspecting Officer : M. K. Sharma (Assistant Divisional Officer)

8 Name and designation of Officer
from the building side : Mr. Sanjay Pandey

9 Year of construction : Existing Heritage Bldg. (C.C.)

O. Applicant's letter No. : No. MOH/D/162/CSI(Lic)/SI-I dated 07/01/2014

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 Mt	a. 12 Mt	MR
	• Gate width		MA	• kig.
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos.	2 Nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1 Mt & 1.20 Mtr.	1 Mt & 1.20 Mtr.	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
		NA	NA	NA

	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02	02	M*
	e. Width Of Corridor	NA	NA	N*
	f. Door Size	2 Mtr.	2 Mtr.	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	• Total numbers	10 Nos.	12 Nos.	MR
	• Types	ABC, CO2, Wco2	ABC, CO2, Wco2	M*
	• IS marking	Required	Provided	MR
6	First — Aid Hose Reels			
	• Total numbers on each floor	01	01	M*
	• Length of hose reel hose	30 Mt	30 Mt	M*
	• Nozzle diameter	05 MM	05 MM	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	Required	Provided	M*
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	11A	NA	NA
8	MOEFA	Required	Provided	M*
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler			

2/11

		Basements	NA	NA	NA
		Upper Floor	Required	Provided	MR
		Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants				
		• Size of riser/down- comer	100 MM	100 MM	MR
		• Number of hydrants per floor	01	01	MR
		• Hose Box	01	01	MR
12	Yarc. Hydrants				
		• Total number of hydrants	NA	NA	NA
		• Hose Box	NA	NA	NA
13	Pumping Arrangements				
		○ Ground Level			
		• Discharge of main pump	NA	NA	NA
		• Head of main pump	NA	NA	NA
		• Number of main pumps	NA	NA	NA
		• Jockey pump out put	NA	NA	NA
		• Jockey pump head	NA	NA	NA
		• Standby Pump out put	NA	NA	NA
		• Standby Pump Head	NA	NA	NA
		• auto Staring/Manual stopping	NA	NA	NA
		• Pump House Access	NA	NA	NA
		• Terrace level			
		• Discharge of pump	450 LPM	900 LPM	MR
		• Head of the pump	30 Mtr.	30 Mtr.	MR
		• Power supply	Required	Provided	MR
		• Auto starting of pump	NA	NA	NA
14	Ca	ive water Storage for fire fighting	NA	NA	NA
		Under ground tank capacity	NA	NA	NA
		Draw of connection	NA	NA	NA
		Fire service inlet	NA	NA	NA

ment

N/12

	<ul style="list-style-type: none"> Access to tank Overhead Tank capacity 	Required 10,000 Ltr.	Provided 10,000 Ltr.	MR MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts	NA	NA	NA
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of lift lobby Communication in lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area 	NA	NA	NA
	<ul style="list-style-type: none"> Location 	NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> Detector system panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	YES	ABC , Co2	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule it is recommended to grant fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / FSC is recommended please.



4/6

Signature of the Ins=**ffiker**

DO

VI

Name :- M.K. Shar-24
Designation :- A. D.O. (CC)