

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**

**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

Fax: 23412593, E-mail: cfosz.dlfire@nic.in, Tel:- 011-23414250


NO.F6/DFS/MS/EH/2014/ 521/271

Dated: 26/02/2014

**FIRE SAFETY CERTIFICATE**

Certified that M/s **F. Grill & Lounge Restaurant (A unit of Great Moments Hospitality Pvt. Ltd.)** located at **third floor of MGF Metropolitan Mall, Saket, New Delhi-110017** was granted NOC by this department vide letter No. F6/MS/DFS/EH/2010/2926 dated 08.10.2010, the restaurant was re-inspected by the officer concerned of this department on 27-01-2014 in presence of Mr. Chiranjiv Gupta, accountant of the restaurant and found that the said restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class **Assembly (restaurant)** with effect from 26/2/14 for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on 26/2/14 at New Delhi by.

  
(SANTOKH SINGH)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Copy to: -

1. Deputy Health Officer, South Zone, MCD, Health Department, Green Park, New Delhi.
2. The Manager, M/s F. Grill & Lounge Restaurant (A unit of Great Moments Hospitality Pvt. Ltd.), third floor, MGF Metropolitan Mall, Saket, New Delhi-110017.

**Conditions for the validity of fire safety certificate**

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

n/16

**INSPECTION REPORT**

1. Name & address of the building : M/s F. Grill & Lounge Restaurant (A unit of Great Moments Hospitality Pvt. Ltd.), third floor of MGF Metropolitan Mall, Saket, New Delhi-110017
2. Type of Occupancy : Restaurant
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/EH/2010/2926 dated 08-10-2010
5. Fire Safety directives letter No : Delhi Fire Service Act-2007 & Rules 2010.
6. Date of inspection : 27-01-2014
7. Name of the Inspecting Officers : M.K.Chattopadhyay, ADO(M.Rd)
8. Name and designation of officers from the building side : Mr. Chiranjiv Gupta, accountant
9. Year of Construction : 2009
10. Applicant's letter No. : nil dated 05-10-2013.

Restaurant is located at third floor of MGF Metropolitan Mall, Saket, New Delhi-110017

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	09 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	06 mts	Provided	MR
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-	-	-
	• Upper Floors	(18) 02 for rest.	Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-	-	-
	• Upper Floors	1.5 mts each	Provided	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	---	---	---
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	02 (near rest.)	02	MR
	g. Width of Corridor	1.5 mts	Provided	MR
	h. Door Size	1.5 mts	Provided	MR
3	<b>Compartmentation.</b>			

2/7

	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	Required	Provided	MR
		Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour	Provided in Mall	MR
		12 a/c per hour	Provided	MR
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	05	Provided	MR
		ABC, CO <sub>2</sub>	Provided	MR
		ISI marked	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	01	Provided in restaurant	MR
		30 m	Provided	MR
		5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	Required (smoke/heat)	Provided	MR
		Staircase	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided in entire building	MR
8	<b>MOEFA</b>			
		Required	Provided	MR
9	<b>Public Address System.</b>			
		Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	Required in mall basement	Provided	MR
		Required	Provided	MR
		Required in mall basement	Provided	MR
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> </ul>	100 mm	Provided in Restaurant	MR
		01 (for rest.)	Provided	MR

1/11/2019  
 5/10/19

7

2/8

	• Hose Box	01	Provided	MR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	<b>Pumping Arrangements.</b>			
	• Ground Level	-	-	-
	➤ Discharge of main Pump	4500 LPM	Provided in Mall	MR
	➤ Head of Main pump	70 mts	Provided	MR
	➤ Number of main pumps	02	Provided	MR
	➤ Jockey Pump out put	450 LPM	Provided in Mall	MR
	➤ Jockey pump head	70 mts	Provided	MR
	➤ Standby Pump out put	4500 LPM	Provided in Mall	MR
	➤ Standby Pump Head	70 mts	Provided	MR
	➤ Auto Starting/ Manual stopping	Required	provided	MR
	➤ Pump House Access	Required	Provided for entire mall	MR
	• Terrace level	N/A	N/A	N/A
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	5,00,000 liters	Provided in Mall	MR
	➤ Draw-off connection	Required	Provided in Mall	MR
	➤ Fire service inlet	Required	Provided in Mall	MR
	➤ Access to tank	Required	Provided in Mall	MR
	• Overhead Tank capacity	20,000 liters	Provided in Mall	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	Required in Mall	Provided	---
	• Pressurization of Lift lobby	Required in Mall	Provided	---
	• Communication In lift Car	Required in Mall	Provided	---
	• Fireman's Grounding Switch	Required in Mall	Provided	---

N/9

	• Lift Signage	Required in Mall	Provided	---
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	Required	Provided in Mall	MR
	• Flow Switch Panel	Required	Provided in Mall	MR
	• PA System Panel	Required	Provided in Mall	MR
	• Batter backup	Required	Provided in Mall	MR
	• Building Floor Plans	Required	Provided in Mall	MR
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	01 CO <sub>2</sub> type fire extinguishers found provided near elect. panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/EH/2010/2926 dated 08-10-2010, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DFA is put up for approval & signature please.

~~DO (SZ)~~

*[Handwritten signature]*  
10/2/14

*[Handwritten signature]*  
15/2/2014



Signature of the Inspecting Officer  
Name M.K.CHATTOPADHYAY  
Designation: - Asstt. Div. Officer (M.Rd)