

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/School/2014/W2/263

Dated: 24/02/2014

FIRE SAFETY CERTIFICATE

Certified that Goldy Public School, 56-B, Balbir Vihar, Rohini, Extn, Delhi - 110041 comprised of Ground Floor Only owned / occupied by Goldy Public School, has already been issued fire safety certificate vide this office letter No F-6/DFS/MS/2011/980 dated 26/05/2011. The premise was re-inspected by the officer from this department on dated 27/01/2014 in the presence of Sh. B.K Ahuja and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have there fore deemed complied with the requirements of Circular issued by Director of Education letter dated 17/01/2005 and the building/premise is fit for occupancy of Group Class B (Educational) with effect from 24/02/2014 for a period of three years, subject to compliance of the conditions.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 24/02/14 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in



Copy to:

1. The Principal, Goldy Public School, 56-B, Balbir Vihar, Rohini, Extn, Delhi - 110041
2. The Director of Education, old Secretariat, Delhi.

n/6

One Block - G.F. only

INSPECTION REPORT

1. Name & address of the building: GOLDY PUBLIC SCHOOL, 56-B, BALBIR
VIHAR, ROHINI EXTN, DELHI - U.I.
2. Type of Occupancy: ✓
3. Type of Case: New Case / Renewal
4. Details of previous NOC: F-6/DESI/MS/2007/1098 dt 17-9-07
5. Fire Safety directives letter No: Circular of Director of Edn dt 31/17/05
6. Date of inspection: 27-11
7. Name of the Inspecting Officers: M. P. Sharma
8. Name and designation of officers from the building side: Sh. B. K. Ahuja
9. Year of Construction: 2000 ✓
10. Applicant's letter No.: - 11-913

P.A. 650 sqds. CA - 550 sqds. No. S - 209. No. CR - 08

	Minimum Standards on fire prevention and fire safety U/R 33	in NBE of Requirement Dir of Edn	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR ✓
	• Gate width	-	-	-
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	-	-	-
	• Basements	-	-	-
	b. Width of staircases	-	-	-
	• Upper Floors	-	-	-
	• Basements	-	-	-
	c. Protection of exits	-	-	-
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size	1 mt	1.05 mt	MR ✓
3	Compartmentation.	-	-	-
	• Fire check door	-	-	-

r/h

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 			
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	03 ISI marked	05 ABC + CO2 yes	MR ✓ MR ✓ MR ✓
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 m 5 mm		
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 			
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 			
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 			
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 			

13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
15	Exit Signage.	—	—	—
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
17	Standby power supply	—	—	—
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
		—	—	—
19	Fire Control Room			

	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-6/DPS/ms/2007/1098 Dated 17.09.07... Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the ~~Inspecting~~ Officer N.P. Sharma 27-1-14

Name N.P. SHARMA

Designation ADO 'A'

Signature of the Inspecting Officer

Name

Designation



27-1-14