

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. f6/dfs/ms/school/2014/w2/253

Dated: 21 / 02 / 2014

FIRE SAFETY CERTIFICATE

Certified that the M. C. Co-ed School, Sector-18, Rohini, Delhi-110085 comprised of Ground + one upper floor owned/occupied by M C Co-ed School have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 03/02/2014 in the presence of Mrs. Renu Bhatnagar (Principal) and that the building / premises is fit for occupancy of Educational building with effect from 21 / 02 / 2014 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 6 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 21 / 02 / 14 at New Delhi


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, M.C. Co-ed School, Sector-18, Rohini, Delhi-110085
2. The Director of Education, Old Secretariat, Delhi.



one Block - G.F + F.F. + one Hall at G.F.

INSPECTION REPORT

1. Name & address of the building: M.C. Co-ed School, Sector 18, Rohini
 2. Type of Occupancy : Delhi-85 Educational
 3. Type of Case : ✓ New Case / Renewal
 4. Details of previous NOC : —
 5. Fire Safety directives letter No : Circular of the director of Education 01-311
 6. Date of inspection : 03-2-14
 7. Name of the Inspecting Officers : N.P. Sharma
 8. Name and designation of officers
 from the building side : Mrs. Renu Bhatnagar Principal
 9. Year of Construction : 1992 & 2003
 10. Applicant's letter No. : - 23/214

Plot area:- 3920 sqft Covered area:- 1700 sqft No.'s of students:- 1654 No.'s of classrooms:- 38

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu BBL /NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	P	MR
	• Upper Floors	03	03 —	MR
	• Basements	—	—	—
	b. Width of staircases	R	P	MR
	• Upper Floors	1.5 mtr	1.90 mtr each	MR
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	1. mtr	1.20 mtr	MR

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	—	—	—
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	— —	— —
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	one @ 3rd Syde ISI marked	as ABC yes	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	— — —	— — —
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		— — — — —	— — — — —
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 		— — —	— — —
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 		— — —	— — —

Yard Hydrants.			
	• Total number of hydrants	✓	✓
	• Hose Box	✓	✓
13	Pumping Arrangements.		
	• Ground Level	✓	✓
	➤ Discharge of main Pump	✓	✓
	➤ Head of Main pump	✓	✓
	➤ Number of main pumps	✓	✓
	➤ Jockey Pump out put	✓	✓
	➤ Jockey pump head	✓	✓
	➤ Standby Pump out put	✓	✓
	➤ Standby Pump Head	✓	✓
	➤ Auto Starting/ Manual stopping	✓	✓
	➤ Pump House Access	✓	✓
	• Terrace level	✓	✓
	➤ Discharge of pump	✓	✓
	➤ Head of the pump	✓	✓
	➤ Power Supply	✓	✓
	➤ Auto Starting of pum	✓	✓
14	Captive Water Storage for fire fighting.		
	• Underground tank capacity	✓	✓
	➤ Draw-off connection	✓	✓
	➤ Fire service inlet	✓	✓
	➤ Access to tank	✓	✓
	• Overhead Tank capacity	✓	✓
15	Exit Signage.		
16	Provision of Lifts.		
	• Pressurization of Lift Shaft	✓	✓
	• Pressurization of Lift lobby	✓	✓
	• Communication In lift Car	✓	✓
	• Fireman's Grounding Switch	✓	✓
	• Lift Signage	✓	✓
17	Standby power supply		
		✓	✓

m/n

18	Refuge Area.			
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	Fire Control Room			
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

* One Hall at Gf. Having three nos of exits 2-7 mtr each.

The fire protection systems provided in the building were test checked and found functional at the time of inspection, NO Short Comings.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no.Dated.../...../..... Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer 03-214

Name N.P. Sharma

Designation ADD 'R'

Signature of the Inspecting Officer

Name

Designation

