

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:- 011-23412593

Ph: 011 - 23414250


No F6/DFS/MS/school/2014/MOZ/270

Dated: 26/02/14

FIRE SAFETY CERTIFICATE

Certified that the **Navyug Co-Ed Sr. Sec. School & Navyug Pry. School at Tilak Marg, New Delhi** comprises of ground & first floor was granted NOC by this department vide letters No. F6/DFS/MS/2014/103 dated 24-01-2014 & F6/DFS/MS/2008/389 dated 13-02-2008 two separate schools. Now the NDMC have merged the schools on dated 20.04.2011. The premises was re-inspected by the officer concerned of this department on 15-01-2014 in the presence of Sh. Sajjan Sharma Fo NDMC, have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.2011 & DFS order dates 18.04.2012 and that the building is fit for occupancy, class B "Educational Building" with effect from 26/02/14 for a period of **three years**, subject to conditions printed overleaf.

Issued on .... 26/02/14 ..... at New Delhi by.

  
(Santokh Singh)  
Chief Fire Officer,  
Delhi Fire Service.



Copy to:-

1. The Principal  
Navyug Co-Ed Sr. Sec. School  
Tilak Marg, New Delhi
2. Anil Kumar Saha Fire Officer  
New Delhi Municipal Council  
Palika Kendra New Delhi.

-12/4-

## INSPECTION REPORT

1. Name & address of the building: Navyug Co-Ed Sr. Sec. School,  
Tilak Marg, New Delhi. (Navyug Pry.  
School & Navyug Co-Ed Sec. School)  
Amalgamated.
2. Building is comprised of : Ground & First floor
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC: F6/DFS/MS/2008/389 dated 13-2-2008  
& F6/DFS/MS/2008/651 dated 04.03.2008.
6. Fire Safety directive letter No : NA
7. Date of Inspection : 15.01.2014
8. Name of the Inspecting officers : Gurmukh Singh, Div. Officer.
9. Name and designation of Officer:  
from the building side : Sh. Sajjan Sharma Fo NDMC
10. Year of Construction : Old
12. Applicant's letter No : Letter No. -Nil- dated 10.9.2013

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	Existing Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	5Mtr	5 Mtr.	MR (old case) h.
	• Gate width	4.5Mtr	4.5 Mtr	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	4Nos.	4 Nos.	MR
	• Basement	NA	NA	NA
	B. Width of Staircases			
	• Upper Floor	1.5 Mtr.	1.35, 1.2, 1.05 & 1.05 ramp	MR
	• Basement	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA

h



	<ul style="list-style-type: none"> <li>• Pressurization</li> </ul>	NA	NA	NA
	e. No. of continuous staircases to terrace	1 No	2 Nos.	MR
	g. Width of Corridor	1.5 Mtr. or less	2.0 Mtr.	MR
	h. Door Size	1.0Mtr.	1.0 Mtr.	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire rating of shaft door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Water curtain</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Upper floor</li> </ul>	NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	11 Nos.	18Nos.	MR
	<ul style="list-style-type: none"> <li>• types</li> </ul>	ABC & Co2	ABC & Co2	MR
	<ul style="list-style-type: none"> <li>• ISI marking</li> </ul>	Required	Provided	MR
6	First-aid-Hose Reels.			
	<ul style="list-style-type: none"> <li>• Total numbers at each floor</li> </ul>	1 No	3 Nos.	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5 mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location of main panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location of repeater panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Hooter's location</li> </ul>	NA	Provided	NA
8	MOEFA	NA	NA	NA
9	Public address System.	NA	Provided	NA
10	Automatic Sprinkler System.	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• upper floor (1<sup>st</sup> floor)</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• sprinkler above false ceiling</li> </ul>	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>• size of riser/down-comer</li> </ul>	NA	NA	NA

	• Number of hydrants per floor	NA.	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA.	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main Pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby pump out put	NA	NA	NA
	➤ Standby pump Head	NA	NA	NA
	➤ Auto Starting /Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 Mtr.	40 Mtr.	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	2500 Ltr.	2500+3000 Ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication in lift car	NA	NA	NA
	• Firemen's grounding switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.	NA	NA	NA
	• Total area	NA	NA	NA




-N/74-

	• Location	NA	NA	NA
19	Fire Control Room			
	• Detector system panel	NA	NA	NA
	• Flow switch panel	NA	NA	NA
	• PA system panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection systems fire protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the **NOC** issued vide letter no. **F6/DFS/MS/2008/389** dated 13.02.2008 & **F6/DFS/MS/2014/103** dated **24.01.2014** renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

The two schools have been joined fresh NOC is submitted.

  
 Name **Gyanankh Singh**  
 Designation **AO (C)**