

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No: F6/DFS/MS/school/2014/W2/250

Dated: 21/02/14

FIRE SAFETY CERTIFICATE

Certified that the building of **North Delhi Municipal Corporation Primary School**, located at **ED Block, Pitampura, Delhi - 110088** comprised of ground floor only, owned and occupied by North Delhi Municipal Corporation Primary School have complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education/ NBC and verified by the officers concerned of Fire Service on 27-01-2014 in the presence of **Yash Bala (Teacher)** and that the building / premises is fit for the occupancy class "**Educational**" **Group B Sub Division B - 1** with effect from 21/02/14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 21/02/14 at New Delhi.

  
(Santokh Singh)  
Chief Fire Officer,  
Delhi Fire Service.  
Ph: 011 - 23414250

  
21/2

Copy to:-

1. The Principal,  
North Delhi Municipal Corporation Primary School,  
ED Block, Pitampura, Delhi - 110088

Following fire safety directives must be adhered to:-

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The school building presently lying vacant will not be used for any other purpose.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1. Name & address of the building: North Delhi Municipal Corporation Primary School,  
E D Block, Pitampura, Delhi-110088
2. Type of Occupancy : Educational Ground floor only
3. Type of Case : New 11 class rooms
4. Details of previous NOC : Letter No —
5. Fire Safety directives Letter No. : DOE Circular 3298-3398 dated 1-3-11
6. Date of inspection : 27-01-14
7. Name of the Inspecting Officer : Mukesh Verma AD(AM)
8. Name and designation of Officer Yash Bala (Teacher)  
from the building side :
9. Year of Construction : 1986
10. Applicant's letter No. : Nil dated 18-12-13

Total Area = 6400 m<sup>2</sup>, Covered Area = 752 m<sup>2</sup>

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL <del>DOE</del> Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	<u>Accessible</u>	<u>Provided</u>	<u>MR</u>
	• Gate width	<u>Accessible</u>	<u>Provided</u>	<u>MR</u>
	• Width of internal road	<u>NA</u>	<u>NA</u>	<u>NA</u>
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Basements	<u>NA</u>	<u>NA</u>	<u>NA</u>
	b. Width of staircases			
	• Upper floors	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Basements	<u>NA</u>	<u>NA</u>	<u>NA</u>
	c. Protection of exits			
	• Fire check door	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Pressurization	<u>NA</u>	<u>NA</u>	<u>NA</u>
	d. No of continuous staircase to terrace	<u>NA</u>	<u>NA</u>	<u>NA</u>
	e. Width Of Corridor	<u>NA</u>	<u>NA</u>	<u>NA</u>
	f. Door Size	<u>1m</u>	<u>2x110cm</u>	<u>MR</u>

3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>			N/A
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour		
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 a/c per hour		N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	4 ABC ISI marked	Provided Provided Yes	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>			N/A
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>			N/A
8.	MOEFA			N/A
9.	Public Address System			N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>			N/A

11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>• Size of riser/down- comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>		N/A	
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>		N/A	
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Staring/Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>		N/A	
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>• Under ground tank capacity</li> <li>➤ Draw of connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>		N/A	
15	Exit Signage		N/A	
16.	Provision of Lifts			

	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> <li>➤ Pressurization of lift lobby</li> <li>➤ Communication in lift Car</li> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>				
17.	Standby power supply				
18.	Refuge Area				
	<ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>				
19.	Fire control room				
	<ul style="list-style-type: none"> <li>➤ Detector system panel</li> <li>➤ Flow Switch Panel</li> <li>➤ PA System Panel</li> <li>➤ Batter backup</li> <li>➤ Building Floor Plans</li> </ul>				
20.	Special Fire Protection Systems for Protection of special Risks, if any;				

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/~~issue shortcomings as noted at serial numbers~~

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation



CF/195