

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

Fax:- 011-23412593

E-mail ID:cfowz.dlfire@nic.in

No. F6/DFS/MS/2014/MOZ/267 Dated 25/02/14

FIRE SAFETY CERTIFICATE

Certified that the **Palika Kendra Parliament Street at New Delhi** comprises 2Basement + ground +19 upper floors was granted NOC by this department vide letter No. F6/MS/DFS/2009/2506/HR/NOC/41 dated 02-07-2009. The premises was re-inspected by the officer concerned of this department on 05-01-2014 in the presence of Mr. Sajjan Kumar Fire officer & Mr.A.K.Saha CSO and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy Business Class Group d (3) Sub Division with effect from 25/02/ 2014 for period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...25/02/14..... at New Delhi by.


(Santokh Singh)
Chief Fire Officer
Delhi Fire Service
Ph – 011-23414250

Copy to:-

1. Palika Kendra Parliament Street at, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

2/17

INSPECTION REPORT

1. Name & address of the building : Palika Kendra Parliament Street, New Delhi.
2. Building is comprised of : Office Building in NDMC.
3. Type of Occupancy : Business (d) 2B + Gr. + 19 floors
4. Type of Case : Renewal
5. Details of previous NOC : F6/MS/DFS/2009/2506/HR/NOC/41 dated 02/07/09
6. Fire Safety directives Letter No. : 12 Points
7. Date of inspection : 05/01/2014
8. Name of the Inspecting Officer : Sh. Gurmukh Singh (DO/CD) & Sh. M. K. Sharma (ADO/CC)
9. Name and designation of Officer
 from the building side : Mr. Sajjan Kumar Fire officer & Mr. A.K. Saha CSO & Fire officer
10. Year of Construction : 1984
11. Applicant's letter No. : FIRE/1569/D-dated.02/07/13

S No	Minimum standards on fire prevention and fire safety U/R 33	Existing Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 Mtr.	6 Mtr.	MR
	• Gate width	6 Mtr.	6 Mtr.	MR
	• Width of internal road	4.5 & 6 Mtr.	4.5 & 6 Mtr.	MR
2.	Number, width, Type & Arrangements of exits & Ramps			
	a. Number of staircases			
	• Upper floors	2 Nos.	2 Nos.	MR
	• Basements	2 Nos.	2 Nos.	MR
	b. Width of staircases			
	• Upper floors	1 Mtr.	1.40 Mtr.	MR
	• Basements	1 Mtr.	1.40 & 1.20 Mtr.	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR

P
Mans

N/18

	<ul style="list-style-type: none"> • Pressurization 	Required	Provided	MR
	d. No of continuous staircase to terrace	02	01	MR (old)
	e. Width Of Corridor	1.5 Mt.	1.5 Mt.	MR
	f. Door Size	1 Mt.	1 Mt.	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door in Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	Required	Provided	MR
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	Required	Provided	MR
	<ul style="list-style-type: none"> • Water Curtain 	Required	Provided	MR
	<ul style="list-style-type: none"> • Fire Dampers 	Required	Provided	MR
4	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	30 ACPH	Mechanical	MR
	<ul style="list-style-type: none"> • Upper floors 	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	304 Nos.	304 Nos.	MR
	<ul style="list-style-type: none"> • Types 	ABC, CO ₂ , Wco ₂ ,	ABC, CO ₂ , Wco ₂	MR
	<ul style="list-style-type: none"> • IS marking 	Foam	Foam	MR
		Required	Provided	MR
6	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	01	01	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	06 MM	06 MM	MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	Required	Provided	MR
	<ul style="list-style-type: none"> • Location of Main Panel 	At FCR G. floor	At FCR G. floor	MR
	<ul style="list-style-type: none"> • Location of Repeater Panel 	Zone wise	Zone wise	MR
	<ul style="list-style-type: none"> • Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> • Hooters' Location 	Floor wise	Floor wise	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR

N/19

10	Automatic Sprinkler			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants			
	• Size of riser/down- comer	150 MM	150 MM	MR
	• Number of hydrants per floor	1 No	1 No	MR
	• Hose Box	1 No	1 No	MR
12	Yard Hydrants			
	• Total number of hydrants	02	02	MR
	• Hose Box	Required	Provided	MR
13	Pumping Arrangements			
	○ Ground Level			
	• Discharge of main pump	1800 LPM	1800 LPM	MR
	• Head of main pump	100 Mtr.	100 Mtr.	MR
	• Number of main pumps	2	2	MR
	• Jockey pump out put	220 LPM	220 LPM	MR
	• Jockey pump head	100 Mtr.	100 Mtr.	MR
	• Standby Pump out put	1800 LPM	1800 LPM	MR
	• Standby Pump Head	100 Mtr.	100 Mtr.	MR
	• auto Staring/Manual stopping	Required	Provided	MR
	• Pump House Access			
	○ Terrace level	NA	NA	NA
	• Discharge of pump	NA	NA	NA
	• Head of the pump	NA	NA	NA
	• Power supply	NA	NA	NA
	• Auto starting of pump	NA	NA	NA
14	Captive water Storage for fire fighting			
	• Under ground tank capacity	2,00,000 Ltr.	2,00,000 Ltr.	MR
	• Draw of connection	Required	Provided	MR

h.

h

month

N/20

	<ul style="list-style-type: none"> • Fire service inlet 	Required	Provided	MR
	<ul style="list-style-type: none"> • Access to tank 	Required	Provided	MR
	<ul style="list-style-type: none"> • Overhead Tank capacity 	50,000 Ltr.	50,000 Ltr.	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft-7 	Required	Provided	MR
	<ul style="list-style-type: none"> • Pressurization of lift lobby-7 	Required	Provided	MR
	<ul style="list-style-type: none"> • Communication in lift Car 	Required	Provided	MR
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	Required	Provided	MR
	<ul style="list-style-type: none"> • Lift Signage 	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> • Total area 	NA	NA	NA
	<ul style="list-style-type: none"> • Location 	NA	NA	NA
19	Fire control room	At Ground Floor		
	<ul style="list-style-type: none"> • Detector system panel 	Required	Provided	MR
	<ul style="list-style-type: none"> • Flow Switch Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> • PA System Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> • Batter backup 	Required	Provided	MR
	<ul style="list-style-type: none"> • Building Floor Plans 	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Co ₂ flooding system	MR

One staircase is up to terrace and 2nd staircase up to 18th floors.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/MS/DFS/2009/2506/HR/NOC/41 dated 02/07/2009 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

Name :- Sh. Gurmukh Singh
Designation :-DO(CD)

Signature of the Inspecting Officer

Name :- Sh. M. K. Sharma
Designation :- A. D.O. (CC)