

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. f6/dfs/ms/school/2014/w2/257

Dated: 24/02/2014

FIRE SAFETY CERTIFICATE

Certified that Vani Model School, A-5, Rajiv Nagar, Main Road , Begum Pur Delhi-110086 comprised of Ground Floor owned/occupied by Vani Model School, have complied with the fire prevention and fire safety requirements in accordance with the circular No-262-362 dated 17/01/2005 issued by Director of Education and verified by the officer concerned of Fire Service on 31/01/2014 in the presence of Sh. Amit Vashisht and that the building / premises is fit for occupancy of Educational building with effect from 24/02/2014 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 6 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 24/02/14 at New Delhi


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Vani Model School, A-5, Rajiv Nagar, Main Road , Begum Pur Delhi-86
2. The Director of Education, Old Secretariat, Delhi

N/S

INSPECTION REPORT

G.F.

1. Name & address of the building: VANI MODEL SCHOOL A-5, RAJIV NAGAR
MAIN ROAD, BEGUM PUR, DELHI-86
2. Type of Occupancy: Educational
3. Type of Case: New Case / Renewal
4. Details of previous NOC: F-6/D.F.S./ms/09/1861 dt-25-6-2019
5. Fire Safety directives letter No: Circular of the director of Education dt-1-3-11
6. Date of inspection: 31-1-14
7. Name of the Inspecting Officers: N.P. Sharma
8. Name and designation of officers
from the building side: Sh. Armit Vashisht.
9. Year of Construction: 2014
10. Applicant's letter No.: - 26-1213

Plot area:- 1500 Sqds Covered area:- 700 Sqds No.'s of students:- 312 No's of classrooms:- 08

	Minimum Standards on fire prevention and fire safety U/R 33	Circular Dir. of Edu Requirement/ NBC	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p>Accessible</p> <p>-</p> <p>-</p>	<p>Accessible</p> <p>-</p> <p>-</p>	<p>MR ✓</p> <p>-</p> <p>-</p>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	-	-	-
	• Basements	-	-	-
	b. Width of staircases	-	-	-
	• Upper Floors	-	-	-
	• Basements	-	-	-
	c. Protection of exits	-	-	-
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size	01 mtr	01 mtr	MR ✓

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	04 ISI marked	06 ABC yes	MR MR MR ✓
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm		
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 			
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 			

12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	—	—	—
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pum 	—	—	—
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	—	—	—
15	Exit Signage.	—	—	—
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	—	—	—
17	Standby power supply	—	—	—

N/8

18	Refuge Area.			
	➤ Total Area	✓	✓	✓
	➤ Location	✓	✓	✓
19	Fire Control Room			
	• Detector System Panel	✓	✓	✓
	• Flow Switch Panel	✓	✓	✓
	• PA System Panel	✓	✓	✓
	• Batter backup	✓	✓	✓
	• Building Floor Plans	✓	✓	✓
20	Special Fire Protection Systems for Protection of special Risks, if any:	✓	✓	✓

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-6/DFs/ms/09/1861 Dated. 25/...6.../2019. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer [Signature] 31-1-14
 Name N. P. Sharma
 Designation ADD R.

Signature of the Inspecting Officer
 Name
 Designation

