


No. F.6/DFS/MS/EH/2014/SZ/ 281

Dated: 28/02/14

FIRE SAFETY CERTIFICATE

Certified that the M/s Chilis Restaurant at shop no. R-308, Ambience Mall Vasant Kunj, New Delhi running at third floor of the building comprised of two basement, lower ground floor and upper ground floor plus three upper floors was granted NOC by this department vide letter No: F6/DFS/MS/EH/2010/3180 dated 15.11.2010. The premises was re-inspected by the officer concerned of Delhi Fire Service on 14.02..2014 in the presence of Sh. Ajay (Manager) of the restaurant and observed that fire safety norms as required under Rule 33 of Delhi Fire Service Rules, 2010 have deemed complied and that the building / premises is fit for occupancy class-D "Assembly building Restaurant" with effect from 28/02/14 for a period of Three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on 28/02/14 at New Delhi by


(Dr. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The DHO(South Zone), Office of Deputy Health Officer, M.C.D. Health Department South Zone, Green Park, New Delhi,
2. The Manager, M/s Chilis Restaurant at shop no. R-308, 3rd Floor, Ambience Mall Vasant Kunj, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The Basement shall be used strictly as per the provisions of Building Bye Laws.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1	Name & address of the building	M/s Chilis Restaurant at shop no. R-308, 3rd floor, Ambience Mall Vasant Kunj, New Delhi 110070		
2	Type of Occupancy	Assembly Building "D" Restauant		
3	Type of case	Renewal		
4	Details of previous NOC	F6/DFS/MS/EH/2010/3180 dated 15.11.2010		
5	Fire safety directives letter No	Nil		
6	Date of inspection	14.2.2014		
7	Name of the inspecting Officers :	D.O. (South) D.P. Bhardwaj ,		
8	Name and designation of officers from the building side	Sh. Ajay (Manager),		
9	Year of construction			
10	Applicant's letter No.	Nil	24.01.2014	(Resturant running at 3rd floor shop no. R-308)
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	Required	10 Mtr Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	Old Case	2 Nos. Near Restaurant Provided	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	Old Case	1.38-1.5 Mtrs Provided	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrac	Required	Provided by Mall	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	Required	1.17, 1.49 Mtrs Provided	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour	N/A	N/A
		12 a/c per hour	Provided	MR
5	Fire Extinguishers			
	total numbers		6 Nos	MR
	Types		ABC, Water Co2	MR
6	ISI marking	ISI	Yes	MR
	First-Aid Hose Reels.	Provided & Maintain by Mall		
	total numbers on each floor	do	do	do
	Length of Hose reel hose	do	do	do

7	Nozzle Diameter	do	do	
	Automatic fire detection and alarming system:-	Provided & Maintain by Mall		
	Type of detectors	do	do	do
	location of Main Panel	do	do	do
	location of Repeater panel	do	do	do
	Alternate source of power	do	do	do
8	hooter's location	Provided & Maintain by Mall		
9	MOEFA	Provided & Maintain by Mall		
10	Public Address System.	Provided & Maintain by Mall		
	Automatic Sprinkler System.			
	basement	do	do	do
	upper floors	do	do	do
11	sprinkler above false ceiling	do	do	do
	Internal Hydrants	Provided & Maintain by Mall		
	Size of riser/down-corner	do	do	do
	Number of Hydrants per floor	do	do	do
12	hose Box	do	do	do
	Yard Hydrants.	Provided & Maintain by Mall		
	total number of hydrants	do	do	do
13	hose box	do	do	do
	Pumping arrangements	Provided & Maintain by Mall		
	1. Ground level			
	a. Discharge of main Pump	do	do	do
	b. Head of main pump	do	do	do
	c. Number of main pumps	do	do	do
	d. jockey pump out put	do	do	do
	e. jockey pump head	do	do	do
	f. Standby Pump output	do	do	do
	g. Stanby Pump head	do	do	do
	h. Auto Starting/Manual stopping	do	do	do
	pump house access	do	do	do
	2. Terrace level			
	a. Discharge of pump	do	do	do
	b. head of the pump	do	do	do
	c. Power supply	do	do	do
14	d. Auto starting of pump	do	do	do
	Captive water storage for fire fighting	Provided & Maintain by Mall		
	1. Underground tank capacity	do	do	do
	a. Draw-off connection	do	do	do
	b. fire service inlet	do	do	do
	c. Access to tank	do	do	do
15	Over head tank Capacity	do	do	do
16	Exit Signage.	Provided & Maintain by Mall		
	Provision of lifts.			
	a. Pressurization of lift shaft	do	do	do
	b. pressurization of lift lobby	do	do	do
	c. communication in lift car	do	do	do
	d. Fireman's grounding switch	do	do	do
17	e. Lift signage	do	do	do
18	Standby power supply	Provided & Maintain by Mall		
	Refuge Area.	Provided & Maintain by Mall		
	total area	do	do	do

ation	do	do	do
Fire control room	Provided & Maintain by Mall		
a. detector system Panel	do	do	do
b. Flow switch Panel	do	do	do
c. PA system Panel	do	do	do
d. Batter backup	do	do	do
e. Building floor plans	do	do	do

20 **Special Fire Protection systems for protection of special risks, if any: N/A**

The fire protection systems provided in the building were checked and found functional at the time of inspection.
 In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules of NOC issued vide letter no. **F6/DFS/MS/EH/2010/3180 dated 15.11.2010** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.

Signature of the Inspecting Officer
 Name D.P. BHARDWAJ
 Designation:- D.O. (South)

