

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.

E-mail:- [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in)

Fax:- 011-23412593

No.F.6/DFS/MS/School/2014/ 52 / 286

Dated: 28/2/14

**FIRE SAFETY CERTIFICATE**

Certified that the building of **Durga Public School** located at RZ-28 & 31/184, Durga Park, Street No-2, New Delhi-110045 having two blocks namely Block A & Block B. Block A is comprised of basement, ground floor plus one upper floor and Block B is comprised of ground floor plus one upper floor but the school is running at ground floor in each block, having total 08 rooms (Including Class Rooms & Office) owned/occupied by the school management was inspected by the officer concerned of this department on 04.02.2014 in the presence of Sh. Vipin Panwar (Manager) and found that the school management have complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the school building (At ground floor only) is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on..... 28/2/14 .....at New Delhi.

  
(DR. G.C. MISRA)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Ph:- 011-23414333

Copy to:-

1. The Manager,  
Durga Public School, RZ-28 & 31/184,  
Durga Park, Street No-2, New Delhi-110045.
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi - 110054.



Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

(A-Block) R2-28/184 Comprised of Basement, Ground floor and one upper floor and R2-31/184 comprised of ground floor and one upper floor. (B-Block).  
The School is at ground floor in above mentioned premises N/1  
 (New Case)

**INSPECTION REPORT**

1. Name & address of the building: Durga Public School (Regd.) R2-28 & 31/184, Durga Park Ghat, ND-45
2. Type of Occupancy : Educational
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. \_\_\_\_\_ Dated \_\_\_\_\_
5. Fire Safety directives letter No : \_\_\_\_\_
6. Date of inspection : 04/02/2014
7. Name of Inspecting Officer : ADO Sandeep Duggal
8. Name and designation of officers:  
 From the building side : Mr Vipin Panwar (Manager)
9. Year of Construction : R2-28/184 is 1988 and R2-31/184 in 2006.
10. Applicant's letter No. : Nil dated 08/01/2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<p>Accessible</p> <p>—</p> <p>—</p>	<p>5 mtr</p> <p>253 x 93 in R2-28/184 (A)</p> <p>345 x 96 in R2-31/184 (B)</p>	<p>MR</p> <p>—</p> <p>—</p>
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	<p>—</p> <p>—</p>	<p>—</p> <p>—</p>	<p>School at Ground Floor</p> <p>— do —</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	<p>—</p> <p>—</p>	<p>—</p> <p>—</p>	<p>School at Ground Floor</p> <p>— do —</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• pressurization</li> </ul>	<p>—</p> <p>—</p>	<p>—</p> <p>—</p>	<p>—</p> <p>—</p>
	d. No. of continuous staircases to terrace			
		<p>—</p>	<p>01</p>	<p>—</p>
	e. Width of Corridor			
		<p>—</p>	<p>—</p>	<p>—</p>
	f. Door Size	<p>01 mtr</p>	<p>93cms in R2-28/184</p> <p>95cms in R2-31/184</p>	<p>Students less than 45 in each class.</p> <p>MR (Being old Bldg)</p>
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	<p>30 a/c per hour</p> <p>—</p>	<p>—</p> <p>Natural Ventilation</p>	<p>School at Ground Floor</p> <p>MR</p>
	Ground floor	—	Natural Ventilation	MR

N/2

M

		12 a/c per hour		
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	<p>04 NO<sup>s</sup> ABC &amp; CO<sub>2</sub> ISI marked</p>	<p>Provided <del>do</del> <del>do</del></p>	<p>MR MR MR</p>
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	<p>30 m 5 mm</p>		
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>			
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>			
11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>			
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>			
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/Manual stopping</li> </ul>			

SCM

Durga Public School (Regd) R2-28<sup>N/3</sup> & 31/184, Durga Park,  
 Cat no. 2, ND Delhi - 110045

	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>	—	—	—
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	—	—	—
<b>15.</b>	<b>Exit Signage.</b>	—	—	—
<b>16.</b>	<b>Provision of Lifts:</b>			No lift
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	—	—	—
<b>17.</b>	<b>Standby power supply</b>	—	—	—
<b>18.</b>	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	—	—	—
<b>19.</b>	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	—	—	—
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	—	—	—

N/4

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note :- The premises having school are comprised of Block "A" at RZ-28/184 :- Basement, ground floor & first floor and Block "B" at RZ-31/184 :- Ground floor & first floor, but school is running at ground floor as per affidavit submitted by manager of school. The school <sup>sub</sup> and basement has separate entry/exit & number of students are less than 45 in each class mentioned in above mentioned affidavit. The year of construction of Block "A" is 1998 and Block "B" is 2006, which is also mentioned in affidavit placed on e-324. FSC is recommended ~~for~~.

Sandeep  
13/02/2014

Signature of Inspecting Officer

Name Sandeep Duggal

Designation Asst. Divisional officer.

Signature of Inspecting Officer

Name

Designation

