

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

Ph.23414333,Fax:23412593,E-mail:cfohq.dlfire@nic.in

No. F6/DFS/MS/EH/2014/NOZ/277

Dated: 28/02/14

FIRE SAFETY CERTIFICATE

Certified that the Haldiram Restaurant cum Show room at G-42 to 48 at ground floor ,of Cross River Mall, Plot No. 9B & 9C, C.B.D Near Karkardooma, Shahdara, Delhi-32,owned/occupied by M/s Haldiram Ethnic Foods Pvt. Ltd. , was granted NOC vide letter no.F6/DFS/MS/EH/2010/1697 dated 10.06.2010. The restaurant cum show room was inspected by the officer concerned of this department on 08.02.2014 in the presence of Sh.Sunil Banyal (Manager),and found that the restaurant cum show room have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and that the building is fit for occupancy Group D " Restaurant/ Assembly Building " with effect from 28/02/14..... for a period of three years, subject to conditions printed overleaf.

Issued on ... 28/02/14..... at New Delhi by


  
(Dr.G.C.Misra)  
Chief Fire Officer  
Delhi Fire Service

To,

The Deputy Health Officer,  
Shahdara (South) Zone, EDMC,  
Health Department, Shahdara South Zone,  
Karkardooma, Delhi.

Copy to:-

M/s Haldiram Ethnic Foods Pvt. Ltd.  
H-154, Sector-63, Noida, U.P.

  
28/2/14

### CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation,ventilation,structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

1. Name & address of the building : Haldiram Ethnic Foods Pvt. Ltd. (Restaurant cum Show room) at G-42, to 48, Cross River Mall, Plot No. 9B & 9C, Central Business District Near Karkardooma, Shahdara, Delhi-32.
2. Building is comprised of : **Two basement, ground plus three upper floors**
3. Type of Occupancy : Assembly (Restaurant cum Show room)
4. Type of Case : **Renewal**
5. Details of Previous NOC : FS/MS/DFS/EH/2010/1697 Dated 10.06.2010
6. Fire Safety direction letter No : Delhi Fire Service Act, 2007 and Rules 2010.
7. Date of Inspection : 08.02.14
8. Name of the Inspecting Officers: : Suresh singh (ADO)
9. Name of the designation of Officer from the building side : Sh.Sunil Banyal ( Manager)
10. Year of Construction : 2006
11. Applicant's letter No : Dated 16.01.2014

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement/NBC	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	24 m	<b>MR</b>
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	6 m	6 m	<b>MR</b>
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	N.A.	N.A.	N.A.
	Upper Floor	N.A.	N.A.	N.A.
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases	N.A.	N.A.	N.A.
	Upper Floor	N.A.	N.A.	N.A.
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits	N.A.	N.A.	N.A.
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
	g. Width of Corridor	N.A.	N.A.	N.A.
	h. Door Size	2 Mtrs.	<b>2 Mtrs.</b>	<b>MR</b>
	i. no. of doors	2 nos.	<b>3 nos.</b>	<b>MR</b>
3	Compartmentation.			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	Provided in main building	<b>MR</b>
	Upper floor	12 a/c per hour	N.A.	N.A.

5.	Fire Extinguishers			
	Total numbers	05 no.	05 no.	MR
	types	Co2 & ABC	Co2 & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	01 (near the restaurant)	1 no. Provided	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	Not Required	Provided in main building	MR
	Location of main panel	Not Required	Provided in main building	MR
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	Required	Provided	MR
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	Required	Provided	MR
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	basement	N.A.	Provided	MR
	Ground floor	N.A.	Provided	MR
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrant	1 no.	1 no.	MR
	Hose Box	1 no.	1 no.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	Not Required	Provided	MR
	➤ Discharge of main Pump	Not Required	2850 LPM	MR
	➤ Head of Main Pump	Not Required	60 m	MR
	➤ Number of main pumps	Not Required	2 no.	MR
	➤ Jockey pump out put	Not Required	180 LPM	MR
	➤ Jockey pump head	Not Required	60 m	MR
	➤ Standby pump out put	Not Required	2850 LPM	MR
	➤ Standby pump Head	Not Required	60 m	MR
	➤ Auto Starting /Manual stopping	Not Required	Provided	MR
	➤ Pump House Access	Not Required	Provided	MR
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

IRN/12

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	Not Required	2,00,000 liters	MR
	Draw-off connection	N.A.	Provided	MR
	Fire service inlet	N.A.	Provided	MR
	Access to tank	N.A.	Provided	MR
	Overhead Tank capacity	10,000 ltrs.	50,000 liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	Provided for main	building	
18	Refuge Area.	N.A.	N.A.	N.A.
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room	Provided for main building		
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The NOC issued vide letter no. F.6/DFS/MS/EH/2010/1697 dated 10.06.2010 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.



Do (F&amp;S)

*Suresh Singh*  
13-2-14

Signature of the Inspecting Officer  
Name : Suresh Singh  
Designation: ADO (Shah)