

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

Fax : 011-23412593 E-mail : cfohq.dfire@nic.in Ph. 011-23414333.

No.F6/DFS/MS/2014/ 52/308

Dated : 04/03/14

FIRE SAFETY CERTIFICATE

Certified that the **Children's Book Trust** located at **6, Diplomatic Enclave, Chanakyapuri, New Delhi**, comprised of **Basement, Ground + 03 Upper Floor** was granted NOC by this department vide letter No.F6/DFS/MS/2003/1773 dated **08/08/13**. The premises was re-inspected by the officer concerned of this department on **20/02/14** in the presence of **Mr. Hari Kumar** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Business Building Group – E** with effect from 04/03/14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed below.


(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

Copy to:- (1) Miss Yamuna Shankar, G.M. (A&F),
Nehru House, 4, Bahadur Shah Zafar Marg,
New Delhi-110002.

(2) Children's Book Trust, 6,
Diplomatic Enclave, Chanakyapuri, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

2/18

INSPECTION REPORT

1. Name & address of the building:- Children's Book Trust located at 6, Diplomatic Enclave, Chanakyapuri, New Delhi.
2. Type of occupancy:- Business Group-E
3. Type of case:- Renewal.
4. Details of previous NOC:- No.F6/DFS/MS/2003/1773 dated 08/08/13
5. Fire safety directives No.- F6/MS/DFS/BP/99/2899 dated 15/03/99
6. Date of inspection:- 20/02/14.
7. Name of the inspecting officer:- D.O.D.P. Bhardwaj & A.D.O S.S. Kaushik
8. Name & designation of officer-
From the building side:- Mr. Hari Kumar.
9. Year of construction:- 2001
10. Applicant's letter No:- 1300 dated 29/11/13

		Basement, ground+ 3 upper floors		Old case
S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	12mtr.	Provided	M/R
	2) Gate width	5 mtr.	5 mtr.	M/R
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	3 Nos	3Nos	M/R
	2. Basements	3 Nos	3 Nos	M/R
	B. Width of staircase			
	1. Upper floors	1.5 mtr.	1.20 mtr. ,1.40 mtr. & 1.25 mtr.	M/R old case
	2. Basements	1.5 mtr.	1.20 mtr. ,1.40 mtr. & 1.25 mtr.	M/R old case
	C. Protection of exits			
	1. Fire check door	Required	Provided	M/R
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Two	Two	M/R
	E. Width of corridor	1.5Mtrs	1.5 Mtrs	M/R
	F. Door size	1.2 Mtrs	1.2 Mtrs	M/R
3.	Compartmentation			
	1) Fire check door	Required	Provided	M/R
	2) Sealing of electrical shafts	Required	Provided	M/R
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Exhaust fan	M/R
	2) Upper floors	12 a/c per hour	Open	M/R

2/18

A/10-

			corridor	
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	10 Nos.	MR
	2) Types		ABC&Wco2	MR
	3) ISI marking			
6.	First-Aid Hose Reel			
	1) Total number of each floor	Required	1 Nos	M/R
	2) Length of hose reel hose	30 m	Yes	M/R
	3) Nozzle diameter	5 mm	Yes	M/R
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Heat & Smoke	Provided	M/R
	2) Location of main panel	Ground floor	Provided	M/R
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	M/R
	5) Hooter's Location	every floor	Provided	M/R
8.	MOEFA	Required	Provided	M/R
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	M/R
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100mm	100mm	M/R
	2) Number of hydrants per floor	1 Nos	1Nos	M/R
	3) Hose box	1 Nos	1 Nos	M/R
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A

13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2280 LPM	2280 LPM	M/R
	b) Head of main pump	60 Mtrs	60 Mtrs	M/R
	c) Number of main pump	2 Nos	Provided	M/R
	d) Jockey pump out put	180 LPM	Provided	M/R
	e) Jockey pump head	60 Mtrs.	60 Mtrs	M/R
	f) Stand by pump output	2280 LPM	2280 LPM	M/R
	g) Stand by pump head	60 Mtrs	60 Mtrs	M/R
	h) Auto starting/Manual stopping	Yes	Yes	M/R
	2) Terrace level			
	a) Discharge of pump	900 LPM	900 LPM	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	50,000 ltrs.	Provided	M/R
	a) Draw-off connection	Required	Provided	M/R
	b) Fire service inlet	Required	Provided	M/R
	c) Access to tank	Yes	yes	M/R
	d) Over head tank capacity	10,000 Ltrs	Provided	M/R
15.	Exit Signage.	Required	Provided	MR

M. Anand

N/11


16.	Provision of Lifts.			
	a) Pressurization of lift shaft	Required	Provided	M/R
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	M/R
	d) Fireman's switch	Required	Provided	M/R
	e) Lift signage	Required	Provided	M/R
17.	Stand by Power Supply	Required	Provided	M/R
18.	Refuge Area			
	Total area location	NA	NA	NA
19.	Fire Control Room			
	a) Detector system panel	Required	Provided	M/R
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	Required	Provided	M/R
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The shortcomings communicated vide letter dated 23/07/13 found complied.
The fire protection system provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No.F6/DFS/MS/2003/1773 dated 08/08/03 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Accordingly DFA is put up please


Signature of the inspecting officer



Name:- D.P. Bharadwaj

Designation:- Divisional officer

Signature of the inspecting officer



Name :- S.S. Kaushik

Designation :- Assistant Divisional officer