

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

NO. F6/DFS/MS/2014/NDZ/312

Dated: 05/03/14

FIRE SAFETY CERTIFICATE

Certified that Directorate of Agriculture Marketing State Grading Laboratory at premises No.49-Sham Nath Marg, Delhi-06, comprises of ground plus one story (Lab at ground floor only), owned/occupied by Directorate of Agriculture Marketing ,Govt. of NCT of Delhi have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules,2010 and verified by the officers concerned of this department on dated 5.2.2014 in the presence of Sh. Dineshchand Senior Chemist and that the building is fit for occupancy class "Storage of poison" with effect from....for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules,2010.

Issued on...05/03/14...at New Delhi by


(Dr. G. C. Misra)
Chief Fire Officer
T.No.011-23414333

Copy to:-

1. Joint Commissioner of Police (Licensing) in r/o Letter No.412-13/Addl.C.P./Lic.(Poison)/Sul. Dated 3.1.2014.
2. Senior Chemist, Directorate of Agricultural Marketing, Govt. of NCT of Delhi, 49-Sham Nath Marg, Delhi-110054

Conditions for the validity of fire safety certificate are overleaf:-

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

②/N-1
INSPECTION REPORT

1. Name & address of the building : **Poision License No. 3 of 1974 of Directorate of Agricultural Marketing, Govt. of NCT of Delhi, 49-ShahNath Marg, Delhi-110054.**
2. Building is comprised of : **Ground Plus one (Lab on ground floor only)**
3. Type of Occupancy : **Business Building(Lab) / *Storage of poison***
4. Type of Case : **New.**
5. Details of Previous NOC : **NOC was issued for E-197,OIA Phase-3rd (F5/(3A)/DFS/2004/185, Dated 2.8.04. New case for this address.**
6. Fire Safety direction letter No : **Nil.**
7. Date of Inspection : **05.02.14**
8. Name of the Inspecting Officers: : **Vedpal (ADO)**
9. Name and designation of Officer from the building side : **Sh. Dinesh Chand (Senior Chemist)**
10. Year of Construction : **2004**
11. Applicant's letter No : **Latter No. 412-13/Addl.C.P./Lic.(Poison/Sul. dated- 03.01.2014**

| S.No | Minimum Standards on fire prevention and fire safety as per past Practice. | Requirement | Provided at Site | Remarks MR/NMR |
|--------------|----------------------------------------------------------------------------|-----------------|------------------|-------------------|
| 1 | Access to building | | | |
| | Road width | 6 m | 6 m | MR |
| | Gate width | N.A. | N.A. | N.A. |
| | Width of internal road | N.A. | N.A. | N.A. |
| 2 | Number, Width, Type and Arrangement of Exits. | | | |
| | a. Number of Staircases | N.A | N.A | N.A |
| | Upper Floor | N.A | N.A | N.A |
| | Basement | N.A. | N.A. | N.A. |
| | B. Width of Staircases | N.A | N.A | N.A |
| | Upper Floor | N.A | N.A | N.A |
| | Basement | N.A. | N.A. | N.A. |
| | c. Protection of exits | N.A. | N.A. | N.A. |
| | Fire check door | N.A. | N.A. | N.A. |
| | Pressurization | N.A. | N.A. | N.A. |
| | e. No. of continuous staircases to terrace | N.A. | N.A. | N.A. |
| | | 1.5 m | 1.5 m | MR |
| | g. Width of Corridor | 1 m | 1 m | MR |
| h. Door Size | | | | |
| 3 | Compartmentation | | | |
| | Fire check door | N.A. | N.A. | N.A. |
| | Sealing of electrical shafts | N.A. | N.A. | N.A. |
| | Fire rating of shaft door | N.A. | N.A. | N.A. |
| | Water curt Fire Dampers | N.A. | N.A. | N.A. |
| | | N.A. | N.A. | N.A. |
| 4 | Smoke Management System. | | | |
| | Basement | 30a/c per hour | N.A. | N.A. |
| | Upper floor | 12 a/c per hour | N.A. | N.A. |

h

h

| | | | | |
|----|-----------------------------------------------|-----------------------|------------|------|
| 5. | Fire Extinguisher | | | |
| | Total numbers | 02 no. | 04 no. | MR |
| | types | CO ₂ & ABC | ABC Type | MR |
| | IS marking | ISI marked | ISI marked | MR |
| 6 | First-aid-Hose Reels. | | | |
| | Total numbers of each floor | N.A. | N.A. | N.A. |
| | Length of hose reel hose | N.A. | N.A. | N.A. |
| | Nozzle diameter | N.A. | N.A. | N.A. |
| 7 | Automatic fire detection and alarming system. | | | |
| | Type of detectors | N.A. | N.A. | N.A. |
| | Location of main panel | N.A. | N.A. | N.A. |
| | Location of repeater panel | N.A. | N.A. | N.A. |
| | Alternate source of power | N.A. | N.A. | N.A. |
| | Hooters | N.A. | N.A. | N.A. |
| 8 | MOEFA | N.A. | N.A. | N.A. |
| 9 | Public address System. | N.A. | N.A. | N.A. |
| 10 | Automatic Sprinkler System. | | | |
| | Basement | N.A. | N.A. | N.A. |
| | upper floor | N.A. | N.A. | N.A. |
| | sprinkler above false ceiling | N.A. | N.A. | N.A. |
| 11 | Internal Hydrants | | | |
| | size of riser/down-comer | N.A. | N.A. | N.A. |
| | Number of hydrants per floor | N.A. | N.A. | N.A. |
| | Hose Box | N.A. | N.A. | N.A. |
| 12 | Yard Hydrants. | | | |
| | Total number of hydrants | N.A. | N.A. | N.A. |
| | Hose Box | N.A. | N.A. | N.A. |
| 13 | Pumping Arrangements. | | | |
| | ➤ Ground Level | N.A. | N.A. | N.A. |
| | ➤ Discharge of main Pump | N.A. | N.A. | N.A. |
| | ➤ Head of Main Pump | N.A. | N.A. | N.A. |
| | ➤ Number of main pumps | N.A. | N.A. | N.A. |
| | ➤ Jockey pump out put | N.A. | N.A. | N.A. |
| | ➤ Jockey pump head | N.A. | N.A. | N.A. |
| | ➤ Standby pump out put | N.A. | N.A. | N.A. |
| | ➤ Standby pump Head | N.A. | N.A. | N.A. |
| | ➤ Auto Starting /Manual stopping | N.A. | N.A. | N.A. |
| | ➤ Pump House Access | N.A. | N.A. | N.A. |
| | ➤ Terrace Level | N.A. | N.A. | N.A. |
| | ➤ Discharge of pump | N.A. | N.A. | N.A. |
| | ➤ Head of the Pump | N.A. | N.A. | N.A. |
| | ➤ Power supply | N.A. | N.A. | N.A. |
| | ➤ Auto Starting of pump | N.A. | N.A. | N.A. |

N/3

Directorate of Agricultural Marketing, Govt. of NCT of Delhi, 49-Shah Nath Marg, Delhi-54.

| | | | | |
|----|--------------------------------------------------------------------------|------|------|------|
| 14 | Captive Water Storage for Fire Fighting. | | | |
| | Underground tank capacity | N.A. | N.A. | N.A. |
| | Draw-off connection | N.A. | N.A. | N.A. |
| | Fire service inlet | N.A. | N.A. | N.A. |
| | Access to tank | N.A. | N.A. | N.A. |
| | Overhead Tank capacity | N.A. | N.A. | N.A. |
| 15 | Exit Signage. | | | |
| 16 | Provision of Lifts. | | | |
| | Pressurization of Lift Shaft | N.A. | N.A. | N.A. |
| | Pressurization of Lift lobby | N.A. | N.A. | N.A. |
| | Communication in lift car | N.A. | N.A. | N.A. |
| | Firemen's grounding switch | N.A. | N.A. | N.A. |
| | Lift Signage | N.A. | N.A. | N.A. |
| 17 | Standby power supply | | | |
| 18 | Refuge Area. | | | |
| | Total area | N.A. | N.A. | N.A. |
| | Location | N.A. | N.A. | N.A. |
| 19 | Fire Control Room | | | |
| | Detector system panel | N.A. | N.A. | N.A. |
| | Flow switch panel | N.A. | N.A. | N.A. |
| | PA system panel | N.A. | N.A. | N.A. |
| | Batter backup | N.A. | N.A. | N.A. |
| | Building Floor Plans | N.A. | N.A. | N.A. |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | | | |
| | | N.A. | N.A. | N.A. |

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer
 Name Vedpal
 Designation ADO

Vedpal
12/2/14

D.O. (Central)

bsharma
25/2/14

