

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001


No. F6/DFS/MS/FW/2014/NMZ/296

Dated: 09/03/14

FIRE SAFETY CERTIFICATE

Certified that the M/S Dulichand Fireworks Prop. Sh. Kuldeep Srivastava at Shop No. 1097, Bazar Paiwalan, Jama Masjid, Delhi-06, at ground floor only, was granted NOC by this department vide letter No. F.5/(3A)/DFS/2007/154. Dated 30.3.2007. The premises was re-inspected by the officer concerned of this department on 19-2-2014 in the presence of Sh. Kuldeep Srivastava (Owner) and found that the said fireworks shop have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Fireworks Storage with effect from ..04/03/..2014 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued ..04/03/14 at New Delhi by.


(Dr. G.C. Misra)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Tel:- 011-23414333
E-Mail:- cfhq.dlfire@nic.in

Copy to:-

1. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony New Delhi-110049 w.r.t. letter No.7350/Addl. C.P./Lic.(Expl.) dated 11.02.14.
2. M/S Duli Chand Fire works, 1097, Bajar Pai Walan, Jama Masjid, Delhi-06.

Conditions for the validity of fire safety certificate are overleaf:-

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M/S Duli Chand Fire works, 1097, Bajar Pai Walan, Jama Masjid, Delhi-06.
2. Type of Occupancy : Storage Fireworks.
3. Type of Case : Old Case
4. Details of Previous NOC : No.F.5/(3A)/DFS/2007/154. Dated 30.3.2007.
5. Fire Safety direction letter No : NIL.
6. Date of Inspection : 19.02.14
7. Name of the Inspecting Officers: : Vedpal (ADO)
8. Name and designation of Officer from the building side : Mr. Kuldeep Srivastava
9. Year of Construction : 1875
10. Applicant's letter No : No.7350/Addl.CP/Lic(Expl.) dated 11.02.14

S.No	Point of Inspection	Requirement	Provided Site	at	Remarks MR/NMR
1	Type of construction and floor area & floor level				
	a. Minimum floor area	9 m2 (mini)	9.5 m2		MR
	b. Construction	Pucca	Provided		MR
	c. Premises Location	Not under the staircase / Mean of escape	Provided		MR
	d. Business permissible only at ground floor	Required	Provided		MR
	e. Business from pavement of road prohibited	Prohibited	Yes		MR
2	Entrance & Exits to the licensed premises				
	The licensed premises shall have independent entrance and exit.	Required	Provided (Yes)		MR
3	Type and distance of the surrounding risk				
	The premises shall be situated at a distance of 15 m from any such premises used for similar explosives / inflammable or hazardous materials.	Required 15 m	Provided		MR

M/S Duli Chand Fire works,1097, Bajar Pai Walan, Jama Masjid, Delhi- 06

4	Nature of business run in the licensed premises			
	The premises in which fireworks are kept shall be used only for possessing and sale for fireworks and no other purposes.	Required	Provided (Yes)	MR
5	Type of electrical wiring and electrical fittings.			
	a. Preferably concealed or through conduit	Required	Provided	MR
	b. All electrical fitting should be flame / spark proof	Required	Provided with casing & capping	MR
6	Extension of shop for business			
	Prohibited	Prohibited	Yes	MR
7	Approach road			
	The road width on the side of which premises is located should be 12 m.	12 m	12 m	MR
8	Fire protection arrangement.			
	a. Extinguishers (Type & No's.)	2 nos. water type & 1no. of ABC / Co2 Type	Provided	MR
	b. Sand and Water Buckets	2 nos.	Provided	MR
	c. Water Drum (s)	1 no.	Provided	MR
9	Any other point that is contrary to the safety of people.			

The fire protection systems provided in shop were test checked and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter No. F.5/(3A)/DFS/2007/154. Dated 30.3.2007, renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended

Signature
Signature of the Inspecting Officer

Name Vedpal

Designation ADO