

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:- 011-23412593

E-mail ID: [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in)


No F6/DFS/MS/2014/MDZ/311

Dated 05/03/14

FIRE SAFETY CERTIFICATE

Certified that the **Gandhi Memorial Hall** located at, **Pearey Lal Bhawan, 2, Bahadur Shah Zagar Marg, New Delhi** comprises of Ground floor + 03 Auditorium & Hall at ground floor was granted NOC by this department vide letter No.F6/MS/DFS/2011/Auditorium/331 dated 18/02/2011. The premises was re-inspected by the officer concerned of this department on 07-01-2014 in the presence of Mr. Rakesh Bhaskar and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and the building is fit for occupancy class B "Assembly Building" with effect from ~~18/02/2011~~ 05/03/14 for period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... 05/03/14 ..... at New Delhi by.

  
(Dr. G. C. Misra)  
Chief Fire Officer  
Delhi Fire Service  
Ph - 011-23414333

Copy to:-

1. Gandhi Memorial Hall located at, Pearey Lal Bhawan, 2, Bahadur Shah Zagar Marg, New Delhi
2. The Joint. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi - 110049 w.r.t. letter No. 80601-602/Joint. C.P.Lic.(Amst.) dated 29/11/13.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

N/60

**INSPECTION REPORT**

1. Name & address of the building : Gandhi Memorial Hall, Pearey Lal Bhawan Association, 2  
Bhadur Shah Zagar Marg, New Delhi.
2. Type of Occupancy : Assembly (Gr. + 3 & Audi & Hall at Gr. floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/MS/DFS/2011/Auditorium/331 dated 18/02/2011
5. Fire Safety directives Letter No. : F6/DFS/MS/95/313 dated 16/03/95
6. Date of inspection : 07/01/2014
- 7 Name of the Inspecting Officer : Sh. Gurmukh Singh (DO/CD) & Sh. M. K. Sharma (ADO/CC)
- 8 Name and designation of Officer  
from the building side : Mr. Rakesh Bhaskar
- 9 Year of Construction : 1981
10. Applicant's letter No. : No.80601-602/Joint C.P./Lic.(Amst.) dated Delhi the 29/11/13

S No	Minimum standards on fire prevention and fire safety U/R 33	Existing Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 Mtr.	12 Mtr.	MR
	• Gate width	4.5 Mtr.	4.5 Mtr.	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits & Spiral Staircase			
	a. Number of staircases (Each block)	3 Nos.	3 Nos.	MR
	• Upper floors	3 Nos.	3 Nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors (one ramp)	1.6 Mtr.	1.6, 1.5 & .8 Mtr.	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
		NA	NA	NA

h

Mar 14



	<ul style="list-style-type: none"> <li>• Pressurization</li> </ul>	NA	NA	NA
	d. No of continuous staircase to terrace	1 No	1 No	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1 Mt	1 Mt	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	NA	NA	NA
4	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	Required	Exhaust fan	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	20 Nos.	20 Nos.	MR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ABC, CO <sub>2</sub> , Wco <sub>2</sub>	ABC, CO <sub>2</sub> , Wco <sub>2</sub>	MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	Required	Provided	MR
6	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	04	04	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	05 MM	05 MM	MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	At G. floor	At G. floor	MR
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>			
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	NA	NA	NA

N/62

	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required NA	Provided NA	MR NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100 MM 2 No 2 No	100 MM 2 No 2 No	MR MR MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	04 04	04 04	MR MR
13	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>auto Staring/Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	900 LPM 70 Mtr. 1 450 LPM 70 Mtr. NA NA NA NA NA NA NA NA NA NA NA	900 LPM 70 Mtr. 1 450 LPM 70 Mtr. NA NA NA NA NA NA NA NA NA NA NA	MR MR MR MR MR NA NA NA NA NA NA NA NA NA NA NA
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>Under ground tank capacity</li> <li>Draw of connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	50,000, 52,500 Ltr. Required Required Required 6500 Ltr.	50000, 52500 Ltr. Provided Provided Provided 6500 Ltr.	MR MR MR MR MR

h

mesh

N/63

15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of lift lobby	NA	NA	NA
	• Communication in lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire control room			
	• Detector system panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Co2 & DCP	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/MS/DFS/2011/Auditorium/331 dated 19/08/2010 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer



Name :- Sh. Gurmukh Singh  
Designation :-DO(CD)

Signature of the Inspecting Officer



Name :- Sh. M. K. Sharma  
Designation :- A. D.O. (CC)

