

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/School/2014/W2/300

Dated: 04/03/2014

FIRE SAFETY CERTIFICATE

Certified that M. R Public School, Rajiv Nagar Ext., Barwala Road, Begum Pur, Delhi - 110086 comprised of Ground Floor + First Floor owned / occupied by M. R Public School, has already been issued fire safety certificate vide this office letter No F-6/DFS/MS/2009/1809 dated 19/06/2009. The premise was re-inspected by the officer concerned and all the fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have there fore deemed complied with the fire prevention and fire safety requirements in accordance with circular No-262-362 dated 17/01/2005 issued by Director of Education and verified by the officer concerned of Fire Service on 20/ 01/2014 in the presence of Sh. Lokesh Kumar and that the building / premises is fit for occupancy of Group Class B (Educational) with effect from 04/03/2014 for a period of three years, subject to compliance of the conditions.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 04/03/14 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
cfowz.dlfire@nic.in

**Copy to:**

1. The Principal, M. R Public School, Rajiv Nagar Ext., Barwala Road, Begum Pur, Delhi
2. The Director of Education, Old Secretariat, Delhi - 110054.

GF + FF

M13

INSPECTION REPORT

1. Name & address of the building: M.R. Public School, Rajeev Nagar Extn. Barwala Road, Begun pūr, Delhi-88
2. Type of Occupancy: educational
3. Type of Case: New Case / Renewal
4. Details of previous NOC: F.6/OFS/MS/2009/1809/dt 19-6-09
5. Fire Safety directives letter No: Circular of The Director of Edn dt 01-3-11
6. Date of inspection: 20-1-14
7. Name of the Inspecting Officers: M.P. Sharma
8. Name and designation of officers from the building side: sr. Laker
9. Year of Construction: 2005
10. Applicant's letter No.: 30-11-13

Plot area:- 3500 sqd Covered area:- 1500 sqd No.'s of students:- 658 No's of classrooms:- 26

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu BBE/NBC Requirement <i>dt 17-1-05</i>	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	<u>Accessible</u>	<u>Accessible</u>	<u>MR</u>
	• Gate width	<u>-</u>	<u>-</u>	<u>-</u>
	• Width of internal road	<u>-</u>	<u>-</u>	<u>-</u>
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	<u>R</u>	<u>P</u>	<u>MR</u>
	• Upper Floors	<u>02</u>	<u>02</u>	<u>MR</u>
	• Basements	<u>N.A.</u>	<u>N.A.</u>	<u>N.A.</u>
	b. Width of staircases			
	• Upper Floors	<u>1.5 mtr</u>	<u>1-1.80 mtr 2-1.36 mtr</u>	<u>MR</u>
	• Basements	<u>-</u>	<u>-</u>	<u>-</u>
	c. Protection of exits			
	• Fire check door	<u>-</u>	<u>-</u>	<u>-</u>
	• Pressurization	<u>-</u>	<u>-</u>	<u>-</u>
	e. No. of continuous staircases to terrace	<u>-</u>	<u>-</u>	<u>-</u>
	g. Width of Corridor	<u>-</u>	<u>-</u>	<u>-</u>
	h. Door Size	<u>01 mtr</u>	<u>1.5 mtr</u>	<u>MR</u>

n/n

3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	-	-	-
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour	-	-
		12 a/c per hour	-	-
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	04	12	MR ✓
		ISI marked	ABC type	MR ✓
			yes	MR ✓
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	④ R	P	MR ✓
		30 m	P	MR ✓
		5 mm	P	MR ✓
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
8	<b>MOEFA</b>	-	-	-
9	<b>Public Address System.</b>	-	-	-
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	-	-	-
		-	-	-
		-	-	-
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	-	-	-
		-	-	-
		-	-	-

n/s

12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—
13	<b>Pumping Arrangements.</b>			
	• Ground Level	—	—	—
	➤ Discharge of main Pump	—	—	—
	➤ Head of Main pump	—	—	—
	➤ Number of main pumps	—	—	—
	➤ Jockey Pump out put	—	—	—
	➤ Jockey pump head	—	—	—
	➤ Standby Pump out put	—	—	—
	➤ Standby Pump Head	—	—	—
	➤ Auto Starting/ Manual stopping	—	—	—
	➤ Pump House Access	—	—	—
	• Terrace level	—	—	—
	➤ Discharge of pump	—	—	—
	➤ Head of the pump	—	—	—
	➤ Power Supply	—	—	—
	➤ Auto Starting of pum	—	—	—
		R	P (4500 lpm)	MR ✓
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity			
	➤ Draw-off connection			
	➤ Fire service inlet			
	➤ Access to tank			
	• Overhead Tank capacity	2500 ltr	5000 ltr	MR ✓
15	<b>Exit Signage.</b>	—	—	—
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	<b>Standby power supply</b>	—	—	—

M/6

18	<b>Refuge Area.</b>			
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	<b>Fire Control Room</b>			
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. *P-6* P.F.S/m.s./2009/1809...Dated. 19.1.06.09.. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.



Signature of the Inspecting Officer *20-1-14*

Name *M. P. Sharma*

Designation *ADD R1*

Signature of the Inspecting Officer

Name

Designation