

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. FG/DFS/MS/School/2014/W2/297

Dated: 04/03/14

FIRE SAFETY CERTIFICATE

Certified that the **Nagar Nigam Prathmik Vidyalaya** located at **U & V Block, Shalimar Bagh, Delhi-110088** comprised of Ground floor only owned / occupied by North Delhi Municipal Corporation have complied with the fire prevention and fire safety requirements in accordance with Director of Education Circular No. F16/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 and verified by the officer concerned of Fire Service on 29.01.2014 in presence of Smt. Roshni Devi (Principal) and that the building / premises is fit for occupancy class "Educational" class B-1 with effect from 04/03/14 for a period of 3 (three) years subject to conditions printed below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on our website [www.dfs.nic.in](http://www.dfs.nic.in).

Issued on 04/03/14 at New Delhi by.

  
(SANTORHI SINGH)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Phone:-23414250

**Copy to :-**

1. Smt. Roshni Devi (Principal), Nagar Nigam Prathmik Vidyalaya, U & V Block, Shalimar Bagh, Delhi-110088.

## INSPECTION REPORT

1. Name & address of the building: Nagar Nigam Pratikshik Vidyalyaya,  
U&V Block, Shalimar Bagh, Delhi-110088
2. Type of Occupancy : Educational Ground Floor only
3. Type of Case : NEW 1 Block, 9 rooms
4. Details of previous NOC : Letter No —
5. Fire Safety directives Letter No. : DOE number 3298 - 3398 dated 1-3-11
6. Date of inspection : 29-01-14
7. Name of the Inspecting Officer : Mukesh Verma ADOMM
8. Name and designation of Officer  
from the building side : Roshni Devi  
(Principal)
9. Year of Construction : 1986
10. Applicant's letter No. : Nil dated 16-12-13

Total area = 6068.65 m<sup>2</sup>, Covered Area = 487.20 m<sup>2</sup>

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	<u>Accessible</u>	<u>Provided</u>	<u>MR</u>
	• Gate width	<u>Accessible</u>	<u>Provided</u>	<u>MR</u>
	• Width of internal road	<u>NA</u>	<u>NA</u>	<u>NA</u>
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Basements	<u>NA</u>	<u>NA</u>	<u>NA</u>
	b. Width of staircases			
	• Upper floors	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Basements	<u>NA</u>	<u>NA</u>	<u>NA</u>
	c. Protection of exits	<u>NA</u>		
	• Fire check door	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Pressurization	<u>NA</u>	<u>NA</u>	<u>NA</u>
	d. No of continuous staircase to terrace	<u>NA</u>	<u>NA</u>	<u>NA</u>
	e. Width Of Corridor	<u>NA</u>	<u>NA</u>	<u>NA</u>
	f. Door Size	<u>1m</u>	<u>110cms.</u>	<u>MR</u>

3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>		N/A	
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	N/A	
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	2 ABC ISI marked	Provided Provided Yes	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>		N/A	
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detector</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>		N/A	
8.	MOEFA		N/A	
9.	Public Address System		N/A	
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>		N/A	

11.	Internal Hydrants <ul style="list-style-type: none"> <li>• Size of riser/down- comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>		N/A	
12.	Yard Hydrants <ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>		N/A	
13.	Pumping Arrangements <ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Staring/Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>		N/A	
14.	Captive water Storage for fire fighting <ul style="list-style-type: none"> <li>• Under ground tank capacity</li> <li>➤ Draw of connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>		N/A	

15	Exit Signage		N/A	
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft			
	➤ Pressurization of lift lobby			
	➤ Communication in lift Car			
	➤ Fireman's Grounding Switch		N/A	
	➤ Lift Signage			
17.	Standby power supply		N/A	
18.	Refuge Area			
	➤ Total area			
	➤ Location		N/A	
19.	Fire control room			
	➤ Detector system panel			
	➤ Flow Switch Panel			
	➤ PA System Panel			
	➤ Batter backup		N/A	
	➤ Building Floor Plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any;		N/A	


The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

.....

*(Handwritten signature lines)*

Nagar Nigam Prathmik Vidyalaya  
U & V Block, Salma Bazar.



Signature of the Inspecting Officer

Name *Mukesh Verma*

Designation *ADO (MN)*

Signature of the Inspecting Officer

Name

Designation