

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No.F.6/DFS/MS/School/2014/ 82/305

Dated: 04/03/14

FIRE SAFETY CERTIFICATE

Certified that the building of **Nav Shiksha Deep Public School** located at 66-67, Sangam Vihar, Phase-I, Kakrola Road, Najafgarh, New Delhi-110043 is comprised of ground floor plus one upper floor but the school is running at ground floor only, having total 07 rooms (Including Class Rooms, Office & Store etc.) owned/occupied by the Mahrishi Parshu Ram Educational & Social Welfare Society (Regd.) was inspected by the officer concerned of this department on 17.02.2014 in the presence of Sh. R.K. Shonak (Manager) and found that the Mahrishi Parshu Ram Educational & Social Welfare Society (Regd.) have complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on.....04/03/14.....at New Delhi.


(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Manager,
Nav Shiksha Deep Public School,
66-67, Sangam Vihar, Phase-I,
Kakrola Road, Najafgarh, New Delhi-110043
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi – 110054.

HK


Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

Building is comprised of ground floor plus one upper floor
 School at ground floor
 (New Case)

INSPECTION REPORT

1. Name & address of the building: Nav Shiksha Deep Public School, 66-67, Sangam Vihar, Phase-I, Kakrola Road, Naya Gash, ND-43.
2. Type of Occupancy: _____
3. Type of Case: New Case/Renewal
4. Details of Previous NOC: Letter No. _____ Dated _____
5. Fire Safety directives letter No: _____
6. Date of inspection: 17.02.2014
7. Name of Inspecting Officer: ADO Sandeep Duggal
8. Name and designation of officers
From the building side: Mr R.K. Shenak (Manager)
9. Year of Construction: 2004
10. Applicant's letter No.: NS DPS / 13-14/2 dt 24/12/2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<u>Accessible</u>	<u>5 mtrs 240 cms</u>	<u>MR</u>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	<u>—</u>	<u>—</u>	<u>Ground floor school</u>
	• Basements	<u>—</u>	<u>—</u>	<u>No Basement</u>
	b. Width of staircases			
	• Upper Floor	<u>—</u>	<u>—</u>	<u>Ground floor School</u>
	• Basements	<u>—</u>	<u>—</u>	<u>No Basement</u>
	c. Protection of exits			
	• Fire check door	<u>—</u>	<u>—</u>	<u>—</u>
	• pressurization	<u>—</u>	<u>—</u>	<u>—</u>
	d. No. of continuous staircases to terrace	<u>—</u>	<u>—</u>	<u>—</u>
	e. Width of Corridor	<u>—</u>	<u>—</u>	<u>—</u>
	f. Door Size	<u>1 mtr</u>	<u>2 mtr (one)</u>	<u>Students enter through breach door MR</u>
3.	Compartmentation			
	• Fire check door	<u>—</u>	<u>—</u>	<u>—</u>
	• Sealing of electrical shafts	<u>—</u>	<u>—</u>	<u>—</u>
	• Fire Rating of shaft door	<u>—</u>	<u>—</u>	<u>—</u>
	• Water Curtain	<u>—</u>	<u>—</u>	<u>—</u>
	• Fire Dampers	<u>—</u>	<u>—</u>	<u>—</u>
4.	Smoke Management System			
	• Basements	<u>30 a/c per hour</u>	<u>—</u>	<u>No Basement</u>
	• Upper floors	<u>—</u>	<u>—</u>	<u>—</u>
	<u>Ground floor</u>	<u>—</u>	<u>Natural Ventilation</u>	<u>MR</u>

N/2

		12 a/c per hour		
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	02 No's ABC & CO2 ISI marked	02 No's Provided	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 m 5 mm		
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 			
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 			
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 			
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 			
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual stopping 			

San

Nav. Shiksha Deep Public School, 66-67, Sangam Vihar, Phase-I,
 N/3 Kakola Road, Najafgarh, ND-43.

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	—	—
15.	Exit Signage.	—	—	—
16.	Provision of Lifts:			No left.
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	—
17.	Standby power supply	—	—	—
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	—
20.	Special Fire Protection System for Protection of special Risks, if any:	—	—	—

N/4.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note :- The School building is comprised of ground floor plus one upper floor. There is single door having width 100cms in each class room. School manager has given undertaking that there are less than 45 students in each class, it is also mentioned in the separate undertaking that school is running at ground floor only placed at C-22 & C-23 respectively. FSC is recommended please

Sandeep
18/2/14

Signature of Inspecting Officer

Name

Sandeep Duggal.

Designation

Asstt. Divisional officer.

Signature of Inspecting Officer

Name

Designation

