

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/2014/CNG/ w2 / 339

Dated: 10/03/2014


**FIRE SAFETY CERTIFICATE**

Certified that the **CNG Dispensing Station** located at **Lok Nayak Puram, Site No.-2, Bakarwala, New Delhi-41**, comprised of Single story Building owned / occupied by **Indraprastha Gas Limited** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 & verified by the officer concerned of Fire Service on 13/02/2014 in the presence of Mr. Aman Vij, Dy. Manager (Project) and that the premises fit for occupancy class **Hazardous (Group J)** with effect from 10/3/2014 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules,2010 subject to conditions printed below.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**Issued on** 10/3/14 **at New Delhi by.**

  
(SANTOKH SINGH)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Phone:-23414250

E-mail: cfowz.dlfire@nic.in

Copy to :-

1. Chief General Manager (Project), Indraprastha Gas Limited, IGL Bhawan, Plot No.4, Community Centre, R.K. Puram, Sec.-9, New Delhi.
2. The Chief Architect, Deptt. of Architecture & Environs, NDMC, Palika Kendra, New Delhi.

# INSPECTION REPORT

(Plot Area=1080m<sup>2</sup>)

1. Name & address of the building: CNG Dispensing Station, Site No.-2, Lok Nayak Puram, Bakarwala, New Delhi-41.
2. Type of Occupancy : Hazardous
3. Type of Case : New
4. Details of previous NOC : Letter No Nil
5. Fire Safety directives Letter No. : F.6/DFS/MS/CNG/2013/2596 dated 27.11.2013
6. Date of inspection : 13.02.2014
7. Name of the Inspecting Officer : A.K. Jaiswal
8. Name and designation of Officer  
from the building side : Mr. Aman Vij (Dy. Manager).
9. Year of Construction :
10. Applicant's letter No. : IGL/CNG/Proj/Bakkar2/170114 dated 17.01.2014

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/NBC (Part-IV) Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr.	30 mtr.	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.00 mtr.	1.00 mtr.	MR

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	• Total numbers	4 trolley 75 K.G. each, 10 K.G. ABC-10 & Co <sub>2</sub> -3	4 trolley 75 K.G. each, 10 K.G. ABC-15 & Co <sub>2</sub> -4	MR
	• Types	ABC,Co <sub>2</sub> &Trolley	ABC,Co <sub>2</sub> & Trolley	MR
	• IS marking	ISI marked	Yes	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	30 mtr.	NA	NA
	• Nozzle diameter	5 mm	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detector	Flame	Provided in compressor packages Area	MR
	• Location of Main Panel	G.F.	G.F.	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power supply	Required	Provided	MR
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA

11.	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level / Over Head			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA

15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	<b>Special Fire Protection Systems for Protection of special Risks, if any:</b> Fire Buckets filled with sand, No smoking boards were found displayed in Hindi & English. No loose electric wiring were seen in premises & Co <sub>2</sub> flooding system found provided.			MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on Fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/

Accordingly DFA is put up please

*Ak Jaiswal*  
13/02/2014  
Signature of the Inspecting Officer

Name : Ashok Kumar Jaiswal

Designation : A.D.O. (Jwala Puri)

*CFO/30*  
*25/7*  
*10/2*  
Signature of the Inspecting Officer

Name

Designation

