

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub – rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/2014/W2/341

Dated: 11/03/14

FIRE SAFETY CERTIFICATE

Certified that the **Aggarwal Millenium Tower** located at **Plot no. E – 1, 2, 3, Netaji Subhash Pace, Pitampura, Delhi – 110034** comprised of 2 Blocks (LG+G+10 Upper Floors & LG+G+5 Upper Floors) was issued FSC vide Letter No. F6/DFS/MS/2003/2315 dated 29-09-2003. The premises was re-inspected by the officer concerned of this department on 03-03-2014 in the presence of Mr. Sunil Jain (Vice President) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Mercantile & Business Building" Group F & Group E with effect from 11/03/14 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on11/03/14..... at New Delhi by.


(Santokh Singh)
Chief Fire Officer,
Delhi Fire Service
Ph – 011-23414250

Copy to:-

1. Sh. Sunil Jain (Vice President),
Plot No. E – 1, 2, 3,
Netaji Subhash Place, Pitampura, Delhi – 110034.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner / occupier shall submit a declaration every year in the Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Aggarwal Millenium Tower, E – 1, 2, 3, Netaji Subhash Place, Pitam Pura, Delhi – 110034.
2. Type of Occupancy : Mercantile + Business (Mixed), 2 Blocks (LG+G+10 Upper Floor & LG+G+5 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/2003/2315 dated 29-09-2003
5. Fire Safety directives Letter No. : Letter No. F6/DFS/MS/BP/2000/1177 dated 06-07-2000
6. Date of inspection : 03-03-2014
7. Name of the Inspecting Officer : DO (West) & ADO (MN)
8. Name and designation of Officer
from the building side : Sh. Sunil Jain (Vice President)
9. Year of Construction : 2003
10. Applicant's letter No. : BPL/DIR/AMT/DFS/2K13/654 dated 18-02-2014

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	60 m	Provided	MR
	• Gate width	6 m	Provided	MR
	• Width of internal road	6 m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Old Case	Old Case	MR
	• Basements	Old Case	Old Case	MR
	b. Width of staircases			
	• Upper floors	Old Case	Old Case	MR
	• Basements	Old Case	Old Case	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Not Required	NR	NR
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	Old Case	Old Case	MR
	f. Door Size	Old Case	Old Case	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR

4.	<ul style="list-style-type: none"> • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required	Provided	MR
		Not Required	NR	NR
		Not Required	NR	NR
5.	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	NR	NR
		12 a/c per hour	Provided	MR
6.	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	48 nos.	Provided	MR
		CO2 & WCO2	Provided	MR
		ISI marked	Provided	MR
7.	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	1	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
8.	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	Smoke & Heat	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
9.	MOEFA	Required	Provided	MR
10.	Public Address System	Required	Provided	MR
11.	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 	Not Required	NR	NR
		Required	Provided	MR
		Required	Provided	MR
12.	<ul style="list-style-type: none"> • Size of riser/down- comer • Number of hydrants per floor • Hose Box 	150 mm	Provided	MR
		1	Provided	MR
		Required	Provided	MR
13.	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump 	2850 lpm	Provided	MR
		75 m	Provided	MR
		2	Provided	MR
		220 lpm	Provided	MR
		75 m	Provided	MR
		2850 lpm	Provided	MR
		75 m	Provided	MR
		Required	Provided & Functional	MR
Required	Provided	MR		
	Not Required	NR	NR	

	➤ Head of the pump	Not Required	NR	NR
	➤ Power supply	Not Required	NR	NR
	➤ Auto starting of pump	Not Required	NR	NR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	2,00,000 litres	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	30,000 litres	Provided	MR
15.	Exit Signage	Required	More Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Not Required	NR	NR
	➤ Pressurization of lift lobby	Not Required	NR	NR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	Old Case	Old Case	MR
	➤ Location	5 th , 7 th & 9 th Floor	Provided	MR
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any:	NR	NR	NR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2003/2315 dated 09-09-2003 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Mukesh Verma

Name

Designation

ADO (MN)

Designation