FORM 'H'

FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[Refer sub - rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

No: FG/DFJ/ms/ Ful 2017/ w2/329

Dated:

10/3/14

FIRE SAFETY CERTIFICATE

Issued on 1913/19 at New Delhi.

(Santokh singh) Chief Fire Officer, Delhi Fire Service. Ph: - 011- 23414250

Following fire safety directives must be adhered to:

1. All the means of escape/entry/exit shall be kept free from any obstruction.

2. All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.

3. All the staff members must know the correct method operation of fire fighting system.

4. Any lapse rendering fire fighting system/ equipment non functional shall be risk and responsibility of the management.

5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.

6. The NOC is for fireworks only.

Copy to:

1. The Addl. Commissioner of Police (Lic.).

1st Floor, P.S. Defence Colony, New Delhi.

(Ref. No. (PFW/02)/2014/4901-04/Jt.CP/Lic.(Expl.), dated 30-01-2014

 M/s Om Sai Traders Prop. Sh. Jitesh Gupta. R/o 4777. 2nd Floor, Gali Mitra Wali. Roshnara Road, Delhi – 110007.

INSPECTION PERFORMA (PART – B) (TO BE FILLED IN TRIPLICATE BY THE INSPECTING OFFICER

DATE		IN THE EIGHTE BY THE INSPECTING	
S.NO.	POINT OF INSPECTION	NORM AS PER GUIDELINES/ VR COMMITTEE REPORT	
1.	Type of construction and floor area and floor level	Minimum floor area 9 m ² Pucca construction Premises not under staircase/means of exit	INSPECTING OFFICER Provided Provided Provided
		4. Business permissible only at ground floor5. Business from pavement of road prohibited	
2.	Entrance & exit to the licensed premises	The licensed premises shall have independent entrance and exit	Provided
3.	Type and distance of surrounding risk	The premises shall be situated at a distance of 15m from any such premises used for similar exclusive/inflammable or hazardous materials	Provided
4.	Nature of business run in the licensed premises	The premises in which fire works are kept shall be used only for possession and sale of fire works and no other purpose	No other business allowed
5.	Type of Electrical wiring and electrical fittings	 Preferably concealed or through conduit The electrical fittings should be flame/ spark proof 	Provided Provided
6.	Extension of shop for business	prohibited spank proof	Prohibited
7.	Approach road	The road width on the sides of which premises is located should be 12m	Provided
8.	Fire Protection arrangements 1. Extinguishers (type & no.) 2. Sand/ Water buckets 3. Water Drum	 All the extinguishers shall have ISI mark No. of fire extinguishers & type shall be in accordance with the risk & area of the premises Minimum 2 buckets each of sand & water shall be provided 	Provided 4 nos. (2 ABC 5kg, 2 CO2 4.5 Kg) Provided
	Any other point that is contrary to the safety of people	provided	Fireworks allowed only at Ground Floor, No other trade is allowed.

GRANT OF NOC FOR SALE/ STORAGE OF FIRE WORKS

(In areas other than walled city and congested areas)
INSPECTION REPORT (PART – A)

(To be filled by the Inspecting Officer)

1. Name and Address of

the licensee:

M/s Om Sai Traders Proprietor Sh. Jitesh Gupta

2. Address of the licensed

premises:

Shop No. 3, HU Block, DDA Market, Pitampura, Delhi

3. License No. and

validity period:

New

4. Authority by which

license was issued

last:

New

5. Name and Designation

of the Inspecting

Officer:

Sunil Chawdhary DO (West), Mukesh Verma ADO (MN)

6. Date and time

of inspection:

19-02-2014 at 1430 Hours

7. Period for which license

is to be renewed and

the authorized quantity:

1500 kg (300 kg fireworks + 1200 kg Chinese/ Sparkles)

8. Recommendations of

the inspecting officer

for issue/ rejection of

NOC with reasons:

Recommended

(Signature of Inspecting Officer)

Remarks of DO