

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001  
Fax: 23412593, E-mail: [cfohq.dfire@nic.in](mailto:cfohq.dfire@nic.in), Tel:- 011-23414333

No.F6/ DFS/ MS/ 2014/ 347

Dated: 12/3/14

FIRE SAFETY CERTIFICATE

Certified that, **Jagan Nath Gupta Memorial Educational Society**, located at MOR Pocket-105 Kalkaji, New Delhi-110019 comprised of Basement, Ground + 04 Upper Floors was granted FSC by this department vide letter No.F6/DFS/MS/2010/3035 dated 27/10/2010. The premises was re-inspected by the officer concerned of this department on 29/02/14 in the presence of Mr. Amit Kamra, Administrative Officer and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Educational** with effect from 12/3/14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued on 12/3/14 at New Delhi by.

  
(Dr. G.C. Misra)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

o/c  
  
11/3/2014  
ADD (BUP)

Copy to: -

Dr. Amit Gupta  
Jagan Nath Gupta Memorial Educational Society  
MOR Pocket-105 Kalkaji, New Delhi-110019

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building :Jagan Nath Gupta Memorial Educational Society,  
MOR Pocket-105,Kalkaji, New Delhi-110019
2. Type of Occupancy : Educational (School)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2010/3035 Dated-27/10/2010
5. Fire Safety directives letter No : No.F6/DFS/MS/BP/2008/2612 Dated: 16/09/2008
6. Date of inspection : 29/02/2014
7. Name of the Inspecting Officers : ADO D.B. Mukherjee
8. Name and designation of officers from the building side : Mr. Amit Kamra (Adminstrative Officer)
9. Year of Construction :2000 & 2011
10. Applicant's letter No. : Nil dated: 17/10/2013,

(Building is comprised of Basement, Ground + Four upper Floors)

**Old case**

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	9 m	Provided	MR
	• Gate width	5 m	Provided 02 Nos 4.87& 4.37 mtrs	MR
	• Width of internal road	6 m	Provided	MR
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	Upper Floors	02	02 Nos	MR
	Basements	02	03 Nos	MR
	b. Width of staircases			
	Upper Floors	1.50 m	1.56 mtr, 1.12 mtr	MR(Old case)
	Basement	02	1 mtr, 1.56 mtr & 0.79 mtr	MR(Old case)
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	N/A	N/A	N/A



3	<b>Compartmentation.</b>			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	N/A	N/A
5	<b>Fire Extinguishers</b>			
	• Total numbers	Required	25nos	MR
	• Types	ABC,CO <sub>2</sub>	Provided	MR
	• IS marking	Required	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Required	Ground Floor	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	DG Set	MR
	• Hooters' Location	N/A	N/A	N/A
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System</b>			
	• Basement	Required	Provided	MR
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	Size of riser/down-comer	01	Provided	MR
	Number of hydrants per floor	01	Provided	MR
	Hose Box	01	Provided	MR

12	<b>Yard Hydrants.</b>			
	Total number of hydrants	Required	Provided	MR
	Hose Box	Required	Provided	MR
13	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>			
	Discharge of main Pump	N/A	N/A	N/A
	Head of Main pump	N/A	N/A	N/A
	Number of main pumps	N/A	N/A	N/A
	Jockey Pump out put	N/A	N/A	N/A
	Jockey pump head	N/A	N/A	N/A
	Standby Pump out put	N/A	N/A	N/A
	Standby Pump Head	N/A	N/A	N/A
	Auto Starting/ Manual stopping	N/A	N/A	N/A
	Pump House Access	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>			
	Discharge of pump	900 LPM	Provided 2 Nos. 450 & 900 LPM	MR
	Head of the pump	Required	Provided	MR
	Power Supply	Required	Provided	MR
	Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	25,000Ltr	30,000Ltr	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pressurization of Lift lobby</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Communication In lift Car</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Fireman's Grounding Switch</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Lift Signage</li> </ul>	Required	Provided	MR
17	<b>Standby power supply</b>	Required	D G Set- 82.5 KV	MR

*Handwritten signature*



18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Provided CO <sub>2</sub> extinguishers near electric main panels	MR

The fire protection system provided in the building were checked and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter no F6/DFS/MS/2010/3035 Dated-27/10/2010 renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended. Accordingly DFA is put up for approval pl.


Signature of the Inspecting Officer



Name (D.B.Mukherjee)

Designation :- Assistant Divisional Office

DO (South)



21/3/14