

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.

F6/DFS/MS/2014/W2/333

Dated: 10/03/2014

FIRE SAFETY CERTIFICATE

Certified that the Building at Plot No. J-33, Udyog Nagar, Rohtak Road, New Delhi-110041, comprised of **Ground Floor + First Floor + Second Floor only** owned / occupied by **Sh. Shakti Katyal**, has already been issued Fire Safety Certificate vide letter No. **F5/(J)/DFS/2002/627 dated 31/10/2002**. The premises / Building was re-inspected by the officer concerned of Fire Service on **10.02.2014** in the presence of **Sh. Rakesh (Supervisor)** and found that building / premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class **Industrial** with effect from 10/03/2014 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
- ✕ 5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 10/3/14 **at New Delhi by.**


(SANTORH SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Phone:-23414250
E-mail: cfowz.dlfire@nic.in

Copy to :-

1. Sh. Shakti Katyal, J-33, Udyog Nagar, Rohtak Road, New Delhi-110041 .

N/2

INSPECTION REPORT

Ground Floor + 1st Floor + 2nd Floor

1. Name & address of the building: **J-33, Udyog Nagar,**
Rohtak Road, New Delhi-110041.
2. Type of Occupancy : **Industrial**
3. Type of Case : **Renewal**
4. Details of previous NOC : Letter No **F5/(J)/DFS/2002/627 dated 31/10/2002**
5. Fire Safety directives Letter No. : ----
6. Date of inspection : **10.02.2014**
7. Name of the Inspecting Officer : **A.K. Jaiswal**
8. Name and designation of Officer
from the building side : **Sh. Rakesh (Supervisor)**
9. Year of Construction : **2002**
10. Applicant's letter No. : **Nil**

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/ Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 Mtr.	Provided	MR
	• Gate width	4.5 Mtr.	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	Old Case	Old Case	Old Case
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	One	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Old Case	Old Case	Old Case

3.	Compartmentation			
	• Fire check door	NR	NR	NR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4.	Smoke managements System			
	• Basements	30 a/c per hour	NR	NR
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	10	12	MR
	• Types	ABC/Co2/W Co2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	One	Provided	MR
	• Length of hose reel hose	Not Mentioned in previous NOC	30mtr	MR
	• Nozzle diameter	Not Mentioned in previous NOC	5mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	NR	NR	NR
	• Location of Main Panel	NR	NR	NR
	• Location of Repeater Panel	NR	NR	NR
	• Alternate source of power	NR	NR	NR
	• Hooters' Location	NR	NR	NR
8.	MOEFA	NR	NR	NR
9.	Public Address System	NR	NR	NR
10.	Automatic Sprinkler System			
	• Basements	NR	NR	NR
	• Upper Floor	NR	NR	NR
	• Sprinkler above false ceiling	NR	NR	NR

11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down- comer 	Not Mentioned in previous NOC	150mm	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	NR	NP	NR
	<ul style="list-style-type: none"> • Hose Box 	NR	NP	NR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NR	NR	NR
	<ul style="list-style-type: none"> • Hose Box 	NR	NR	NR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level / Over Head 			
	<ul style="list-style-type: none"> • Discharge of main pump 	NR	NR	NR
	➤ Head of main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Staring/Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	<ul style="list-style-type: none"> • Terrace level 			
	➤ Discharge of pump	Not Mentioned in previous NOC	450 LPM	MR
	➤ Head of the pump	Not Mentioned in previous NOC	40MH	MR
	➤ Power supply	Not Mentioned in previous NOC	Provided	MR
	➤ Auto starting of pump	Not Mentioned in previous NOC	Provided	MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity 	25,000 Lts.	Provided	MR
	➤ Draw of connection	NR	NR	NR
	➤ Fire service inlet	NR	NR	NR
	➤ Access to tank	NR	NR	NR
	<ul style="list-style-type: none"> • Overhead Tank capacity 	5,000 Ltr.	Provided	MR

Handwritten notes and signatures at the bottom of the page.

N/5

15	Exit Signage	Not Mentioned in previous NOC	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Not Mention in Recommendation	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Batter backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any:	NR	NR	NR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F5/(J)/DFS/2002/627 dated 31/10/2002 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Ak Jaiswal
10/02/2014

Signature of the Inspecting Officer

Name : Ashok Kumar Jaiswal

Designation : A.D.O. (Jwala Puri)

Signature of the Inspecting Officer

Name

Designation



CFD/312
25/2/14
10/3/14

D.O. (Jw) 17/2
A.C.F.O.

Heentat
24/2

10/02/2014