

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[Refer sub – rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/EH/2014/WZ/342

Dated: 11/03/14

FIRE SAFETY CERTIFICATE

Certified that the **Mughal Grantha (A unit of Metro Grill Restarant)** located at **Unit No. 116 – 117, First Floor, NDM – II, Plot no. D – 1, 2, 3, Netaji Subhash Pace, Pitampura, Delhi – 110034** was issued FSC vide Letter No. F6/DFS/MS/EH/2009/2586 dated 20-08-2009. **Eleven Course (A Unit of Eleven Course Hospitality Pvt. Ltd.)** is running in same premises. The NDM – II, Netaji Subhash Place has already issued FSC vide Letter No. F6/DFS/MS/2014/WZ/290 dated 03-03-2014. The premises was re-inspected by the officer concerned of this department on 19-02-2014 in the presence of Mr. Tarun Sharma (Engineer) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class “Assembly” Group D with effect from 11/03/14 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 11/03/14 at New Delhi by.


(Santokh Singh)
Chief Fire Officer,
Delhi Fire Service
Ph – 011-23414250

Copy to:-

1. Dy. Health Officer (Civil Lines Zone),
Public Health Department (NDMC),
16, Rajpur Road, Delhi – 110054.
2. Sh. Sandeep Jain (Director),
Eleven Course Hopitality Pvt. Ltd.,
Unit No. 116 – 117, First Floor, NDM – II,
D – 1, 2, 3, Netaji Subhash Place, Pitampura, Delhi – 110034.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner / occupier shall submit a declaration every year in the Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

Restaurant in the name of Mughal Grantha was operating from same premises and issued FSC vide letter dated 20-08-2009.

INSPECTION REPORT

1. Name & address of the building: Eleven Course, Unit No. 116 – 117, First Floor, NDM – II, Plot no. D – 1, 2, 3, Netaji Subhash Place, Pitampura, Delhi – 110034.
2. Type of Occupancy : Assembly
3. Type of Case : Renewal (Situating in Building already issued NOC vide Letter No. F6/DFS/MS/2014/WZ/290 dated 03-03-2014)
4. Details of previous NOC : FSC issued earlier in the name of Mughal Grantha vide letter no. F6/DFS/MS/2009/2586 dated 20-08-2009
5. Fire Safety directives Letter No. : FSC Issued to the building
6. Date of inspection : 19-02-2014
7. Name of the Inspecting Officer : DCFO (WZ), DO (W), ADO (MN)
8. Name and designation of Officer
from the building side : Sh. Tarun Sharma
9. Year of Construction : 2010
10. Applicant's letter No. : DHO/CLZ/2014/1672 dated 09-01-2014

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	Old Case	Old Case	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Old Case	Old Case	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA

N14

	<ul style="list-style-type: none"> Water Curtain Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour	NA	NA
		12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	02 nos. each type DCP, CO2 & WCO2 ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	1 30 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke Required NA Required Required	Provided Provided at GF NA Provided Provided	MR MR NA MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Not Required Required Required	NR Provided Provided	NR MR MR
11.	Internal Hydrants: common with the mall			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	150 mm 1 Required	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements: Common with the mall			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level 			
		NA	2850 lpm	MR
		NA	110 m	MR
		NA	Provided	MR
		NA	180 lpm	MR
		NA	110 m	MR
		NA	2850 lpm	MR
		NA	110 m	MR
		NA	Provided	MR
		NA	Provided	MR

M/S

	➤ Discharge of pump	900 lpm	The Main pump is provided in place of terrace pump	MR
	➤ Head of the pump	40 m	-	MR
	➤ Power supply	Required	-	MR
	➤ Auto starting of pump	Required	-	MR
14.	Captive water Storage for fire fighting: Common with the mall			
	• Under ground tank capacity	NA	2,00,000 litres	MR
	➤ Draw off connection	NA	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	Provided	MR
	• Overhead Tank capacity	10,000 litres	20,000 Litres Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued in the name of Mughal Grantha (Now Eleven Course) vide letter no. F6/DFS/MS/2009/2586 dated 20-08-2008 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name *Mukesh Verma*

Name

Designation *ADO (MN)*

Designation

12/10/2021