

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/2014/ 335

Dated: 10/3/14

FIRE SAFETY CERTIFICATE

Certified that the **Divine Happy Sr. Sec. School** at **A- 2 / B Block, Paschim Vihar, New Delhi-110063** comprised of **Basement + Ground + one upper floor** only owned / occupied by **Divine Happy Sr. Sec. School** has already been issued NOC / FSC by this department vide letter **No. F.6/DFS/MS/2008/30 dated 07.01.2008**. The premises was re-inspected by the officer concerned of this department on **10.02.2014** in the presence of **Sh. Ankit Solanki (Manager)** and observed that Fire prevention and fire safety arrangements provided in the premises, found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by **Director of Education, GNCT of Delhi vide letter No. 262-362 dated 17.01.2005** and that the building / premises is fit for occupancy class **Educational** (Group B) with effect from ...10/3/14.....for a period of 3 (three) years subject to conditions printed below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 10/3/14 **at New Delhi by.**


(SANTOKH SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Phone:-23414250
E-mail: cfowz.dlfire@nic.in

Copy to :-

1. Sh. Ankit Solanki (Manager), Divine Happy Sr. Sec. School, A- 2 / B Block, Paschim Vihar, New Delhi-110063.
2. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi-110054.

INSPECTION REPORT

Basement + G + 1
 Plot Area = 1 Acre (4800Yard²)
 Covered Area = 1/2 Acre (2400 Yard²)

1. Name & address of the building: **Divine Happy Sr. Sec. School,**
A-2 / B Block, Paschim Vihar, New Delhi-110063.
2. Type of Occupancy : **Educational**
3. Type of Case : **Renewal**
4. Details of previous NOC : Letter No **F6/DFS/MS/2008/30 dated 07.01.2008**
5. Fire Safety directives Letter No. : **DOE Circular Dated 17.01.2005**
6. Date of inspection : **10.02.2014**
7. Name of the Inspecting Officer : **A.K. Jaiswal**
8. Name and designation of Officer
 from the building side : **Sh. Ankit Solanki (Manager)**
9. Year of Construction : **2007**
10. Applicant's letter No. : **DHS/1853/2013-2014 dated 24.01.2014**

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Circular 17.1.2005 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	2	3	MR
	b. Width of staircases			
	• Upper floors	1.50 Mtr.	1.52 Mtr.	MR
	• Basements	1.50 Mtr.	1.54Mtr.1.54Mtr. 2.00 Mtr.	MR
	c. Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	1.50 Mtr.	1.50 Mtr.	MR
	f. Door Size	1.00 Mtr.	1.00 Mtr.	MR

3.	Compartmentation			
	• Fire check door	NR	NR	NR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4.	Smoke managements System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	10	14	MR
	• Types	ABC/CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	One at each floor	One at each floor	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	5 mm.	5 mm.	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	NR	NR	NR
	• Location of Main Panel	NR	NR	NR
	• Location of Repeater Panel	NR	NR	NR
	• Alternate source of power	NR	NR	NR
	• Hooters' Location	NR	NR	NR
8.	MOEFA	NR	NR	NR
9.	Public Address System	NR	NR	NR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor / GF	NR	NR	NR
	• Sprinkler above false ceiling	NR	NR	NR

11.	Internal Hydrants			
	• Size of riser/down- comer	100 mm.	100 mm.	MR
	• Number of hydrants per floor	One	One	MR
	• Hose Box	One	One	MR
12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13.	Pumping Arrangements			
	• Ground Level / Over Head			
	• Discharge of main pump	NR	NR	NR
	➤ Head of main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Staring/Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	450 Lit/Min.	450 Lit/Min. 180 Lit/Min.	MR
	➤ Head of the pump	40 Meter Head	40 Meter Head each	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NR	NR	NR
	➤ Draw of connection	NR	NR	NR
	➤ Fire service inlet	NR	Provided	NR
	➤ Access to tank	NR	NR	NR
	• Overhead Tank capacity	5,000 Ltr.	10,000 Ltr.	MR

15.	Exit Signage	NR	NP	NR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	NR	NR	NR
18.	Refuge Area			
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NR	NR	NR
	➤ Flow Switch Panel	NR	NR	NR
	➤ PA System Panel	NR	NR	NR
	➤ Battery backup	NR	NR	NR
	➤ Building Floor Plans	NR	NR	NR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. **F6/DFS/MS/2008/30 dated 07.01.2008** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Cond. on N/9

N/9

Divine Happy Sr. Sec. School,
A-2 / B Block, Paschim Vihar, New Delhi-110063.

Ak Jaiswal
10/02/2014

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name : Ashok Kumar Jaiswal

Name

Designation : A.D.O. (Jwala Puri)

Designation