

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/ms/school/2014/WZ/352

Dated: 13/03/14


FIRE SAFETY CERTIFICATE

Certified that the **M.C. Primary Pratibha Vidyalaya (Co-Ed.)** at **Jwala Heri, Paschim Vihar Delhi-110063** comprised of **two blocks, Ground floor and Ground + One upper floor** only owned / occupied by **M.C.D** have complied with the fire prevention and fire safety requirements in accordance with Director of Education **Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011** and verified by the officer concerned of Fire Service on **22.02.2014** in presence of **Smt. Asha (Principal)** and that the building / premises is fit for occupancy class **Educational (Group-B)** with effect from **...13./03./14....** for a period of 3 (three) years subject to conditions printed below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 13/03/14 **at New Delhi by.**


(SANTOKH SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Phone:-23414250

o/c ASJ

Copy to :-

1. Smt. Asha (Principal), M.C. Primary Pratibha Vidyalaya (Co-Ed.), Jwala Heri, Paschim Vihar Delhi-110063.
2. Commissioner, NDMC, Civic Center, J.L.Nehru Marg, New Delhi-110002.

N/1

IInd Block Ist Block
(G+1) & G Block

INSPECTION REPORT

1. Name & address of the building: MC Primary Pratibha Vidyalaya
(Co-ed.), Jwalaheri, Delhi-63
2. Type of Occupancy : Educational
3. Type of Case : New Plot Area 224 m²
Total Covered Area 3x128 m²
= 384 m²
4. Details of previous NOC : Letter No Nil
5. Fire Safety directives Letter No. : DOE circular dated 1/3/2011
6. Date of inspection : 22/2/14
7. Name of the Inspecting Officer : A.K. Jaiswal
8. Name and designation of Officer
from the building side : Asha (Principal)
9. Year of Construction : -----
10. Applicant's letter No. : Nil Dated 27/1/2014

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/DOE cir. Requirements 1/3/11	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 Mtr	1.25 X 2	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	1	P	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.00 Mtr	P	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			NR
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	Natural ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	4	4	MR
	<ul style="list-style-type: none"> • Types 	ABC/CO ₂ ISI marked	Provided	MR
	<ul style="list-style-type: none"> • IS marking 		Provided	
6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 			NR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detector • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			NR
8.	MOEFA			
9.	Public Address System			NR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 			NR

11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down- comer • Number of hydrants per floor • Hose Box 	NR		
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NR		
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NR		
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NR		

M.C. Primary Patishah Vidyalaya (Co-ed)
 Jawahar, Delhi - 110063

N/A

15	Exit Signage		NR	
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft			
	➤ Pressurization of lift lobby			
	➤ Communication in lift Car			
	➤ Fireman's Grounding Switch			
	➤ Lift Signage			
17.	Standby power supply		NR	
18.	Refuge Area			
	➤ Total area			
	➤ Location		NR	
19.	Fire control room			
	➤ Detector system panel			
	➤ Flow Switch Panel			
	➤ PA System Panel			
	➤ Batter backup			
	➤ Building Floor Plans		NR	
20.	Special Fire Protection Systems for Protection of special Risks, if any;		NA	

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. _____ dated _____ renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

- Note : ① All class Rooms are having ^{double} doors in each rooms.
- ② School is comprised of 2 Blocks G Floor H(G+1) Floor
old Block New Block
- ③ New (G+1) Block is having ② stairs of 1.25 Mtr. width each.

N/5
M C Primary Pratibha Vidyalaya
(Co-ed.), Jwala Heri, Delhi-63

Ak Jaiswal
22/2/14

Signature of the Inspecting Officer

Name

A. K. Jaiswal

Designation

ADO/(JWP)

Signature of the Inspecting Officer

Name

Designation