

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/2014/School/WZ/ 368

Dated: 14 / 3 / 2014

FIRE SAFETY CERTIFICATE

Certified that the Ch Khushi Ram Model School, , Main Mubarak Pur Road, D-55/1, Inder Enclave, Phase II, Agar Nagar Mod, Delhi 110086 running at Ground & first floor of a premise comprised of Ground + 2 upper floor owned/occupied by Ch Khushi Ram Model School have complied with the fire prevention and fire safety requirements in accordance with the Circular No 262-362 dated 17/01/2005 issued by Director of Education and verified by the officer concerned of Fire Service on 29/01/2014 in the presence of Sh. Virender Singh (Manager) and that the building / premises is fit for occupancy of Educational building with effect from 14 / 3 / 2014 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 The second floor shall not be used for school purposes.
- 6 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 14/3/14 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Ch Khushi Ram Model School, Main Mubarak Pur Road, D-55/1, Inder Enclave, Phase II, Agar Nagar Mod, Delhi 110086
2. The Director of Education, Old Secretariat, Delhi



N/12

One Block - GF+FF+2nd Floor (2nd Floor not in use)

INSPECTION REPORT

1. Name & address of the building: Ch. Khushiram Model School Main Mubarak
2. Type of Occupancy: pun Road, D-55/1, Jinder Sndhwa II, Pagan Nagar Mod Delhi 86
3. Type of Case: New Case / Renewal Educational
4. Details of previous NOC: —
5. Fire Safety directives letter No: Circular of the director of Edn dt 01-3-11
6. Date of inspection: 29-1-14
7. Name of the Inspecting Officers: N. P. Sharma
8. Name and designation of officers
from the building side: Sh. Viender Singh (Manager)
9. Year of Construction: 2000
10. Applicant's letter No.: CKMS/Jan 2014 dt-10-1-2014

PA - 500 Sqm. C.A. 250 Sqm. Nols-250, No. R. 12

	Minimum Standards on fire prevention and fire safety U/R 33	Cir NBC of Requirement the director	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases	R	P	MR
	• Upper Floors	01	02	MR
	• Basements	—	—	—
b.	Width of staircases			
	• Upper Floors	1.5 mtr	s/c-1 - 1 mtr s/c-2 - 1 mtr	MR
	• Basements	—	—	—
c.	Protection of exits			
	• Fire check door	—	—	—
	• Pressurization	—	—	—
e.	No. of continuous staircases to terrace	—	—	—
g.	Width of Corridor			
h.	Door Size	01 mtr	01 mtr	MR

N/13

3	Compartmentation.			
	• Fire check door			
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke Management System.			
	• Basements	30 a/c per hour		
	• Upper floors	12 a/c per hour		
5	Fire Extinguishers			
	• Total numbers	03	ou	MR ✓
	• Types	ISI marked	ABC	MR ✓
	• IS marking		yes	MR ✓
6	First-Aid Hose Reels.			
	• Total numbers on each floor			
	• Length of hose reel hose	30 m		
	• Nozzle diameter	5 mm		
7	Automatic fire detection and alarming system.			
	• Type of detectors			
	• Location of Main Panel			
	• Location of Repeater Panel			
	• Alternate source of power			
	• Hooters' Location			
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	• Basement			
	• Upper floor			
	• Sprinkler above false ceiling			


11	Internal Hydrants	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	✓	✓	✓
12	Yard Hydrants.	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	✓	✓	✓
13	Pumping Arrangements.	<ul style="list-style-type: none"> • Ground level <ul style="list-style-type: none"> ➢ Discharge of main Pump ➢ Head of Main pump ➢ Number of main pumps ➢ Jetty Pump out put ➢ Jetty pump head ➢ Standby Pump out put ➢ Standby Pump Head ➢ Auto Starting/ Manual starting ➢ House Access • Terminal level <ul style="list-style-type: none"> ➢ Discharge of pump ➢ Head of the pump ➢ Water Supply ➢ Auto Starting of pum 	✓	✓	✓
14	Captive Water storage for fire fighting.	<ul style="list-style-type: none"> • Under ground tank capacity ➢ Draw off connection ➢ Fire hose inlet ➢ Access to tank •• Overhead tank capacity 	✓	✓	✓
15	Exit Signage		✓	✓	✓

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	Standby power supply	—	—	—
18	Refuge Area.			
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	Fire Control Room			
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

* An Affidavit and Photos indicate That 2nd Floor is not in use of School.


The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....


Signature of the Inspecting Officer

Name N. P. Sharma

Designation ADO R.





Signature of the Inspecting Officer

Name

Designation