

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. FG/DFS/MS/school/2014/w2/371

Dated: 14 / 3 / 2014

**FIRE SAFETY CERTIFICATE**

Certified that Chankya Modern School, Gali No- 16, T. Point Near Gurudwara, Kaushik Enclave, Burari, Delhi-110084 comprised of Ground + 2 Upper Floors (School Running at Ground Floor Only) owned/occupied by Chankya Modern School, have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 28/01/2014 in the presence of Sh. Sawdesh (Principal) and that the building / premises is fit for occupancy of Educational building with effect from 14 / 3 / 2014 for a period of three years, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 6 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 14/3/14 at New Delhi

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Chankya Modern School, Gali No- 16, T. Point near Gurudwara, Kaushik Enclave, Burari, Delhi-110084
2. The Director of Education, Old Secretariat, Delhi

INSPECTION REPORT

Gr floor & Gr+two inter connected

1. Name & address of the building: Chankya Modern School, Gali No-16 Kaushtik
2. Type of Occupancy: Educational
3. Type of Case: New Case / Renewal
4. Details of previous NOC: Nil
5. Fire Safety directives letter No: Dir. of Edu. dt. 1.3.14
6. Date of inspection: 28.1.14
7. Name of the Inspecting Officers: ADD (B.W)
8. Name and designation of officers from the building side: Sh. Sandesh - Principal
9. Year of Construction: 2007
10. Applicant's letter No: Lt. No. 4/C.M.S./24 dt. 15.1.14

Plot area: 390m<sup>2</sup> Covered area: 290m<sup>2</sup> No.'s of students: 120 No's of classrooms: 7

	Minimum Standards on fire prevention and fire safety U/R 33	Circular Dir. of Edu Requirement <u>NBC</u>	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<u>Accessible</u>	<u>Accessible</u>	<u>MR</u>
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	<u>FSC for Gr. floor only.</u>	<u>Upper floors</u>	
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	<u>used for residential purpose</u>	<u>At risk it furnished by owner.</u>	
	b. Width of staircases	<u>NR</u>	<u>1.35 m<sup>2</sup></u>	
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	<u>—</u>	<u>—</u>	<u>—</u>
	c. Protection of exits	<u>—</u>	<u>—</u>	<u>—</u>
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	<u>—</u>	<u>—</u>	<u>—</u>
	e. No. of continuous staircases to terrace	<u>—</u>	<u>—</u>	<u>—</u>
	g. Width of Corridor	<u>—</u>	<u>—</u>	<u>—</u>
	h. Door Size	<u>1 m<sup>2</sup></u>	<u>1 m<sup>2</sup></u>	<u>MR</u>
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> </ul>			



4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	30 a/c per hour		N/A
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	12 a/c per hour		
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	3 ABC	3	MR
	<ul style="list-style-type: none"> <li>Types</li> </ul>	ISI marked	ABC	MR
	<ul style="list-style-type: none"> <li>IS marking</li> </ul>		yes	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>			N/A
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m		
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm		
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>			N/A
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>			
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>			
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>			
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>			
8	<b>MOEFA</b>			
9	<b>Public Address System.</b>			
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>			N/A
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>			
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>			
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>			N/A
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>			
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>			
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>			N/A
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>			
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>			N/A
	<ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Head of Main pump</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Jockey Pump out put</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>			

