

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F.6/DFS/MS/2014 / *school/w 2/370*

Dated: *14/3* /2014

**FIRE SAFETY CERTIFICATE**

Certified that the M C Primary Co-ed School, Mukherjee Park, Civil Line Zone, Delhi-110009 comprised of Ground floor only owned/occupied by M C Primary Co-ed School has already been issued fire safety certificate vide letter no. F-6/DFS/MS/2009/1405 dated 19/05/2009. The premises was re-inspected by the officer from this department on dated 28/02/2014 in the presence of Sh. Pardeep Kumar Sharma and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have there fore deemed complied with the requirements of circular issued by Director of Education letter dated 17/01/2005 and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 14/3/2014 for a period of three years, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 14/3/14 at New Delhi by

*Singh*  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
cfowz.dlfire@nic.in

**Copy to:**

1. The Principal, M C Primary Co-ed School, Mukherjee Park, Civil Line Zone, Delhi-110009
2. The Director of Education, Old Secretariat, Delhi

N/3

Two Blocks - Both G.F.

**INSPECTION REPORT**

1. Name & address of the building: M.C. Primary Co-ed School, Mukherjee Park, (Civil line Area) Delhi-9 Educational
2. Type of Occupancy: Educational
3. Type of Case: New Case / Renewal
4. Details of previous NOC: F-6/DFS/MS/2009/1405 dt 19-5-09
5. Fire Safety directives letter No: Circular of the director of Edn.
6. Date of inspection: 28-2-14
7. Name of the Inspecting Officers: N. P. Sharma
8. Name and designation of officers from the building side: St. Pradeep K. Sharma
9. Year of Construction: 1976
10. Applicant's letter No.: - 101218

Plot area:- 9090m<sup>2</sup> Covered area:- 850 m<sup>2</sup> No.'s of students:- 210 No's of classrooms:- 06

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu BBE/NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	<u>Accessible</u>	<u>Accessible</u>	<u>MR</u> ✓
	• Gate width	<u>-</u>	<u>-</u>	<u>-</u>
	• Width of internal road	<u>-</u>	<u>-</u>	<u>-</u>
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	<u>-</u>	<u>-</u>	<u>-</u>
	• Upper Floors	<u>-</u>	<u>-</u>	<u>-</u>
	• Basements	<u>-</u>	<u>-</u>	<u>-</u>
	b. Width of staircases	<u>-</u>	<u>-</u>	<u>-</u>
	• Upper Floors	<u>-</u>	<u>-</u>	<u>-</u>
	• Basements	<u>-</u>	<u>-</u>	<u>-</u>
	c. Protection of exits	<u>-</u>	<u>-</u>	<u>-</u>
	• Fire check door	<u>-</u>	<u>-</u>	<u>-</u>
	• Pressurization	<u>-</u>	<u>-</u>	<u>-</u>
	e. No. of continuous staircases to terrace	<u>-</u>	<u>-</u>	<u>-</u>
	g. Width of Corridor	<u>-</u>	<u>-</u>	<u>-</u>
	h. Door Size <u>Two doors in each class room - Provided.</u>	<u>1mtr</u>	<u>1.10mtr</u>	<u>MR</u> ✓

N/A

3	<b>Compartmentation.</b>	N/A		
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4	<b>Smoke Management System.</b>	N/A		
	• Basements	30 a/c per hour	—	—
	• Upper floors	12 a/c per hour	—	—
5	<b>Fire Extinguishers</b>			
	• Total numbers	02	02	MR ✓
	• Types	ISI marked	ABC	MR ✓
	• IS marking		yes	MR ✓
6	<b>First-Aid Hose Reels.</b>	N/A		
	• Total numbers on each floor		—	—
	• Length of hose reel hose	30 m	—	—
	• Nozzle diameter	5 mm	—	—
7	<b>Automatic fire detection and alarming system.</b>	N/A		
	• Type of detectors	—	—	—
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Hooters' Location	—	—	—
8	<b>MOEFA</b>	—	—	—
9	<b>Public Address System.</b>	—	—	—
10	<b>Automatic Sprinkler System.</b>	N/A		
	• Basement	—	—	—
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11	<b>Internal Hydrants</b>	N/A		
	• Size of riser/down-comer	—	—	—
	• Number of hydrants per floor	—	—	—
	• Hose Box	—	—	—

N/5

12	<b>Yard Hydrants.</b>	NIA		
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	-	-	-
13	<b>Pumping Arrangements.</b>	NIA		
	<ul style="list-style-type: none"> <li>Ground Level               <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>Terrace level               <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pum</li> </ul> </li> </ul>	-	-	-
14	<b>Captive Water Storage for fire fighting.</b>	NIA		
	<ul style="list-style-type: none"> <li>Underground tank capacity               <ul style="list-style-type: none"> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	-	-	-
15	<b>Exit Signage.</b>	-	-	-
16	<b>Provision of Lifts.</b>	NIA		
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	-	-	-
17	<b>Standby power supply</b>	-	-	-

n/6

18	<b>Refuge Area.</b>	NIA		
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	<b>Fire Control Room</b>	NIA		
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

✓ In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F-6** **10FFS/ms/2009/1405** Dated **19/05/09** Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer *N.P. Sharma* 28-2-14

Name **N.P. Sharma**

Designation **ADD R,**

~~DD NW~~  
*Sharma*  
4/3/14

Signature of the Inspecting Officer

Name

Designation

