

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. FG/DFS/MS/School/2014/W2/367

Dated: 14/3/2014

FIRE SAFETY CERTIFICATE

Certified that Himalaya International School, F-Block, Sect.-9, Rohini, New Delhi-110085 comprised of Basement + Ground + One upper floor owned/occupied by Himalaya International School, has already been issued fire safety certificate vide letter no. F-6/DFS/MS/2008 /2774 dated 01/10/2008. The premises was re-inspected by the officer from this department on dated 07/12/2013 in the presence of Sh. Hariom Bhardwaj and observed that the school now complies of basement + Ground + two upper floors. The premises have deemed complied with the requirements of Circular No-262-362 dated 17/01/2005 & Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education / and verified by the officer concerned of Fire Service and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 14/3/2014 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 14/3/14 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Himalaya International School, F-Block, Sect.-9, Rohini, New Delhi-85
2. The Director of Education, Old Secretariat, Delhi

N/18

Basement + GF + FF + 2nd F

INSPECTION REPORT

1. Name & address of the building: Himalaya International School, F-Block, Sector 9
 2. Type of Occupancy : Rohini, Delhi-85- school
 3. Type of Case : New Case / Renewal
 4. Details of previous NOC : F-6/DPS/MS/2008/2774 dt 01-10-08
 5. Fire Safety directives letter No : circular of the director of Edn dt 17-1-05
 6. Date of inspection : 15-02-14
 7. Name of the Inspecting Officers : N. I. Sharma
 8. Name and designation of officers
 from the building side : St. H.O. Bhardwaj
 9. Year of Construction : 2007
 10. Applicant's letter No. : - 24-9-13

Plot area:- 800m² Covered area:- 1458m² No.'s of students:- 600 No's of classrooms:- 24

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR ✓
	• Gate width	-	-	-
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	P	MR
	• Upper Floors	02	02	MR
	• Basements	02	02	MR
	b. Width of staircases	R	P	MR
	• Upper Floors	1.5mts	1.5mts each	MR ✓
	• Basements	1.5mts	1.5mts each	MR ✓
	c. Protection of exits	-	-	-
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size	1mt	1.2mt	MR ✓

N/19

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	-	-	-
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	-	-
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	06 ISI marked	08 ABC Yes	MR ✓ MR ✓ MR ✓
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	one @ each floor 30 m 5 mm	P P P	MR ✓ MR ✓ MR ✓
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	-	-	-
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	R - -	P - -	MR ✓ - -
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	R (4") one R	P P P	MR ✓ MR ✓ MR ✓

12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	-	-	-
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pum 	-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		R	P	MR -
		450 lpm	P	MR -
		40 mtr	P	MR -
		-	-	-
		-	-	-
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 			
		10000ltr	P	MR -
15	Exit Signage.	R	P	MR -
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
17	Standby power supply	-	-	-

N/21

18	Refuge Area.			
	➤ Total Area	-	-	-
	➤ Location	-	-	-
19	Fire Control Room			
	• Detector System Panel	-	-	-
	• Flow Switch Panel	-	-	-
	• PA System Panel	-	-	-
	• Batter backup	-	-	-
	• Building Floor Plans	-	-	-
20	Special Fire Protection Systems for Protection of special Risks, if any:	-	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-4/DF.S/ms/2008/2774...Dated...01/10/08... Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

(Signature) 20-2-14

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name N. P. SHARMA

Name

Designation ADD R1

Designation



(Signature)
21/2/14