

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001
Ph.23414333,Fax:23412593,E-mail:cfohq.dfire@nic.in


No. *FG/DFS/MS/School/2014/ND2/363*

Dated: *14/03/2014*

FIRE SAFETY CERTIFICATE

Certified that the Nand Lal Modern Public School at A-Block,Sushila Garden,Fanne, Khan More,Mandoli,Delhi-93,owned/occupied by, Nand Lal Modern Public School comprising of ground plus one upper floor was granted NOC for ground floor vide letter no.F.6/DFS/MS/2008/1625 dated 16.06.2008.The school building was inspected by the officer concerned of this department on 03.03.2014 in the presence of Sh.Shiv Kumar Sharma (Manager) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and found that the building is fit for occupancy class B "Educational Building" with effect from.....*14/03/14*..... for a period of three years, subject to conditions printed overleaf.

14/3/14
Issued on...at New Delhi by



(Dr.G.C.Misra)
Chief Fire Officer
Delhi Fire Service

To,
The Manager
Nand Lal Modern Public School
A-Block,Sushila Garden,Fanne,
Khan More,Mandoli,Delhi-93,

Copy to:-
The Dy. Director of Education
B-Block,Yamuna Vihar, Delhi.

o/c
Recd
14/3/14

- MS
1. Name & address of the building : Nand Lal Modern Public School at A-Block, Sushila Garden
Fanne Khan More, Mandoli, Delhi-93.
 2. Building is comprised of : Ground +1 upper floor.
 3. Type of Occupancy : Educational
 4. Type of Case : Renewal
 5. Details of Previous NOC letter : F.6/DFS/MS/2008/1625 Dated 16.06.2006 for ground floor
 6. Fire Safety Circular No. : F.16/Estate/CC/FS/2011/3298 to 3398 dated 1.3.11
 7. Date of Inspection : 03.03.2014
 8. Name of the Inspecting officers : A DO Vijay Bahadur
 9. Name and designation of
Officer from the building side : Sh. Shiv Kumar Sharma (Manager).
 10. Year of Construction : 2006
 11. Applicant's letter No : dated 04.02.2014.

NO.	Minimum Standards on fire prevention and fire safety 3298 to 3398 dated 1.3.11	Circular Requirement	Provided at Site	Remarks
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 Mtrs.	7 Mtrs.	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	01 No.	2 Nos.	MR
		N/A	N/A	N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	1.5 M	1.0 M & 80 CMS	MR
		N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01No.	01No.	MR
	g. Width of Corridor	1.5 M	1.5 M	MR
	h. Door Size	1.0 Mtrs	1.0 Mtrs	MR
	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A	N/A	N/A
		N/A	N/A	N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • types • IS marking 	04 Nos.	06 Nos.	MR
		ABC & Co2	ABC & Co2	MR
		ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Length of hose reel hose • Nozzle diameter 	N/A	N/A	N/A
		N/A	N/A	N/A


7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of main panel Location of repeater panel Alternate source of power 	N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooter's location 	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	N/A	N/A	N/A
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> upper floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants	N/A	N/A	N/A
	<ul style="list-style-type: none"> size of riser/down-comer 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Number of hydrants per floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
12	Yard Hydrants.	N/A	N/A	N/A
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
13	Pumping Arrangements.	N/A	N/A	N/A
	<ul style="list-style-type: none"> Ground Level 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of Main Pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey pump head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby pump Head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting /Manual stopping 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Pump House Access 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace Level 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Discharge of pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of the Pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Power supply 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	<ul style="list-style-type: none"> Underground tank capacity 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Draw-off connection 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Fire service inlet 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Access to tank 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Overhead Tank capacity 	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Communication in lift car 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Firemen's grounding switch 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Lift Signage 	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	<ul style="list-style-type: none"> Total area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location 	N/A	N/A	N/A

N/5

19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire safety arrangements provided in the building were tested/ checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The NOC issued vide letter no. F.6/DFS / MS/2008/1625 Dated 16.06.2008 renewal under the circular no. F.16/Estate/CC/FS/2011/3298-3348 dated 1.3.11 is recommended


31/3/14


Signature of the Inspecting Officer

Name:-Vijay Bahadur

Designation:-ADO(T.Pur)

DO(ED)

Submitted for approval please.


4/20/14