

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001
Ph.23414333,Fax:23412593,E-mail:cfohq.dfire@nic.in

No. *FG/DFS/MS/School/2014/ND2/364*

Dated: *14/3/14*

FIRE SAFETY CERTIFICATE

Certified that the R.S.Memorial Public School at B-409,Gali no.21,Bhajanpura, Delhi-53, owned/occupied by R.S.Memorial Public School, comprising of ground floor was granted NOC vide letter no. No.F.6/DFS/MS/2008/2889 dated 16.10.2008.The school building was inspected by the officer concerned of this department on 24.02.2014 in the presence of Smt.Kusam Lata (Manager) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no.262-362 Dated 17.01.2005 issued by the Director of Education and found that the building is fit for occupancy class B "Educational Building" with effect from*14/3/14*..... for a period of three years, subject to conditions printed overleaf.

Issued on*14/3/14*..... at New Delhi by



(Dr.G.C.Misra)
Chief Fire Officer
Delhi Fire Service

GC
Real
14/3/14

To,
The Manager
R.S.Memorial Public School
B-409,Gali no.21,Bhajanpura, Delhi-53.

Copy to:-
The Dy.Director of Education
B-Block,Yamuna Vihar, Delhi.

- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building: R.S.Memorial Public School at B-409,Gali No.21,
Bhajanpura,Delhi -53.
2. Building is comprised of : Ground floor.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter :F.6/DFS/MS/2008/ 2889 dated 16.10.2008
6. Fire Safety direction letter No :Circular No.262-362 Dated 17.01.2005 Director of Education
7. Date of Inspection : 24.02.2014
8. Name of the Inspecting officers: DO Virendra Singh
9. Name and designation of Officer:
from the building side : Smt.Kusam Lata (Manager)
10. Year of Construction - :2008
11. Applicant's letter No : Nil

| NO. | Minimum Standards on fire prevention and fire safety U/R33 | Old Circular Requirement | Provided at Site | Remarks |
|-----|--|--------------------------|------------------|---------|
| 1 | Access to building | | | |
| | • Road width | 06 Mtrs. | 06Mtrs. | MR |
| | • Gate width | N/A | N/A | N/A |
| | • Width of internal road | N/A | N/A | N/A |
| 2 | Number, Width, Type and Arrangement of Exits | | | |
| | a. Number of Staircases | | | |
| | • Upper Floor | N/A | N/A | N/A |
| | • Basement | N/A | N/A | N/A |
| | B. Width of Staircases | N/A | N/A | N/A |
| | • Upper Floor | N/A | N/A | N/A |
| | • Basement | N/A | N/A | N/A |
| | c. Protection of exits | N/A | N/A | N/A |
| | • Fire check door | N/A | N/A | N/A |
| | • 5Pressurization | N/A | N/A | N/A |
| | e. No. of continuous staircases to terrace | N/A | N/A | N/A |
| | g. Width of Corridor | N/A | N/A | N/A |
| | h. Door Size | 1.0 Mtrs | 1.0 Mtrs | MR |
| 3 | Compartmentation. | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Sealing of electrical shafts | N/A | N/A | N/A |
| | • Fire rating of shaft door | N/A | N/A | N/A |
| | • Water curtain | N/A | N/A | N/A |
| | • Fire Dampers | N/A | N/A | N/A |
| 4 | Smoke Management System. | | | |
| | • Basement | N/A | N/A | N/A |
| | • Upper floor | N/A | N/A | N/A |
| 5. | Fire Extinguisher | | | |
| | • Total numbers | 2 Nos. | 5 Nos. | MR |
| | • Types | ABC & Co2 | ABC & Co2 | MR |
| | • IS marking | ISI marked | ISI marked | MR |
| 6 | First-aid-Hose Reels. | | | |
| | Total numbers of each floor | N/A | N/A | N/A |
| | • Length of hose reel hose | N/A | N/A | N/A |
| | • Nozzle diameter | N/A | N/A | N/A |
| 7 | Automatic fire detection and alarming system. | | | |
| | • Type of detectors | N/A | N/A | N/A |
| | • Location of main panel | N/A | N/A | N/A |
| | • Location of repeater panel | N/A | N/A | N/A |

| | | Required | Provided | MR |
|----|--|----------|----------|-----|
| 8 | MOEFA | | | |
| 9 | Public address System. | N/A | N/A | N/A |
| 10 | Automatic Sprinkler System. | | | |
| | • Basement | N/A | N/A | N/A |
| | • upper floor | N/A | N/A | N/A |
| | • sprinkler above false ceiling | N/A | N/A | N/A |
| 11 | Internal Hydrants | | | |
| | • size of riser/down-comer | N/A | N/A | N/A |
| | • Number of hydrants per floor | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 13 | Pumping Arrangements. | N/A | N/A | N/A |
| | • Ground Level | N/A | N/A | N/A |
| | ➤ Discharge of main Pump | N/A | N/A | N/A |
| | ➤ Head of Main Pump | N/A | N/A | N/A |
| | ➤ Number of main pumps | N/A | N/A | N/A |
| | ➤ Jockey pump out put | N/A | N/A | N/A |
| | ➤ Jockey pump head | N/A | N/A | N/A |
| | ➤ Standby pump out put | N/A | N/A | N/A |
| | ➤ Standby pump Head | N/A | N/A | N/A |
| | ➤ Auto Starting /Manual stopping | N/A | N/A | N/A |
| | ➤ Pump House Access | N/A | N/A | N/A |
| | • Terrace Level | N/A | N/A | N/A |
| | ➤ Discharge of pump | N/A | N/A | N/A |
| | ➤ Head of the Pump | N/A | N/A | N/A |
| | ➤ Power supply | N/A | N/A | N/A |
| | ➤ Auto Starting of pump | N/A | N/A | N/A |
| 14 | Captive Water Storage for Fire Fighting. | N/A | N/A | N/A |
| | • Underground tank capacity | N/A | N/A | N/A |
| | ➤ Draw-off connection | N/A | N/A | N/A |
| | ➤ Fire service inlet | N/A | N/A | N/A |
| | ➤ Access to tank | N/A | N/A | N/A |
| 15 | • Overhead Tank capacity | N/A | N/A | N/A |
| 16 | Exit Signage. | N/A | N/A | N/A |
| 17 | Provision of Lifts. | N/A | N/A | N/A |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication in lift car | N/A | N/A | N/A |
| | • Firemen's grounding switch | N/A | N/A | N/A |
| | • Lift Signage | N/A | N/A | N/A |
| 18 | Standby power supply | N/A | N/A | N/A |
| | Refuge Area. | N/A | N/A | N/A |
| | • Total area | N/A | N/A | N/A |
| | • Location | N/A | N/A | N/A |
| 19 | Fire Control Room | N/A | N/A | N/A |
| | • Detector system panel | N/A | N/A | N/A |
| | • Flow switch panel | N/A | N/A | N/A |
| | • PA system panel | N/A | N/A | N/A |
| | • Battery backup | N/A | N/A | N/A |

N/S

| | | | | |
|----|--|-----|-----|-----|
| 20 | Special Fire Protection systems for protection of special Risks, if any: | N/A | N/A | N/A |
|----|--|-----|-----|-----|

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The NOC issued vide letter no. F.6/DFS/MS/2008/2889 dated 16.10.2008 renewal under the circular no.262-362 dated 17.01.2005 is recommended, *please.*

Virendra Singh
5/27/14

Signature of the Inspecting Officer
Name:-Virendra Singh
Designation:-DO (ED.)