

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/School/2014/w2/ 373

Dated: 14/ 3 /2014

FIRE SAFETY CERTIFICATE

Certified that the Sanskar Shiksha Kunj, Gali no.-9-B, Main Gaunda Road, Bankner, Delhi-110040 comprised of Ground + one upper floor owned/occupied by Sanskar Shiksha Kunj have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 18/02/2014 in the presence of Mrs. Soni Khatri (Principal) and that the building / premises is fit for occupancy of Educational building with effect from 14/ 3 /2014 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 14/3/14 at New Delhi


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Sanskar Shiksha Kunj, Gali no.-9-B, Main Gaunda Road, Bankner, Delhi-110040
2. The Director of Education, Old Secretariat, Delhi,



N/1

Gr. floor only.
(Two Block)

INSPECTION REPORT

1. Name & address of the building: Samskar Shiksha kumj Gali No. 9B
2. Type of Occupancy : Educational Gonda Rd. Banknel
3. Type of Case : New Case / Renewal 2011-40
4. Details of previous NOC : N/A
5. Fire Safety directives letter No : Dir. of Edu.
6. Date of inspection : 18.2.14
7. Name of the Inspecting Officers : ADD (B/W)
8. Name and designation of officers from the building side : Mrs. Soni Khatri Principal
9. Year of Construction : 2011
10. Applicant's letter No. : lt ab Nir dt. 7.2.14

PA - 2500 sq. yards. CA -

NO CR = 9
6 room for other purpose
NOC - 200

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement <u>Dir. of Edu.</u>	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Accessable</u>	<u>Accessable</u>	<u>MR</u>
	• Gate width	<u>- do</u>	<u>- do</u>	<u>MR</u>
	• Width of internal road	<u>-</u>	<u>-</u>	<u>-</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			<u>N/A</u>
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	<u>1 m²</u>	<u>1 m²</u>	<u>MR</u>
3	Compartmentation.			
	• Fire check door	<u>-</u>	<u>-</u>	<u>-</u>

13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pum 			
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply			
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 			

2/4.

	<ul style="list-style-type: none"> • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

→ XI/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers..... Nil.....

Signature of the Inspecting Officer

Name

Designation

[Handwritten signature]

Deputy
27/2/14


Signature of the Inspecting Officer

Name

Designation

[Handwritten signature]
25-2-14

ADD (BWS)



158/DCO (W)