

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

Ph.23414333,Fax:23412593,E-mail:cfohq.dfire@nic.in

No.

F.6/DF/MS/school/2014/ND2/365

Dated:

14/3/14

FIRE SAFETY CERTIFICATE

Certified that the Yog Bharti Public School at C-Block, New Ashok Nagar, Delhi-96, owned/occupied by Yog Bharti Public School, comprising of ground plus three upper floors was issued Fire Safety Certificate vide letter no. No.F.6/DFS/MS/2010/3379 dated 20.12.2010. The school building was inspected by the officer concerned of this department on 12.02.2014 in the presence of Sh.C.P.Gupta (Chairman) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no.262-362 Dated 17.01.2005 issued by the Director of Education and found that the building is fit for occupancy class B "Educational Building" with effect from14/3/14..... for a period of three years, subject to conditions printed overleaf.

Issued on14/3/14..... at New Delhi by



(Dr.G.C.Misra)
Chief Fire Officer
Delhi Fire Service

g.c.
Red
14/3/14

To,

The Head Mistress
Yog Bharti Public School
C-Block, New Ashok Nagar, Delhi-96,

Copy to:-

The Dy. Director of Education
Anand Vihar, Delhi.

- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building: YogBharti Public School at C- Block, New Ashok Nagar, Delhi -90
2. Building is comprised of : Ground +3, upper floor.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/2010/3379 dated 20.12.2010
6. Fire Safety direction letter No : Circular No.262-362 Dated 17.01.2005 Director of Education
7. Date of Inspection : 12.02.2014
8. Name of the Inspecting officers: DO Virendra Singh
9. Name and designation of Officer:
from the building side : Sh.C.P.Gupta (Chairman).
10. Year of Construction - :1997
11. Applicant's letter No : dated 29.01.2014.

NO.	Minimum Standards on fire prevention and fire safety U/R33	Old Circular Requirement	Provided at Site	Remarks
1	Access to building	06 Mtrs.	06 Mtrs.	MR
	• Road width	N/A	N/A	N/A
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	02 Nos	02 Nos.	MR
	• Upper Floor	N/A	N/A	N/A
	• Basement			
	B. Width of Staircases			
	• Upper Floor	1.5 M	1.10 M & 90 CM	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	1no.	2 Nos.	MR
	g. Width of Corridor	1.5 M	1.45 & 1.5 M	MR
	h. Door Size	1.0 Mtrs	1.0 Mtrs	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	08 Nos.	10 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	1 no.	1 no.	MR
	• Length of hose reel hose	30 M	30 M	MR
	• Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A


8	MOEFA	Required	Provided	MR
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 MM	100 MM	MR
	• Number of hydrants per floor	1 No.	1 No.	MR
	• Hose Box	1No.	1 No.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.	N/A	N/A	N/A
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
15	• Overhead Tank capacity	5000 Ltrs.	5,000 Ltrs.	MR
16	Exit Signage.	N/A	N/A	N/A
	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
17	• Lift Signage	N/A	N/A	N/A
18	Standby power supply	N/A	N/A	N/A
	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
19	• Location	N/A	N/A	N/A
	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A

NIS

20	• Building Floor Plans	N/A	N/A	N/A
	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.
In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The Fire Safety certificate issued vide letter no. F.6/DFS/MS/2010/3379 Dated 20.12.2010 renewal under the circular no.262-362 dated 17.01.2005 is recommended.




Signature of the Inspecting Officer

Name:-Virendra Singh

Designation:-DO(ED)