

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/GH/2014/MD2/340

Dated: 20/03/14

FIRE SAFETY CERTIFICATE

Certified that the Al Tauheed, Guest House located at 3771-72-73 and 3774, Netaji Subhash Marg, Darya Ganj, New Delhi -110002, comprises of ground floor commercial (Others properties), first floor (03 guest rooms + reception), 2nd floor (03 guest rooms), 3rd floor (03 guest rooms), 4th floor (02 guest rooms), total 11 guest rooms, owned/occupied by M/S Al Tauheed, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on dated 25.02.14 in the presence of Sh. Shah Nawaz Ahmad (Manager) and that the building is fit for occupancy class "Residential" Group A Sub Division A-1 Lodging or Rooming Houses for first floor to fourth floor with effect from 20/03/2014 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules, 2010.

Issued on 20/03/14 at New Delhi by



(Dr.G.C.Misra)
Chief Fire Officer
T.No.011-23414333



Copy to:-

1. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony New Delhi-110049 w.r.t. letter No.50144/Joint C.P./Lic.(H) dated 26.09.13.
2. M/s Al Tauheed, 3771-72-73 and 3774, Netaji Shubhash Marg Darya Ganj New Delhi-2.
3. Commissioner, NDMC, Civic Centre, New Delhi for verification of height of building.

Conditions for the validity of fire safety certificate are overleaf:-

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Al Tauheed, Guest House, 3771-72-73 and 3774, Netaji Subhash Marg, Darya Ganj, New Delhi -110002.
2. Building is comprised of : G+4 (Guest house at 1st floor to 4th floor). Ground floor Commercial (Others properties). Total 11 Rooms
3. Type of Occupancy : Lodging House.
4. Type of Case : New Case.
5. Details of Previous NOC : Nil
6. Fire Safety direction letter No : N/A
7. Date of Inspection : 25.02.2014
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of Officer from the building side : Sh. Shah Nawaz Ahmad (Manager)
10. Year of Construction : 1983
11. Applicant's letter No : No.50144/Joint C.P./Lic.(H) dated 26.09.13


S.No	Minimum Standards on fire prevention and fire safety U/R33	BBL Requirements (PSS Area)	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	N.A.	40 meters	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	A. Number of Staircases	1 no.	1 no.	MR
	Upper Floor	1 no.	1 no.	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases	80 cms.	90 cms.	MR
	Upper Floor	80cms.	90 cms.	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits	N.A.	N.A.	N.A.
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
	g. Width of Corridor	N.A.	N.A.	N.A.
	h. Door Size	N.A.	N.A.	N.A.
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	N.A.	N.A.
	Upper floor	12 a/c per hour	N.A.	N.A.

5.	Fire Extinguisher	08 nos.	08 nos.	MR
	Total numbers	CO ₂ & ABC	CO ₂ & ABC	MR
	types	ISI marked	ISI marked	MR
	IS marking			
6	First-aid-Hose Reels.	N.A.	N.A.	N.A.
	Total numbers of each floor	N.A.	N.A.	N.A.
	Length of hose reel hose	N.A.	N.A.	N.A.
	Nozzle diameter	N.A.	N.A.	N.A.
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	Basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the Pump	N.A.	N.A.	N.A.
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.

N/4

Al Tauheed, 3771-72-73 and 3774, Netaji Subhash Marg, Darya Ganj, New Delhi -02

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	N.A.	N.A.	N.A.
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	Required	01Co ₂ &01ABC Fire Extinguisher provided near electric panel	MR



The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

[Handwritten Signature]
10/3/14

Signature of the Inspecting Officer
Name Vedpal
Designation ADO