

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/School/2014/SZ/ 350

DATED: 21/03/14

FIRE SAFETY CERTIFICATE

Certified that the Great Mission Public School Located at D-40, Sanjay Enclave, New Delhi -110059 comprised of ground plus one upper floor was granted NOC by this department vide letter no. F6/MS/DFS/2011/411 Dated. 03.03.2011. The school building was re-inspected by the officer concerned of this department on 13.03.2014 in the presence of Sh. Uma Shankar (Administration) and found that the school management have deemed complied with fire prevention and fire safety requirements in accordance with under Rule 33 of Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class B "Educational building" with effect from 21/03/14 for a period of **three Years** subject to compliance of the conditions mentioned below.

Issued on 21/03/14 at New Delhi by



(Dr. G.C. Misra)  
Chief Fire Officer  
Delhi Fire Service

Copy to,

1. The Dy. Director, (Education), G.N.C.T...Of Delhi, Old Secretariat, New Delhi-110054.
2. The Principal, Great Mission Public School, D-40, Sanjay Enclave, New Delhi-110059.

Conditions for the validity of fire safety certificate

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1	Name & address of the building	Great Mission Public School, D-40, Sanjay Enclave, New Delhi-110059.	
2	Type of Occupancy	Educational Building "B"	
3	Type of case	Renewal	
4	Details of previous NOC	F6/MS/DFS/2011/411 dated 3.3.2011	
5	Fire safety directives letter No	Nil.	
6	Date of inspection	13.3.2014	
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj	
8	Name and designation of officers from the building side	Sh. Uma Shankar (Administration)	
9	Year of construction	1990	(Ground plus two upper floor)
10	Applicant's letter No.	GMPS/F/17/46 Dated.28.2.2014	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
--------	---	-----------------	------------------	---------------------

<b>1</b>	<b>Access to building</b>			
	1) Road width	Approachable for F E	6 Mtrs.	MR
	2) Gate width	Old Case	3 Mtrs.	MR
	3) Width of internal road	old case	5.4 Mtrs.	MR

<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	Old Case	2 Nos.	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	Old case	1 Mtr. each	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	Required	One	MR
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	Old Case	1 Mtr.	MR

<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

<b>4</b>	<b>Smoke Management system.</b>			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		Natural Vent.	MR

<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers		6 Nos	MR
	Types		Co2 & ABC	MR

<b>6</b>	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	N/A	One Provided	MR
	Length of Hose reel hose	N/A	30 Mtr Provided	MR
	Nozzle Diameter	N/A	5mm provided	MR
<b>7</b>	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
<b>8</b>	<b>MOEFA</b>	N/A	N/A	N/A
<b>9</b>	<b>Public Address System.</b>	N/A	Provided	old case
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	MR
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants</b>			
	Size of riser/down-corner	Old case	100 MM Provided	MR
	Number of Hydrants per floor	Old case	One Provided	MR
	hose Box	Old case	One Provided	MR
<b>12</b>	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
<b>13</b>	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	N/A	450 LPM	MR
	b. head of the pump	N/A	35 Mtrs.	MR
	c. Power supply	N/A	N/A	MR
	d. Auto starting of pump	N/A	N/A	MR
<b>14</b>	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	Old case	5000 Ltr.	MR
<b>15</b>	<b>Exit Signage.</b>	Old case	Provided	MR
<b>16</b>	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC Provided.			

The fire protection systems provided in the building were checked and found functional at the time of inspection. In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No.F6/DFS/MS/2011/411 Dated.3.3.2011, is recommended for renewal.

Accordingly DFA is put up for your approval and signature please.

*S.P. Bhardwaj*  
13/3/14  
Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)