

NO. F6/MS/DFS/~~FW~~2014/SZ/352

DATED: 21/03/14

FIRE SAFETY CERTIFICATE

Certified that the Fireworks shop No.10, at ground floor, DDA Market Bindapur Pkt.10 Delhi of the building comprised of ground floor only owned and occupied by M/s Komal Fireworks have complied with the fire prevention and fire safety requirements in accordance with the Delhi Police Act and verified by the officers concerned of Fire Service on Dated 8.10.2014 in the presence of Sh. Sanjay Kumar and that the shop class Fireworks storage with effect from 21/03/14... for a period of **three** years , subject to conditions printed overleaf.

Issued on21/03/14..... at New Delhi by



(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph. No. 011-23414333



To,

1. The Addl. Commissioner of Police (Lic.),
1st Floor Police Station Defence Colony,
New Delhi

Copy to:

2. Smt. Komal ,
WZ-230, Gali No.7
Lajwanti Garden,
New Delhi.110059.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of the Licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1	Name & address of the building	M/s Komal Firework at Shop No. 10, DDA Market Bindapur, Pkt. 10, Delhi.		
2	Type of Occupancy	Storage Fireworks		
3	Type of case	New Case		
4	Details of previous NOC	Nil		
5	Fire safety directives letter No	Nil		
6	Date of inspection	08.10.2014.		
7	Name of the inspecting Officers :	Sanjay Kumar Tomar DO and ADO S. P. Bhardwaj		
8	Name and designation of officers from the building side	Sh.Sanjay Kumar		
9	Year of construction	2014		
10	Applicant's letter No.	(PFW/04)/2014/9341-43/Joint CP/Lic. (Expl.), dated 25.02.2014		
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR / NMR
1	Type of construction and floor area & floor area of the shop/premises.			
	(a) Minimum floor area	9 sq mtr to 16 sq mtr	9.27 Sq Mtr	MR
	(b) Construction	Pucca	Provided	MR
	(c) Premises Location	Not allowed staircase/means of exit	Complied	MR
	(d) Business permissible only at ground floor.	Required	Complied	MR
	(e) Business from payment of Road Prohibited	Prohibited	Yes	MR
2	Entrance and exit to the licensed premises.			
	The licensed premises shall have independent entrance and exits.	Required	Provided	MR
3	Type of distance of the surrounding risk.			
	The premises shall be situated at a distance of 15m from any such premises used for similar explosive/inflammable or hazardous material.	Required 15 Mtr	Complied	MR
4	Nature of business run in the license premises.			
	The premises in which fire work are kept shall be used only for possession and sale of fireworks and for no other purpose.	Required	Yes	MR

Surya

N/2

5	Type of electric wiring and electrical fitting.			
	(a) Concealed or through conduit	Required	Provided	MR
	(b) All electrical fitting should be flame/spark proof.	Required	Provided with casing & capping	MR
6	Extension of premises.			
	It is prohibited	Prohibited	Yes	MR
7	Approach road.			
	The road width on the side of which premises is located shall be 12mtr.	12 Mtr	Provided	MR
8	Fire protection arrangements.			
	(a) Extinguishers are ISI marked or not (mandatory).	2 Nos. Water type & 1 No. of ABC/Co2 type	Provided	MR
	(b) No of Sand and water buckets (Minimum 2 buckets each of sand and water shall be provided.	2 Nos each	Provided	MR
	No. of extinguishers and type (which shall be in accordance with the risk and area of the premises).	1 No.	Provided	MR
9	Any other point that is contrary to the safety of people.			

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010

Accordingly DFA is put up for your approval and signature please.

Sanjay Tomer
14/3/14

Signature of the inspecting officer

S.P. Bhardwaj
14/3/14

Signature of the inspecting officer

Name Sanjay Tomer

Name S.P Bhardwaj

Designation : DO

Designation:- ADO