

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No: F6/DF-S/MS/school/w14/w2/332

Dated: 20/03/14

FIRE SAFETY CERTIFICATE

Certified that the building of Nigam Pratibha Vidyalaya, located at Basai Dara Pur, New Delhi - 110015 comprised of Ground & Ground plus One Upper Floor, owned and occupied by Nigam Pratibha Vidyalaya have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and verified by the officers concerned of Fire Service on 30-01-2013 in the presence of Krishna Pawar (Principal) and that the building / premises is fit for the occupancy class "Educational" Group B Sub Division B - 1 with effect from 20/03/14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/03/14 at New Delhi.

(Santokh Singh)
Chief Fire Officer,
Delhi Fire Service.
Ph: 011 - 23414250

Copy to:-

1. The Principal,
Nigam Pratibha Vidyalaya,
Basai Darapur, New Delhi - 110015.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement if any shall be used strictly as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N^o 12

Reinspection to see compliance of shortcomings communicated vide letter no. F6/DFS/MS/school/2013/2220 dated 13-9-13

INSPECTION REPORT

1. Name & address of the building: Nigam Pratibha Vidyalaya,
Basai Dara Road, New Delhi-110015
2. Type of Occupancy : Educational Ground & Ground + Upper floor
3. Type of Case : NEW 20 class rooms + 3 other rooms
4. Details of previous NOC : Letter No -
5. Fire Safety directives Letter No. : DOE circular 3298-3398 dated 1/3/11
6. Date of inspection : 30-1-14
7. Name of the Inspecting Officer : Mukesh Verma ADD(MM)
8. Name and designation of Officer
from the building side : Krishna Panwar
(Principal)
9. Year of Construction : 1956
10. Applicant's letter No. : Nil dated 23-10-13

Total Area = 3937.5 m², Covered Area = 3136 m²

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m	1.162m 2.110m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1m	Provided Double Doors	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		N/A	
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N/A	
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	13 ABC & CO ₂ ISI marked	Provided ABC & CO ₂ Yes	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 		N/A	
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		N/A	
8.	MOEFA		N/A	
9.	Public Address System		N/A	
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 		N/A	

N/A

Internal Hydrants

- Size of riser/down-comer
- Number of hydrants per floor
- Hose Box

		N/A	

12. Yard Hydrants

- Total number of hydrants
- Hose Box

		N/A	

13. Pumping Arrangements

- Ground Level
- Discharge of main pump
- Head of main pump
- Number of main pumps
- Jockey pump out put
- Jockey pump head
- Standby Pump out put
- Standby Pump Head
- Auto Starting/Manual stopping
- Pump House Access
- Terrace level
- Discharge of pump
- Head of the pump
- Power supply
- Auto starting of pump

		N/A	
		N/A	

14. Captive water Storage for fire fighting

- Under ground tank capacity
- Draw of connection
- Fire service inlet
- Access to tank
- Overhead Tank capacity

		N/A	
NR	Provided 10000Lts		MR

15	Exit Signage		N/A	
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft			
	➤ Pressurization of lift lobby			
	➤ Communication in lift Car		N/A	
	➤ Fireman's Grounding Switch			
	➤ Lift Signage			
17.	Standby power supply		N/A	
18.	Refuge Area			
	➤ Total area			
	➤ Location		N/A	
19.	Fire control room			
	➤ Detector system panel			
	➤ Flow Switch Panel			
	➤ PA System Panel			
	➤ Batter backup		N/A	
	➤ Building Floor Plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any;		N/A	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/~~issue shortcomings as noted at serial numbers~~.....


Signature of the Inspecting Officer

Name MURESH VERMA

Designation ADD (M2)

Signature of the Inspecting Officer

Name

Designation