


NO. F6/DFS/MS/School/2014/ 52/348

DATED: 21/03/14

FIRE SAFETY CERTIFICATE

Certified that the St. Louis Public School at RZ-50 A, Hari Vihar, Palam More, New Delhi-110043, comprised of ground floor plus one upper floor owned/occupied by St.Louis public School . The inspection of school was carried out & found complied with the Fire prevention and Fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Saftey/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi and verified by the officers concerned of Fire Service on 18.3.2014 in the presence of BK Sahu (Manager) and that the School building is fit for occupancy class B "Educational building" for ground Plus one upper floor with effect from 21/03/14... for a period of **three years**, subject to condition as mentioned below.

Issued on 21/03/14..... at New Delhi by



(Dr. G C Misra)
Chief Fire Officer
Delhi Fire Service
Ph 01123414333

Copy to,

1. The Dy. Director, (Education), G.N.C.T...of Delhi, Old Secretariat, New Delhi-54.
2. Manager St. Lious Public School , RZ-50A,Hari Vihar,Palam More, New Delhi-110043.

Conditions for the validity of fire safety certificate

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1	Name & address of the building	St. Louis Public School , RZ-50A, Hari Vihar, Palam Mode, New Delhi-110043.	
2	Type of Occupancy	Educational Building "B"	
3	Type of case	New	
4	Details of previous NOC	No	
5	Fire safety directives letter No	Edu. Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.	
6	Date of inspection	18.3.2014	
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj	
8	Name and designation of officers from the building side	Sh. B K Sahu (Manager)	
9	Year of construction		
10	Applicant's letter No.	SLPS/2014 Dated.19.2.2014.	(ground plus one upper floor)

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per Directotote of Education.	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	6 Mtrs.	MR
	2) Gate width	Required	3 Mtrs. Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	1NO(1.5 mtrs.)	2 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtrs.	1.06 & .75 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	One	One	MR
	e. Width of corridor	N/A	2.80 Mtrs.	MR
	f. Door size	Required	1 Mtr	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		Natural Vent.	MR
5	Fire Extinguishers			
	total numbers		6 Nos	MR
			CO2 & ABC	MR

	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/3.

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	Yes	ABC	

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards of fire prevention and fire safety required as per circular No. F/16/ Estate/CC/Fire Safety/2011/3298-3398 it is recommended to grant Fire Safety Certificate.

(Directorate of Education)

Accordingly DFA is put up for approval and signature please.

Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)

S.P. Bhardwaj
18/3/14