

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:- 011-23412593

E-mail ID:cfohq.dlfire@nic.in

No F 6 / DFS / MS / EH / 2014 / N02/354

Dated 25/03/14

FIRE SAFETY CERTIFICATE

Certified that the Restaurant in the name and style of **Pizza Hut Restaurant (A unit of Devyani International Ltd.) outlet at M-20, Connaught Place, New Delhi** running at Basement + ground floor and Mezzanine floor and Building is comprised of Basement + ground floor + 2 upper floors was granted NOC by this department vide letter No. F6/DFS/MS/EH/2009/2945 dated 06-10-2009. The premises was re-inspected by the officer concerned of this department on 05-03-2014 in the presence of Sh. Arun Ram (Manager) and found that the said restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy with effect from 25/03/14---2014 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...25/03/14..... at New Delhi by.


(DR.G.C.MISRA)
Chief Fire Officer
Delhi fire Service
Ph – 011-23414333

Copy to:-

1. Pizza Hut Restaurant (A unit of Devyani International Ltd.) outlet at M-20, Connaught Place, New Delhi.
2. Smt. Indu Shekhar Mishra Dy. Commissioner (Excise)/ Licensing Authority L & N Block, Vikas Bhawan, I.P. Estate, New Delhi-110002.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

- 1. Name & address of the building : Pizza Hut Restaurant (A unit of Devyani International Ltd.) outlet at, M-20, Connaught Place, New Delhi
- 2. Type of Occupancy : Restaurant Assembly (B + Gr. & Mezzanine floor)
- 3. Type of Case : Renewal
- 4. Details of previous NOC : F6/DFS/MS/EH/2009/2945 dated 06/10/2009
- 5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 05/03/2014
- 7 Name of the Inspecting Officer : M. K. Sharma (Assistant Divisional Officer)
- 8 Name and designation of Officer
from the building side : Mr. Arun Ram (Manager)
- 9 Year of Construction : Existing Heritage Bldg. (C.C.)
- 10. Applicant's letter No. : No.F.I/Ex/R/L-17/2010-11/14 dated 10/01/2014

S No	Minimum standards on fire prevention and fire safety U/R 33	Existing Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 Mtr	12 Mtr	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos.	2 Nos.	MR
	• Basements	1 No.	1 No.	MR
	b. Width of staircases			
	• Upper floors	80 cms & 90 cms	80 cms & 90 cms	MR
	•	old case	old case	
	• Basements	80 cms	80 cms	MR
	c. Protection of exits			

merh

	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA	NA	NA
	d. No of continuous staircase to terrace	1 No.	1 No.	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	30 ACPH	Mechanical	MR
	<ul style="list-style-type: none"> • Upper floors 	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	10 Nos.	12 Nos.	MR
	<ul style="list-style-type: none"> • Types 	ABC, CO ₂ , Wco ₂	ABC, CO ₂ , Wco ₂	MR
	<ul style="list-style-type: none"> • IS marking 	YES	Provided	MR
6	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	01	01	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	05 MM	05 MM	MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler			
	<ul style="list-style-type: none"> • Basements 	Required	Provided	MR

MR

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 	Required	Provided	MR
11	Internal Hydrants	NA	NA	NA
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
12	Yard Hydrants	NA	NA	NA
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head auto Starting/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 & 180 LPM	450 & 180 LPM	MR
		30 Mtr.	30 Mtr.	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water Storage for fire fighting	NA	NA	NA
	<ul style="list-style-type: none"> Under ground tank capacity Draw of connection Fire service inlet Access to tank Overhead Tank capacity 	15,000Ltrs.	15,000Ltrs.	MR
		NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
		NA	NA	NA

Mark

-17/8

15	Exit Signage	Required	Provided	MR
16	Provision of Lifts	NA	NA	NA
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of lift lobby	NA	NA	NA
	• Communication in lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	Provided	NA
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire control room			
	• Detector system panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC, Co ₂	MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2009/2945 dated 06/10/2009 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

M.K. Sharma
19/3/14

Name :- M.K. Sharma

Designation :- A. D.O. (CC)