

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

Fax:- 011-23412593

E-mail ID:cfohq.dlfire@nic.in


No *F6/DFS/MS/School/2014/MOZ/373*

Dated: *01/04/14*

FIRE SAFETY CERTIFICATE

Certified that **J.P.M. Senior Secondary School for the Blind Lal Bahadur Shastri Marg, Near Hotel Oberoi, New Delhi – 110003** comprises of ground floor classes, first floor hostel & classes, second floor hostel was inspected by the officer concerned of this department on 14-12-2013 in the presence of Mr. David (Principal) and found that the said school building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of **class B & A “Educational Building” & Residential (Hostel)** with effect from *01/04/*2014 for period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to the condition printed overleaf.

Issued on *01/04/14*..... at New Delhi by.



(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph – 011-23414333

Copy to:-

1. J.P.M. Senior Secondary School for the Blind Lal Bahadur Shastri Marg, Near Hotel Oberoi, New Delhi – 110003.
2. P.C. Mehta Dy. Executive Secretary J.P.M. Sr. Sec. School for the Blind.
3. The Director of Education Govt. of NCT.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of Unauthorized construction, if any.

N/1

INSPECTION REPORT

1. Name & address of the building : J.P.M. Senior Secondary School for the blind Lal Bahadur Shastri Marg, (Near Hotel Oberoi), New Delhi-110003
2. Type of Occupancy : Educational & Residential (Hostel) (Gr. + 2 floors) Gr. floor-classes, 1st floor- classes and hostel & 2nd floor- hostel
3. Type of Case : Fresh
4. Details of previous NOC : NA
5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 14/12/2013
- 7 Name of the Inspecting Officer : M. K. Sharma (Assistant Divisional Officer)
- 8 Name and designation of Officer
from the building side : Mr. David (Principal)
- 9 Year of Construction : old building
10. Applicant's letter No. Sa.P.C. Mehta Dy. Executive Secretary dated 08/11/2013

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 Mtr.	9 Mtr.	MR
	• Gate width	4.5 Mtr.	4.5 Mtr.	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	03	03	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	0.83, 1.10 & 1.5 Mtr.	0.83, 1.10 & 1.5 Mtr.	MR
	• Basements	NA	NA	NA

Mash

N/2

	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02	02	MR
	e. Width Of Corridor	1.25 Mtr.	1.50 Mtr.	MR
	f. Door Size	1.0 Mtr.	1.0 Mtr.	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	12	16	MR
	• Types	ABC, CO ₂ , Wco ₂	ABC, CO ₂ , Wco ₂	MR
	• IS marking	Required	Provided	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	03	03	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	05 MM	05 MM	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler			

Merv

	<ul style="list-style-type: none"> Basements 	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer 	100 MM	100 MM	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	02	02	MR
	<ul style="list-style-type: none"> Hose Box 	02	02	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump 	NA	NA	NA
	<ul style="list-style-type: none"> Head of main pump 	NA	NA	NA
	<ul style="list-style-type: none"> Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> Jockey pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> Jockey pump head 	NA	NA	NA
	<ul style="list-style-type: none"> Standby Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> auto Staring/Manual stopping 	NA	NA	NA
	<ul style="list-style-type: none"> Pump House Access 	NA	NA	NA
	<ul style="list-style-type: none"> Terrace level 	NA	NA	NA
	<ul style="list-style-type: none"> Discharge of pump 	450 LPM	450 LPM	MR
	<ul style="list-style-type: none"> Head of the pump 	30 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> Power supply 	Required	Provided	MR
	<ul style="list-style-type: none"> Auto starting of pump 	Required	Provided	MR
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Under ground tank capacity 	Not Required	50,000 ltrs	NA
	<ul style="list-style-type: none"> Draw of connection 	NA	NA	NA
	<ul style="list-style-type: none"> Fire service inlet 	NA	NA	NA
	<ul style="list-style-type: none"> Access to tank 	Required	Provided	MR

2/4

	<ul style="list-style-type: none"> Overhead Tank capacity 	10,000 ltrs.	10,000 ltrs.	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> Pressurization of lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> Communication in lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> Lift Signage 	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	<ul style="list-style-type: none"> Total area 	NA	NA	NA
	<ul style="list-style-type: none"> Location 	NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> Detector system panel 	NA	NA	NA
	<ul style="list-style-type: none"> Flow Switch Panel 	NA	NA	NA
	<ul style="list-style-type: none"> PA System Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Batter backup 	NA	NA	NA
	<ul style="list-style-type: none"> Building Floor Plans 	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC, Co ₂	MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010, is recommended please.

DO (CD)

[Handwritten Signature]
26/3/14

Signature of the Inspecting Officer

[Handwritten Signature]

Name :- M.K. Sharma
Designation :- A. D.O. (CC)