

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:- 011-23412593

E-mail ID:cfohq.dlfire@nic.in

No F6/DFS/MS/EH/ 2014 / MDZ / 371

Dated 01 / 04 / 14

FIRE SAFETY CERTIFICATE

Certified that the **Parikarma Discotheque Premises in Roof Top Revolving Hotels & Restaurant at 22, K.G. Marg, New Delhi** Comprised of Basement, Ground + 19 upper floors (Restaurant is at 18 & 19 floor) was granted NOC by this department vide letter No. F6/DFS/MS/2011/EH/2228 dated 13-09-2011. The premises was re-inspected by the officers concerned of this department on 11-03-2014 in the presence of Mr. Naresh Tyagi (Manager) and found that the said Restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Assembly Building Group D of Sub-Division D-5, with effect from ~~01/04/2014~~ 01/04/2014 for period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 01 / 04 / 14 at New Delhi by.


31/3
(Dr. G. C. Misra)
Chief Fire Officer
Delhi fire Service
Ph – 011-23414333

Copy to:-

1. Parikarma Discotheque Premises in Roof Top Revolving Hotels & Restaurant at 22, K.G. Marg, New Delhi.
2. Medical officer of Health, Health Department, Palika Kendra, New Delhi – 110001
No. MOH/167/D/CMO(Lic.)SI-V dated 16/01/2014.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

N/12

INSPECTION REPORT

1. Name & address of the building : Parikarma Discotheque Premises in Roof Top Revolving Hotels & Restaurant at 22, K.G. Marg, New Delhi.
2. Type of Occupancy : Assembly building (B + Gr. + 19th floors) at 18th + 19th floor only-
Restaurant
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2011/EH/2228 dated 13/09/11
5. Fire Safety directives Letter No. : NA
6. Date of inspection : 11/03/2014
7. Name of the Inspecting Officer : Sh. Gurmukh Singh (DO/CD) & Sh. M. K. Sharma (ADO/CC)
8. Name and designation of Officer
from the building side : Mr. Naresh Tyagi (Manager)
9. Year of Construction : 1990
10. Applicant's letter No. : No. MOH/167/D/CMO (Lic.)/SI-V dated 16/01/2014.

S No	Minimum standards on fire prevention and fire safety U/R 33	Existing Requirements	Provided at site	Remarks
1.	Access of building			MR/NMR
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	12 Mtr 5 Mtr 6 Mtr	30 Mtr 6 Mtr 6 Mtr	MR MR MR
2.	Number, width, Type & Arrangements of exits (from 16 th to 19 th floor s/case 150 cms & 80 cms)			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper floors Basements 	03 up to 15 th floor 2 Nos.	03 up to 15 th floor 2 Nos.	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper floors (16th to 19th floor) Basements 	80 cm & 125 cm old case old case	80 cm & 125 cm old case old case	MR MR MR
	c. Protection of exits			

MW

	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1 No. (old case)	1 No.(old case)	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	30 ACPH	Mechanical	MR
	• Upper floors	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	• Total numbers	20 Nos.	24 Nos.	MR
	• Types	ABC, CO ₂ , Wco ₂	ABC, CO ₂ , Wco ₂	MR
	• IS marking	Required	Provided	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	1 No. each floor	1 No. each floor	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	05 MM	05 MM	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler			

N/14

	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	150 MM	150 MM	MR
		01	01	MR
		01	01	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head auto Staring/Manual stopping Pump House Access 	2280 LPM	2280 LPM	MR
		100 Mtr.	100 Mtr.	MR
		01	01	MR
		220 LPM	220 LPM	MR
		100 Mtr.	100 Mtr.	MR
		2280 LPM	2280 LPM	MR
		100 Mtr.	100 Mtr.	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	900 LPM	900 LPM	MR
		20 Mtr.	20 Mtr.	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Under ground tank capacity Draw of connection Fire service inlet 	2,00,000 Ltr. common	3,00,000 Ltr. common	MR
		Required	Provided	MR
		Required	Provided	MR

mcw

N/15

	<ul style="list-style-type: none"> Access to tank 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	20,000 Ltr.	20,000 Ltr.	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	Required	Provided	MR
	<ul style="list-style-type: none"> Pressurization of lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> Communication in lift Car 	Required	Provided	MR
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	Required	Provided	MR
	<ul style="list-style-type: none"> Lift Signage 	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area 			
	<ul style="list-style-type: none"> Location 	16 th floor	16 th floor	MR
19	Fire control room			
	<ul style="list-style-type: none"> Detector system panel 	NA	NA	NA
	<ul style="list-style-type: none"> Flow Switch Panel 	NA	NA	NA
	<ul style="list-style-type: none"> PA System Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Batter backup 	NA	NA	NA
	<ul style="list-style-type: none"> Building Floor Plans 	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Open headed spray nozzle at LPG	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/2011/EH/2228 dated 13/09/2011 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Name :- Sh. Gurmukh Singh
Designation :-DO(CD)

Name:- Sh. M. K. Sharma
Designation :- A. D.O. (CC)