

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.

E-mail:- [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in)

Fax:- 011-23412593

No. F.6/DFS/MS/School/2014/ 52/439

Dated: 03/04/14

FIRE SAFETY CERTIFICATE

Certified that the **Convent of Gagan Bharti** located at K-4 Block, Mohan Garden, New Delhi-110059 having two blocks namely Old Block & New Block. Both Blocks are comprised of ground floor plus three upper floors was issued NOC by this department vide letter No.F.6/DFS/MS/2010/2524 dated 31.08.2010 for Old Block. The School building was re-inspected by the officer concerned of this department on 20.03.2014 in the presence of Sh. Rajesh Gupta (Principal) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....03/04/14..... at New Delhi.

(DR. G.C. MISRA)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Ph:-011-23414333

Copy to:-

1. The Principal,  
Convent of Gagan Bharti,  
K-4 Block, Mohan Garden, New Delhi-59.
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi – 110 054.

o/c m/s

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

N/17

Ground floor plus three upper floors (Two blocks)

**INSPECTION REPORT**

1. Name & address of the building : Convent of Gagan Bharti, K-4 Block, Mohan Garden, N.D-59.
2. Type of Occupancy : Educational (School)
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F-6/DFS/MS/2010/2524 Date 31.08.2010
5. Fire Safety directives letter No : -
6. Date of inspection : 20.03.2014
7. Name of Inspecting Officer : A.D.O Sandeep Duggal
8. Name and designation of officers  
From the building side : Sh. Rajesh Gupta (Principal)
9. Year of Construction : 2000 & 2013
10. Applicant's letter No. : CGB/XIV/1 dated 06.03.2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building <ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible	07.50mtr & 5.50mtr 320cms, 270, 250cms	MR -
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases <ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	Old Block - 02 New Block - 01	Old Block - 03 New Block - 01	MR NO Basement
	b. Width of staircases <ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	150 cms Each	Old Block - 140 to 130, 125, 120 cms New Block - 150 cms	MR NO Basement
	c. Protection of exits <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• pressurization</li> </ul>	-	-	-
	d. No. of continuous staircases to terrace	-	Two	-
	e. Width of Corridor	-	140cms & 225cms	-
	f. Door Size	100 cms	120cms to 100cms	-
3.	Compartmentation <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	-	-	-
4.	Smoke Management System <ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour	- Natural Ventilation	NO Basement MR

San



N/8

		12 a/c per hour		
5.	Fire Extinguishers			
	• Total numbers	23 Nos	Provided	MR
	• Types	ABC, CO <sub>2</sub>	- do -	MR
	• IS marking	ISI marked	ISI Marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One in each block Floor	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-	-	+
	• Location of Main Panel	-	-	+
	• Location of Repeater Panel	-	-	+
	• Alternate source of power	-	-	+
	• Hooters' Location	-	-	+
8.	MOEFA			
9.	Public Address System			
		-	Provided	+
10.	Automatic Sprinkler System			
	• Basement	-	-	No Basement
	• Upper Floor	-	-	-
	• Sprinkler above false ceiling	-	+	-
11.	Internal Hydrants			
	• Size of riser/down-comer	-	100 M.M in Old Block	-
	• Number of hydrants per floor	-	One in Old Block	-
	• Hose Box	-	- do -	-
12.	Yard Hydrants			
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-

San

N/A

Convent of gagan ...  
K-4 Block, Mohan Garden,  
New Delhi - 110059.

	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>	—	—	—
		450 LPM	900 LPM	MR
		40M	40M	MR
		Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	—	—	—
		—	Provided	—
		—	—	—
		10000 Ltr	10000 Ltr	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	—	—	No Lift
		—	—	-do-
		—	—	-do-
		—	—	-do-
		—	—	-do-
<b>17.</b>	<b>Standby power supply</b>	—	Provided	—
<b>18.</b>	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	—	—	—
		—	—	—
<b>19.</b>	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	—	—	—

SAM

2/10  
N/10  
The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2010/2524 dated 31.08.2010 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Sandeep  
25/3/14  
Signature of Inspecting Officer

Name Sandeep Duggal

Designation Asstt. Divisional Officer.

Signature of Inspecting Officer

Name

Designation

DO (sw)

F.S.C. for G+3 school building is put up for approval please.

P. Kumar  
29/3/14